

YECHEON AP, Korea, Republic of

WMO: 471340

Lat: 36.632N

Lon: 128.355E

Elev: 354

StdP: 14.51

Time Zone: 9.00 (E09)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	13.8	-2.0	5.0	15.0	1.5	6.0	17.3	21.5	27.1	19.9	29.5	2.8	290	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	92.4	78.4	89.6	76.4	86.4	74.6	79.9	88.8	78.6	87.0	77.2	84.4	4.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	144.0	84.1	75.9	137.1	82.4	75.1	133.5	81.3	43.6	89.8	42.2	87.8	40.8	83.9	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.0	12.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	4.0	83.7	2.4	1.0	2.3	84.4	0.8	85.0	-0.5	85.5	-2.3	86.2	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.1	27.8	32.6	42.0	53.9	63.1	71.0	76.7	78.1	68.2	56.9	44.5	33.2		
	DBStd	17.96	6.36	6.76	5.65	6.37	4.58	4.10	4.69	4.28	5.17	6.12	6.46	6.28		
	HDD50	2183	687	487	254	31	0	0	0	0	0	17	186	521		
	HDD65	5088	1152	907	713	336	90	6	0	0	26	256	616	986		
	CDD50	3679	0	0	5	148	405	630	827	871	545	229	19	0		
	CDD65	1112	0	0	0	3	30	186	362	406	121	4	0	0		
	CDH74	9040	0	0	0	81	493	1451	2841	3350	752	72	0	0		
	CDH80	3139	0	0	0	6	76	437	1112	1355	151	2	0	0		
(14) Wind	WSAvg	3.3	4.6	4.4	4.8	4.0	3.3	2.6	2.4	2.3	2.3	2.5	3.2	3.8		
(15) Precipitation	PrecAvg	49.8	0.8	1.2	1.9	3.3	4.1	6.3	11.4	10.6	5.8	2.0	1.6	0.9		
	PrecMax	73.3	2.6	4.0	4.7	8.0	8.4	14.7	27.8	22.7	14.0	6.6	5.9	2.2		
	PrecMin	30.0	0.0	0.0	0.3	0.6	0.7	1.3	3.4	2.6	1.1	0.1	0.2	0.1		
	PrecStd	10.7	0.6	1.0	1.0	1.8	1.9	3.5	5.3	5.7	3.7	1.7	1.3	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	54.0	66.3	80.9	85.6	89.9	96.7	95.6	87.7	79.1	67.6	55.7		
		MCWB	41.7	45.9	52.2	62.3	68.3	70.9	79.5	80.1	74.8	65.0	57.2	47.5		
	2%	DB	44.2	50.1	61.1	76.7	82.3	87.6	92.4	93.2	84.1	75.5	63.0	50.4		
		MCWB	37.7	41.7	48.4	59.8	64.1	69.7	79.2	78.5	72.1	63.0	52.8	43.2		
	5%	DB	41.0	46.6	57.4	73.1	79.2	84.6	89.5	90.1	80.9	72.0	60.4	47.8		
		MCWB	35.5	40.6	46.2	57.2	62.4	69.3	77.4	77.1	69.9	60.6	51.9	41.5		
	10%	DB	37.8	44.3	53.7	68.4	76.8	82.3	86.2	87.7	78.6	69.5	56.3	44.4		
		MCWB	33.3	39.0	44.2	55.0	61.6	68.1	76.1	76.9	69.1	59.3	50.0	39.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	46.9	54.6	66.6	70.3	75.8	81.8	82.0	77.9	68.4	59.6	48.5		
		MCDB	47.4	50.6	61.3	74.2	81.4	83.2	91.5	91.6	82.9	76.8	64.4	54.4		
	2%	WB	38.6	44.1	50.2	62.2	67.5	73.6	79.9	80.1	74.8	65.2	56.0	44.9		
		MCDB	42.6	48.4	59.5	72.6	76.5	81.4	89.2	89.2	80.7	71.7	60.5	49.2		
	5%	WB	36.2	41.5	47.5	59.2	65.1	72.0	78.6	78.9	72.7	62.7	53.3	41.9		
		MCDB	40.0	45.5	55.0	68.9	74.8	79.4	87.5	87.4	78.3	69.6	58.6	46.0		
	10%	WB	33.8	39.3	45.2	56.7	63.0	70.2	77.2	77.7	70.8	60.5	50.6	39.4		
		MCDB	37.2	43.2	52.0	66.3	73.2	78.6	84.5	85.3	76.1	67.6	55.5	43.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.7	18.9	21.0	25.0	23.6	19.8	15.6	16.7	19.6	24.1	21.5	19.4		
		MCDBR	20.8	22.2	27.9	31.3	29.9	25.6	21.0	21.1	21.5	27.3	26.5	23.0		
	5% WB	MCWBR	16.3	16.1	17.6	16.8	14.8	11.8	9.7	9.3	11.0	16.1	17.3	16.7		
		MCWBR	19.1	18.9	24.4	25.6	24.6	19.7	18.7	18.0	16.9	23.5	23.0	20.8		
(40) Clear-Sky Solar Irradiance	taub		0.409	0.462	0.551	0.584	0.592	0.650	0.609	0.555	0.480	0.460	0.436	0.403		
	taud		2.007	1.910	1.742	1.722	1.745	1.687	1.845	1.978	2.126	2.051	2.036	2.047		
	Ebn at Noon		234	237	226	229	230	216	224	234	246	235	223	226		
	Edh at Noon		42	52	68	73	72	77	65	56	46	45	41	38		
(44) All-Sky Solar Radiation	RadAvg		823	1059	1367	1571	1775	1635	1367	1375	1243	1130	819	735		
	RadStd		49	100	136	121	157	123	182	186	145	94	102	55		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+142	+76

Nomenclature: See separate page