

YECHEON AP, Korea, Republic of

WMO: 471340

Lat: 36.632N

Lon: 128.355E

Elev: 108

StdP: 100.04

Time Zone: 9.00 (E09)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -12.0	(c) -10.1	(d) -18.9	(e) 0.7	(f) -9.4	(g) -16.9	(h) 0.9	(i) -8.2	(j) 9.6	(k) -2.7	(l) 8.9	(m) -1.4	(n) 1.3	(o) 290	(p) 0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.3	(c) 33.6	(d) 25.8	(e) 32.0	(f) 24.7	(g) 30.2	(h) 23.7	(i) 26.6	(j) 31.6	(k) 25.9	(l) 30.5	(m) 25.1	(n) 29.1	(o) 2.0	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.6	28.9	24.4	19.6	28.0	24.0	19.1	27.4	83.5	32.1	80.2	31.0	77.1	28.8	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a) 8.1	(b) 6.7	(c) 5.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	
(a) 8.1	(b) 6.7	(c) 5.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-2.3	0.3	5.6	12.2	17.3	21.7	24.8	25.6	20.1	13.8	6.9	0.7
	DBStd	9.98	3.54	3.76	3.14	3.54	2.55	2.28	2.61	2.38	2.87	3.40	3.59	3.49
	HDD10.0	1213	382	271	141	17	0	0	0	0	9	103	289	
	HDD18.3	2827	640	504	396	187	50	3	0	14	142	342	548	
	CDD10.0	2044	0	0	3	82	225	350	459	484	303	127	11	0
	CDD18.3	618	0	0	0	2	17	103	201	226	67	2	0	0
	CDH23.3	5022	0	0	0	45	274	806	1578	1861	418	40	0	0
	CDH26.7	1744	0	0	0	3	42	243	618	753	84	1	0	0
(14) Wind	WSAvg	1.5	2.0	2.0	2.1	1.8	1.5	1.2	1.1	1.0	1.0	1.1	1.4	1.7
(15) Precipitation	PrecAvg	1266	20	31	49	85	104	159	289	268	148	52	40	23
	PrecMax	1862	67	101	119	202	213	374	705	576	356	167	149	57
	PrecMin	761	1	1	8	14	18	32	86	66	27	2	4	3
	PrecStd	272	16	25	26	46	47	90	135	145	93	42	33	16
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	12.2	19.1	27.2	29.8	32.2	36.0	35.4	30.9	26.2	19.8	13.2
		MCWB	5.4	7.7	11.2	16.8	20.2	21.6	26.4	26.7	23.8	18.3	14.0	8.6
	2%	DB	6.8	10.0	16.2	24.8	28.0	30.9	33.6	34.0	28.9	24.1	17.2	10.2
		MCWB	3.2	5.4	9.1	15.5	17.8	21.0	26.2	25.8	22.3	17.2	11.6	6.2
	5%	DB	5.0	8.1	14.1	22.8	26.2	29.2	32.0	32.3	27.2	22.2	15.8	8.8
		MCWB	2.0	4.8	7.9	14.0	16.9	20.7	25.2	25.1	21.1	15.9	11.0	5.3
	10%	DB	3.2	6.8	12.1	20.2	24.9	28.0	30.1	30.9	25.9	20.8	13.5	6.9
		MCWB	0.7	3.9	6.8	12.8	16.4	20.1	24.5	24.9	20.6	15.2	10.0	3.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	8.3	12.5	19.2	21.3	24.4	27.7	27.8	25.5	20.2	15.3	9.2
		MCDB	8.5	10.3	16.3	23.4	27.5	28.4	33.1	33.1	28.3	24.9	18.0	12.4
	2%	WB	3.7	6.7	10.1	16.8	19.7	23.1	26.6	26.7	23.8	18.5	13.3	7.2
		MCDB	5.9	9.1	15.3	22.6	24.7	27.4	31.8	31.8	27.0	22.0	15.8	9.6
	5%	WB	2.3	5.3	8.6	15.1	18.4	22.2	25.9	26.1	22.6	17.1	11.8	5.5
		MCDB	4.5	7.5	12.8	20.5	23.8	26.3	30.8	30.8	25.7	20.9	14.8	7.8
	10%	WB	1.0	4.1	7.3	13.7	17.2	21.2	25.1	25.4	21.5	15.8	10.3	4.1
		MCDB	2.9	6.2	11.1	19.1	22.9	25.9	29.2	29.6	24.5	19.8	13.0	6.3
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.5	11.7	13.9	13.1	11.0	8.7	9.3	10.9	13.4	11.9	10.8
		MCDBR	11.5	12.3	15.5	17.4	16.6	14.2	11.7	11.7	11.9	15.2	14.7	12.8
	5% WB	MCWBR	9.0	9.0	9.8	9.4	8.2	6.6	5.4	5.2	6.1	9.0	9.6	9.3
		MCWBR	10.6	10.5	13.6	14.2	13.7	11.0	10.4	10.0	9.4	13.1	12.8	11.6
(40) Clear-Sky Solar Irradiance	taub	0.409	0.462	0.551	0.584	0.592	0.650	0.609	0.555	0.480	0.460	0.436	0.403	
		2.007	1.910	1.742	1.722	1.745	1.687	1.845	1.978	2.126	2.051	2.036	2.047	
	Ebn at Noon	738	746	714	721	724	682	707	737	774	742	704	713	
		132	165	214	230	228	242	205	176	144	141	128	120	
(44) All-Sky Solar Radiation	RadAvg	2.60	3.34	4.31	4.95	5.60	5.15	4.31	4.34	3.92	3.56	2.58	2.32	
	RadStd	0.15	0.32	0.43	0.38	0.50	0.39	0.57	0.58	0.46	0.29	0.32	0.17	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+79	+42

Nomenclature: See separate page