

POHANG, Korea, Republic of

WMO: 471380

Lat: 36.0319N

Lon: 129.3800E

Elev: 12

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	23.7	-7.5	3.7	26.5	-3.8	4.5	28.8	18.9	37.9	16.2	36.1	8.2	250	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	93.5	77.8	90.7	76.5	88.0	75.8	80.0	88.4	78.9	86.7	77.9	85.3	8.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.9	144.9	84.2	76.7	139.1	83.4	75.6	134.0	82.6	43.7	88.6	42.4	86.8	41.4	85.4	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.4	13.4	11.9	DB	15.5	97.1	3.9	2.5	12.7	98.9	10.4	100.4	8.2	101.8	5.3	103.6
			WB	11.7	81.5	3.4	1.9	9.2	82.9	7.2	84.0	5.3	85.1	2.8	86.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	36.5	40.1	47.7	57.7	66.0	71.5	78.5	79.6	71.7	63.1	51.7	40.4	(6)
(7)		DBStd	15.85	6.22	6.50	6.58	6.52	5.93	5.46	6.39	5.18	4.34	5.02	6.60	6.83	(7)
(8)		HDD50	1200	420	282	124	10	0	0	0	0	1	59	304		(8)
(9)		HDD65	3680	884	696	537	234	62	6	1	0	1	95	400	764	(9)
(10)		CDD50	4411	1	6	52	241	495	644	882	917	652	406	110	5	(10)
(11)		CDD65	1416	0	0	0	15	92	200	418	452	204	34	1	0	(11)
(12)		CDH74	11303	0	0	3	117	609	1252	4015	4338	899	69	1	0	(12)
(13)		CDH80	3979	0	0	0	18	140	370	1666	1593	189	3	0	0	(13)
(14)	Wind	WSAvg	5.9	6.5	6.2	6.3	6.4	5.8	5.2	5.5	5.4	5.5	5.6	5.7	6.2	(14)
(15)	Precipitation	PrecAvg	44.4	1.4	1.6	2.5	3.2	3.1	5.0	7.7	7.8	6.7	2.6	1.8	1.0	(15)
(16)		PrecMax	82.6	5.5	6.2	6.4	7.0	10.7	14.7	22.7	22.8	24.3	10.3	6.2	5.6	(16)
(17)		PrecMin	23.6	0.0	0.0	0.1	0.3	0.5	0.4	0.6	0.8	0.4	0.0	0.0	0.0	(17)
(18)		PrecStd	11.6	1.2	1.3	1.5	1.7	1.9	3.3	5.0	4.8	4.9	2.5	1.7	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	63.9	72.6	82.5	88.1	91.5	96.5	96.6	89.2	79.1	71.5	60.4	(19)
(20)		MCWB	46.3	54.0	53.4	60.4	64.8	71.1	78.9	77.8	75.8	64.6	58.6	51.0		(20)
(21)		2%	DB	50.8	57.3	66.7	77.3	83.7	87.6	93.9	93.6	85.0	75.7	67.5	55.9	(21)
(22)		MCWB	42.3	47.6	50.7	58.2	62.7	71.4	78.3	78.0	73.3	64.6	57.4	47.5		(22)
(23)		5%	DB	48.0	53.1	62.6	73.1	80.6	84.3	91.2	90.9	81.6	73.4	64.6	53.1	(23)
(24)		MCWB	40.5	43.5	50.5	55.8	62.3	70.2	77.4	77.4	72.2	63.8	55.7	45.3		(24)
(25)		10%	DB	45.6	49.8	58.7	69.3	77.1	81.1	88.5	87.7	78.8	71.2	61.7	50.5	(25)
(26)		MCWB	38.6	41.9	47.9	54.5	61.2	69.0	77.0	77.1	70.5	62.3	53.6	43.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.4	57.1	58.6	66.9	70.9	76.5	81.7	81.9	78.2	71.9	63.5	54.0	(27)
(28)		MCDWB	52.8	61.3	63.9	73.5	78.5	85.3	91.7	89.8	84.9	74.3	66.8	56.5		(28)
(29)		2%	WB	44.8	48.9	55.0	62.0	67.5	74.6	80.0	80.3	76.1	68.5	59.9	49.7	(29)
(30)		MCDWB	48.0	54.1	63.2	71.9	76.1	82.5	89.7	88.0	82.7	72.6	65.0	54.8		(30)
(31)		5%	WB	42.2	45.6	51.5	59.4	65.4	72.8	78.9	79.2	74.0	66.0	57.4	46.8	(31)
(32)		MCDWB	46.5	51.2	59.9	67.5	74.4	80.4	88.2	86.3	79.3	70.9	62.9	51.9		(32)
(33)		10%	WB	39.7	43.1	48.8	57.1	63.7	71.0	77.7	78.3	72.2	64.0	55.1	44.1	(33)
(34)		MCDWB	44.6	48.7	56.8	65.1	72.8	78.0	86.3	84.9	77.1	69.5	60.4	49.6		(34)
(35)	Mean Daily Temperature Range		MDBR	13.5	14.1	14.9	15.5	14.7	11.3	10.3	10.0	10.5	13.3	14.2	13.7	(35)
(36)		5% DB	MCDBR	15.3	17.9	20.9	22.1	21.1	17.7	14.9	15.3	14.4	15.5	16.6	16.1	(36)
(37)		MCWBR	10.8	11.5	11.9	10.4	9.0	7.0	4.9	4.8	6.5	8.2	9.9	11.4	(37)	
(38)		5% WB	MCDBR	12.5	14.6	17.4	17.1	15.8	14.2	13.4	12.0	11.4	11.3	13.1	13.9	(38)
(39)		MCWBR	10.8	11.3	11.8	10.6	9.2	6.7	5.2	5.2	6.2	7.8	9.6	11.8	(39)	
(40)		Clear-Sky Solar Irradiance	taub	0.419	0.479	0.566	0.600	0.609	0.651	0.616	0.567	0.502	0.478	0.443	0.411	(40)
(41)	taud		2.024	1.909	1.737	1.716	1.739	1.715	1.856	1.973	2.092	2.036	2.044	2.059	(41)	
(42)	Ebn at Noon		233	233	224	226	226	216	223	231	240	231	223	226	(42)	
(43)	Edh at Noon		42	53	69	74	73	75	64	56	48	46	41	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	842	1035	1340	1566	1724	1557	1412	1417	1195	1098	840	763	(44)	
(45)		RadStd	67	126	132	118	169	136	208	167	134	107	111	56	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page