

POHANG, Korea, Republic of

WMO: 471380

Lat: 36.0319N

Lon: 129.3800E

Elev: 4

StdP: 101.28

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-4.6	-22.0	0.5	-3.0	-19.9	0.6	-1.8	8.4	3.3	7.2	2.3	3.7	250	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	34.2	25.4	32.6	24.7	31.1	24.3	26.7	31.3	26.1	30.4	25.5	29.6	3.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.7	29.0	24.8	19.9	28.6	24.2	19.1	28.1	83.7	31.5	80.8	30.4	78.4	29.6	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	6.0	5.3	DB	-9.1	36.2	2.2	1.4	-10.7	37.2	-12.0	38.0	-13.2	38.8	-14.8	39.8	(4)
(5)			WB	-11.3	27.5	1.9	1.1	-12.7	28.3	-13.8	28.9	-14.9	29.5	-16.2	30.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	2.5	4.5	8.7	14.3	18.9	21.9	25.8	26.4	22.1	17.3	10.9	4.6	(6)	
	DBStd	8.80	3.46	3.61	3.66	3.62	3.30	3.03	3.55	2.88	2.41	2.79	3.67	3.80	(7)	
	HDD10.0	667	233	157	69	6	0	0	0	0	0	1	33	169	(8)	
	HDD18.3	2044	491	387	298	130	34	3	1	0	1	53	222	424	(9)	
	CDD10.0	2451	1	3	29	134	275	358	490	509	362	226	61	3	(10)	
	CDD18.3	787	0	0	0	8	51	111	232	251	113	19	1	0	(11)	
	CDH23.3	6279	0	0	2	65	338	696	2231	2410	499	38	1	0	(12)	
	CDH26.7	2211	0	0	0	10	78	206	926	885	105	2	0	0	(13)	
(14) Wind	WSAvg	2.6	2.9	2.8	2.8	2.9	2.6	2.3	2.5	2.4	2.5	2.5	2.6	2.8	(14)	
(15) Precipitation	PrecAvg	1128	35	41	63	81	79	126	196	198	171	66	46	26	(15)	
	PrecMax	2099	140	158	162	177	272	374	577	579	618	262	158	143	(16)	
	PrecMin	600	0	0	2	7	12	10	14	20	11	0	0	0	(17)	
	PrecStd	295	30	34	39	42	47	83	127	121	124	63	44	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	17.7	22.6	28.1	31.2	33.1	35.8	35.9	31.8	26.2	22.0	15.8	(19)	
		MCWB	7.9	12.2	11.9	15.8	18.2	21.7	26.1	25.5	24.4	18.1	14.8	10.5	(20)	
	2%	DB	10.4	14.0	19.3	25.1	28.7	30.9	34.4	34.2	29.5	24.3	19.7	13.3	(21)	
		MCWB	5.7	8.7	10.4	14.6	17.1	21.9	25.7	25.5	23.0	18.1	14.1	8.6	(22)	
	5%	DB	8.9	11.7	17.0	22.8	27.0	29.1	32.9	32.7	27.5	23.0	18.1	11.7	(23)	
		MCWB	4.7	6.4	10.3	13.2	16.8	21.2	25.2	25.2	22.3	17.7	13.2	7.4	(24)	
	10%	DB	7.6	9.9	14.8	20.7	25.0	27.3	31.4	31.0	26.0	21.8	16.5	10.3	(25)	
		MCWB	3.7	5.5	8.8	12.5	16.2	20.5	25.0	25.1	21.4	16.8	12.0	6.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	13.9	14.8	19.4	21.6	24.7	27.6	27.7	25.7	22.2	17.5	12.2	(27)	
		MCDB	11.6	16.3	17.7	23.0	25.8	29.6	33.2	32.1	29.4	23.5	19.3	13.6	(28)	
	2%	WB	7.1	9.4	12.8	16.7	19.7	23.7	26.7	26.9	24.5	20.3	15.5	9.8	(29)	
		MCDB	8.9	12.3	17.3	22.2	24.5	28.0	32.0	31.1	28.1	22.6	18.3	12.7	(30)	
	5%	WB	5.6	7.6	10.9	15.2	18.5	22.7	26.0	26.2	23.3	18.9	14.1	8.2	(31)	
		MCDB	8.0	10.7	15.5	19.7	23.6	26.9	31.2	30.1	26.3	21.6	17.2	11.1	(32)	
	10%	WB	4.3	6.2	9.3	14.0	17.6	21.7	25.4	25.7	22.3	17.8	12.8	6.7	(33)	
		MCDB	7.0	9.3	13.8	18.4	22.6	25.6	30.2	29.4	25.0	20.8	15.8	9.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.8	8.3	8.6	8.2	6.3	5.7	5.5	5.8	7.4	7.9	7.6	(35)	
		MCDBR	8.5	10.0	11.6	12.3	11.7	9.8	8.3	8.5	8.0	8.6	9.2	8.9	(36)	
	5% WB	MCWBR	6.0	6.4	6.6	5.8	5.0	3.9	2.7	2.7	3.6	4.6	5.5	6.3	(37)	
		MCWBR	7.0	8.1	9.7	9.5	8.8	7.9	7.4	6.7	6.3	6.3	7.3	7.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.419	0.479	0.566	0.600	0.609	0.651	0.616	0.567	0.502	0.478	0.443	0.411	(40)	
		taud	2.024	1.909	1.737	1.716	1.739	1.715	1.856	1.973	2.092	2.036	2.044	2.059	(41)	
	Ebn at Noon	Ebn at Noon	734	734	705	711	713	682	703	729	756	728	704	713	(42)	
		Edh at Noon	132	167	216	232	230	235	203	177	150	145	129	120	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.65	3.26	4.22	4.94	5.43	4.91	4.45	4.47	3.77	3.46	2.65	2.40	(44)	
	RadStd	RadStd	0.21	0.40	0.42	0.37	0.53	0.43	0.66	0.53	0.42	0.34	0.35	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+76	N/A	(47)	

Nomenclature: See separate page