

POHANG AP, Korea, Republic of

WMO: 471390

Lat: 35.988N

Lon: 129.420E

Elev: 70

StdP: 14.66

Time Zone: 9.00 (E09)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	21.6	-2.4	4.9	26.3	1.2	5.9	26.8	25.1	38.0	22.7	34.3	12.5	270	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.4	93.2	78.6	90.9	77.8	87.8	76.6	80.3	89.7	79.2	87.7	78.1	85.7	9.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	143.0	84.6	76.9	140.4	84.2	75.5	133.7	83.0	44.0	90.6	42.7	87.6	41.6	85.6	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.5	18.7	16.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			12.3	84.3	3.6	1.3	9.7	85.2	7.6	86.0	5.6	86.7	3.0	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.4	34.9	37.9	45.3	56.0	64.3	69.9	77.3	78.8	70.4	60.9	50.5	41.0
	DBStd	15.83	6.16	6.34	5.48	6.50	5.79	5.70	6.44	4.79	4.86	5.46	6.42	6.25
	HDD50	1348	468	341	166	16	0	0	0	0	0	3	71	283
	HDD65	4019	933	759	612	280	86	15	2	0	8	144	436	744
	CDD50	4039	0	2	19	196	443	596	848	893	612	341	85	4
	CDD65	1234	0	0	0	10	63	161	385	428	169	18	0	0
	CDH74	9835	0	0	1	85	503	1093	3533	3746	784	88	2	0
	CDH80	3511	0	0	0	17	102	356	1444	1389	195	8	0	0
Wind	WSAvg	7.8	10.0	8.9	8.6	8.2	7.2	6.5	6.6	7.1	7.0	7.0	7.7	8.7
Precipitation	PrecAvg	44.4	1.4	1.6	2.5	3.2	3.1	5.0	7.7	7.8	6.7	2.6	1.8	1.0
	PrecMax	82.6	5.5	6.2	6.4	7.0	10.7	14.7	22.7	22.8	24.3	10.3	6.2	5.6
	PrecMin	23.6	0.0	0.0	0.1	0.3	0.5	0.4	0.6	0.8	0.4	0.0	0.0	0.0
	PrecStd	11.6	1.2	1.3	1.5	1.7	1.9	3.3	5.0	4.8	4.9	2.5	1.7	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	61.2	67.6	82.7	87.4	93.0	96.7	96.7	89.8	80.6	72.0	62.8
		MCWB	45.1	51.2	51.4	63.7	68.4	73.2	80.2	79.5	77.3	66.5	58.5	50.7
	2%	DB	49.8	54.0	62.5	75.6	82.7	87.8	93.4	93.2	84.6	76.6	67.6	57.5
		MCWB	41.7	44.8	49.9	59.9	64.6	71.8	79.0	79.3	74.0	64.1	56.9	47.8
	5%	DB	47.0	50.3	58.8	71.8	79.8	84.0	91.2	90.5	81.3	73.2	64.2	53.9
		MCWB	40.3	42.6	47.5	57.6	63.4	70.7	78.3	78.6	72.0	62.7	55.0	45.4
	10%	DB	44.7	47.8	55.2	68.1	76.6	80.5	87.9	87.7	78.5	70.1	61.0	51.5
		MCWB	38.9	40.9	45.6	56.0	62.6	69.1	77.6	78.0	71.3	61.9	53.9	44.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	54.5	56.8	68.4	71.2	76.9	82.4	82.1	78.8	69.7	61.9	53.8
		MCDB	51.5	60.5	61.7	73.7	80.0	86.3	92.4	90.8	87.3	75.3	67.2	61.7
	2%	WB	44.1	47.7	52.4	63.7	68.5	74.7	80.4	80.6	76.4	67.0	59.5	49.8
		MCDB	47.2	52.8	59.3	74.5	78.0	82.7	90.5	89.7	82.7	72.5	64.5	56.0
	5%	WB	41.4	43.9	49.6	59.9	66.3	72.6	79.2	79.5	74.4	65.1	57.1	46.9
		MCDB	45.8	48.2	54.9	68.5	76.0	80.4	88.3	87.8	79.6	70.7	62.6	52.8
	10%	WB	39.2	41.6	47.1	57.3	64.0	70.4	78.1	78.6	72.2	63.4	54.9	44.3
		MCDB	44.1	46.0	53.1	64.8	73.3	78.6	86.4	85.9	76.7	69.1	60.0	49.8
Mean Daily Temperature Range	5% DB	MDBR	15.6	15.1	15.8	17.3	17.5	13.5	12.1	11.4	12.5	16.5	17.0	16.5
		MCDBR	17.8	20.0	22.1	24.0	24.3	21.3	17.5	17.2	17.7	20.1	21.2	21.4
		MCWBR	13.5	13.7	13.7	13.1	11.8	10.0	8.0	7.7	9.1	11.2	13.7	14.4
	5% WB	MCDBR	16.8	15.3	18.1	20.4	19.9	17.6	16.1	15.1	14.3	15.9	18.3	19.8
		MCWBR	14.3	12.0	13.2	13.5	12.2	9.8	8.4	7.7	8.6	10.6	13.4	14.6
Clear-Sky Solar Irradiance	taub	0.416	0.474	0.559	0.592	0.601	0.642	0.609	0.561	0.498	0.473	0.438	0.408	
	taud	2.038	1.924	1.754	1.733	1.757	1.735	1.874	1.990	2.107	2.053	2.059	2.073	
	Ebn at Noon	234	234	226	227	228	218	225	233	241	233	225	228	
	Edh at Noon	41	52	68	72	72	73	63	55	47	45	40	38	
All-Sky Solar Radiation	RadAvg	842	1033	1338	1566	1722	1552	1414	1420	1192	1097	841	763	
	RadStd	68	127	132	119	170	137	210	167	134	108	111	56	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page