

DAEGU INTL, Korea, Republic of

WMO: 471420

Lat: 35.894N

Lon: 128.659E

Elev: 116

StdP: 14.63

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	19.8	-5.7	4.1	28.6	-2.3	4.9	29.2	23.0	31.8	21.2	31.5	6.5	310	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.4	94.9	77.6	91.8	76.5	89.6	75.3	79.9	89.0	78.9	87.7	78.0	86.1	7.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	142.8	83.4	76.8	140.3	83.0	75.4	133.6	82.3	43.5	89.2	42.4	88.0	41.4	85.7	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	17.0	14.7	12.6	97.3	3.7	2.3	9.9	99.0	7.7	100.3	5.6	101.6	2.9	103.2
			10.1	81.8	3.5	1.7	7.6	83.0	5.6	84.0	3.6	84.9	1.1	86.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	32.7	37.9	46.4	57.2	66.8	73.5	79.5	80.6	71.6	60.7	48.4	36.4
	DBStd	17.35	5.61	6.52	6.22	6.28	4.80	4.28	5.29	4.95	5.08	5.70	6.62	6.31
	HDD50	1571	536	343	146	13	0	0	0	0	0	3	108	422
	HDD65	4164	1001	760	576	244	36	1	0	0	6	156	498	886
	CDD50	4397	0	3	35	227	520	706	916	948	647	334	60	1
	CDD65	1517	0	0	0	9	91	258	451	483	203	22	0	0
	CDH74	13853	0	0	4	171	972	2033	4365	4858	1314	135	1	0
	CDH80	5307	0	0	0	24	259	689	1860	2110	359	6	0	0
Wind	WSAvg	5.6	6.3	6.2	6.6	6.5	5.8	5.6	5.2	5.1	4.6	4.4	5.1	6.1
Precipitation	PrecAvg	40.5	0.8	1.0	2.0	2.9	3.0	5.2	8.8	7.8	5.2	1.7	1.5	0.6
	PrecMax	57.4	4.4	3.5	6.0	6.7	5.6	16.5	21.0	15.6	15.7	5.4	5.4	2.2
	PrecMin	22.4	0.0	0.0	0.3	0.7	0.6	0.5	1.7	0.5	0.1	0.0	0.1	0.0
	PrecStd	8.9	0.8	0.9	1.3	1.6	1.5	3.4	4.5	3.8	4.0	1.3	1.2	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.2	64.0	71.9	82.8	89.7	93.1	98.5	98.4	91.3	80.7	71.6	57.6
		MCWB	42.8	51.8	53.5	60.8	64.2	69.2	79.2	78.2	75.3	64.1	59.4	49.8
	2%	DB	48.5	57.4	66.6	78.8	85.9	89.5	94.9	95.2	87.2	77.4	66.6	53.7
		MCWB	39.7	46.9	50.6	59.1	63.0	69.6	78.5	77.7	73.3	62.8	55.4	45.3
	5%	DB	46.2	53.6	62.8	75.1	82.6	86.4	91.7	93.1	84.1	75.0	64.0	50.2
		MCWB	37.6	43.4	49.0	56.6	62.1	68.5	77.6	77.5	71.1	62.1	53.5	43.2
	10%	DB	43.0	49.9	59.1	71.4	80.2	84.2	89.4	89.9	81.0	71.8	60.5	47.9
		MCWB	36.1	40.5	47.8	54.5	61.7	68.2	76.6	77.0	69.6	60.4	52.0	41.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	57.6	58.8	66.1	72.2	76.8	81.7	81.2	78.2	71.0	62.5	52.0
		MCDB	49.3	60.0	62.7	73.9	77.7	83.0	92.9	89.9	85.6	75.3	66.5	56.2
	2%	WB	41.4	48.3	55.2	62.1	68.6	74.9	80.0	80.0	76.2	67.6	58.5	47.4
		MCDB	45.8	54.6	62.8	73.0	77.7	81.4	89.7	88.9	83.3	72.6	64.6	51.6
	5%	WB	39.3	44.6	51.2	59.3	65.9	72.9	78.9	79.1	74.3	65.0	55.7	44.5
		MCDB	43.7	50.8	60.7	69.9	75.8	80.4	88.0	87.8	80.7	71.3	61.3	48.5
	10%	WB	36.8	41.9	48.4	56.9	64.1	71.1	78.0	78.3	72.1	62.1	53.1	41.6
		MCDB	42.2	47.9	57.4	67.6	74.5	79.6	86.4	86.6	78.0	69.4	59.1	46.7
Mean Daily Temperature Range	5% DB	MDBR	18.1	19.1	21.0	22.4	22.2	18.0	14.5	15.4	17.1	20.7	19.9	17.4
		MCDBR	22.4	25.2	27.6	29.4	28.8	23.9	18.7	19.5	20.2	23.4	24.3	21.4
		MCWBR	14.8	15.7	15.0	13.2	11.5	8.2	6.1	6.0	8.1	11.1	14.1	14.7
	5% WB	MCDBR	19.0	21.1	23.6	23.3	20.8	16.5	16.6	16.2	15.6	16.1	19.4	19.5
		MCWBR	14.4	15.1	14.8	12.9	10.9	7.5	6.5	6.1	7.5	9.3	13.3	14.7
Clear-Sky Solar Irradiance	taub	0.410	0.463	0.547	0.582	0.592	0.645	0.605	0.558	0.490	0.463	0.434	0.404	
	taud	2.031	1.934	1.765	1.740	1.759	1.711	1.865	1.979	2.112	2.065	2.054	2.067	
	Ebn at Noon	237	238	229	230	230	218	226	234	243	236	227	229	
	Edh at Noon	42	52	67	72	71	75	64	56	47	45	40	38	
All-Sky Solar Radiation	RadAvg	865	1078	1386	1586	1767	1594	1406	1413	1232	1145	862	777	
	RadStd	60	108	130	121	168	132	198	180	138	104	105	52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A

Nomenclature: See separate page