

DAEGU AFB, Korea, Republic of

WMO: 471430

Lat: 35.828N

Lon: 128.652E

Elev: 179

StdP: 14.60

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	22.3	-6.8	3.8	28.5	-3.1	4.7	29.4	18.9	33.9	16.6	32.2	6.8	290	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.0	94.2	75.3	91.7	74.7	89.3	73.8	78.3	87.1	77.4	86.1	76.6	85.2	6.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.3	138.1	81.9	75.2	132.9	81.5	74.1	128.2	81.5	42.1	87.7	41.1	86.3	40.3	85.4	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	13.6	11.9	14.5	97.0	3.9	2.4	11.7	98.7	9.4	100.1	7.3	101.5	4.4	103.2	
			11.2	79.6	3.4	1.4	8.7	80.6	6.7	81.4	4.8	82.1	2.3	83.1	
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.6	34.3	38.6	47.4	58.2	67.6	74.0	80.0	80.7	72.0	61.9	49.6	37.8
	DBStd	17.03	5.84	6.47	6.45	6.20	5.13	4.57	5.44	5.02	4.96	5.43	6.55	6.19
	HDD50	1413	487	323	127	8	0	0	0	0	0	2	87	379
	HDD65	3921	952	739	545	217	32	2	0	0	4	124	463	843
	CDD50	4558	0	3	47	254	545	721	929	952	661	371	74	1
	CDD65	1592	0	0	0	13	112	272	464	487	215	29	0	0
	CDH74	14435	0	0	3	144	943	2097	4746	5084	1313	105	0	0
	CDH80	5384	0	0	0	17	235	681	1998	2122	326	5	0	0
Wind	WSAvg	5.1	5.6	5.6	5.8	5.8	5.4	5.3	5.0	5.0	4.5	4.1	4.4	5.1
Precipitation	PrecAvg	40.5	0.8	1.0	2.0	2.9	3.0	5.2	8.8	7.8	5.2	1.7	1.5	0.6
	PrecMax	57.4	4.4	3.5	6.0	6.7	5.6	16.5	21.0	15.6	15.7	5.4	5.4	2.2
	PrecMin	22.4	0.0	0.0	0.3	0.7	0.6	0.5	1.7	0.5	0.1	0.0	0.1	0.0
	PrecStd	8.9	0.8	0.9	1.3	1.6	1.5	3.4	4.5	3.8	4.0	1.3	1.2	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	63.1	72.2	82.4	89.2	92.3	97.4	97.0	90.4	80.2	70.8	57.5
		MCWB	44.0	51.1	52.8	61.1	62.8	68.8	76.0	76.4	73.1	63.5	58.3	48.9
	2%	DB	48.7	56.8	66.8	78.1	85.3	89.1	94.2	94.6	86.5	76.9	66.6	53.3
		MCWB	39.8	45.2	50.1	57.4	62.0	68.2	75.8	75.9	70.8	62.0	55.3	44.0
	5%	DB	45.7	52.7	63.0	74.6	82.5	86.7	91.7	92.2	83.6	74.3	63.4	50.4
		MCWB	37.4	42.4	48.7	55.6	60.9	67.3	75.4	75.7	69.7	61.2	53.2	42.2
	10%	DB	43.4	49.3	59.3	70.8	79.5	84.2	89.3	89.6	81.1	71.6	60.3	47.8
		MCWB	36.1	39.7	47.1	53.9	60.3	66.9	75.0	75.1	68.6	60.3	51.0	40.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	56.1	57.7	66.1	70.1	75.4	79.2	80.3	76.3	70.7	62.2	50.4
		MCDB	50.6	60.4	61.9	72.8	77.8	83.1	87.6	87.7	84.3	73.4	66.9	54.8
	2%	WB	41.8	47.2	54.4	62.1	67.0	73.6	78.2	78.9	74.8	66.8	57.8	46.2
		MCDB	46.2	53.4	62.9	71.7	75.9	81.3	87.2	87.5	82.0	71.9	63.1	51.3
	5%	WB	39.4	43.6	50.6	59.1	65.0	71.9	77.4	77.8	73.3	64.4	55.2	43.5
		MCDB	44.1	50.6	60.4	69.0	75.0	80.2	86.6	86.3	80.4	70.2	61.2	49.0
	10%	WB	37.0	41.1	47.8	56.5	63.3	70.3	76.6	77.0	71.3	61.8	52.9	41.1
		MCDB	42.4	47.9	57.6	66.3	73.9	78.8	85.8	85.3	77.4	69.2	58.8	47.2
Mean Daily Temperature Range	5% DB	MDBR	14.1	15.7	17.5	19.1	19.0	15.7	12.6	13.0	14.3	16.9	16.2	14.7
		MCDBR	17.0	20.4	23.4	25.3	24.8	21.0	16.3	17.0	17.7	19.7	20.3	18.6
		MCWBR	10.9	12.1	12.0	10.0	8.2	6.1	3.9	4.0	5.5	7.8	10.6	11.8
	5% WB	MCDBR	14.7	17.4	19.6	19.4	18.0	14.3	13.9	14.0	12.9	13.7	16.1	17.0
		MCWBR	10.8	12.2	12.5	10.9	9.1	5.9	4.4	4.4	5.6	7.6	10.3	12.2
Clear-Sky Solar Irradiance	taub	0.409	0.462	0.546	0.581	0.591	0.643	0.604	0.557	0.490	0.462	0.433	0.403	
	taud	2.033	1.936	1.768	1.742	1.762	1.714	1.868	1.980	2.111	2.067	2.056	2.069	
	Ebn at Noon	237	239	229	230	231	218	226	234	244	237	227	230	
	Edh at Noon	42	51	67	72	71	75	64	56	47	44	40	38	
All-Sky Solar Radiation	RadAvg	869	1080	1388	1587	1767	1590	1407	1415	1233	1147	866	781	
	RadStd	61	108	130	121	169	133	199	181	137	104	105	51	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	-3.74	N/A	N/A	N/A	N/A	N/A	N/A	+77
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A

Nomenclature: See separate page