

ULSAN, Korea, Republic of

WMO: 471520

Lat: 35.593N

Lon: 129.352E

Elev: 14

StdP: 101.16

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-4.3	-22.3	0.5	-1.8	-20.1	0.6	-0.5	8.1	-1.5	7.2	0.2	3.1	340	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.2	25.0	31.9	24.7	30.6	24.2	26.4	30.4	25.8	29.6	25.2	29.1	3.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	20.6	28.3	24.7	19.8	28.0	24.1	19.0	27.7	82.5	30.5	80.0	29.6	77.5	29.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	6.0	5.3	-8.7	35.1	2.2	1.4	-10.3	36.2	-11.5	37.0	-12.8	37.8	-14.3	38.9		
(5)			-10.8	26.9	1.9	0.9	-12.2	27.6	-13.3	28.2	-14.4	28.7	-15.7	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	2.6	4.5	8.5	13.8	18.5	21.7	25.6	26.4	21.9	16.9	10.7	4.7		
	DBStd	8.63	3.31	3.41	3.38	3.26	2.79	2.43	3.00	2.61	2.44	2.73	3.51	3.54		
	HDD10.0	664	229	157	70	7	0	0	0	0	0	1	33	168		
	HDD18.3	2068	487	388	304	141	33	2	0	0	1	59	228	424		
	CDD10.0	2382	1	2	24	119	262	351	484	509	357	216	56	2		
	CDD18.3	743	0	0	0	4	37	103	226	251	108	15	0	0		
	CDH23.3	5803	0	0	0	27	231	547	2032	2403	522	41	1	0		
	CDH26.7	1859	0	0	0	2	37	110	735	872	103	1	0	0		
(14) Wind	WSAvg	2.2	2.3	2.3	2.4	2.3	2.1	1.9	2.1	2.1	2.1	2.0	2.0	2.3		
(15) Precipitation	PrecAvg	1287	33	40	71	110	104	176	212	220	175	64	54	23		
	PrecMax	2059	120	128	198	223	201	550	620	699	661	295	166	123		
	PrecMin	693	0	0	2	23	10	9	32	23	27	1	0	0		
	PrecStd	347	28	31	44	54	52	113	124	147	129	62	45	25		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	16.8	20.8	26.3	29.8	31.1	34.5	35.3	31.5	26.1	22.0	16.1		
		MCWB	8.3	12.5	12.1	15.9	17.5	21.2	25.4	25.3	23.7	18.8	14.7	10.9		
	2%	DB	11.0	14.2	18.5	23.7	27.6	29.4	33.2	33.5	29.3	24.4	19.8	13.8		
		MCWB	5.8	8.6	10.8	14.1	16.7	20.9	25.0	25.2	22.5	17.9	14.0	8.5		
	5%	DB	9.3	12.1	16.6	21.7	25.8	27.9	32.0	32.3	27.7	23.1	18.2	12.2		
		MCWB	4.5	6.8	10.1	13.0	16.4	20.5	24.8	25.0	22.0	17.4	13.1	7.3		
	10%	DB	7.9	10.2	14.8	20.0	24.3	26.5	30.6	31.0	26.2	21.9	16.7	10.5		
		MCWB	3.6	5.5	9.2	12.8	16.0	20.2	24.5	24.7	21.3	16.5	11.9	6.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	14.2	15.1	18.8	21.5	24.3	27.2	27.2	25.6	22.4	17.5	12.5		
		MCDB	12.2	16.1	17.5	20.6	24.4	27.4	31.6	31.6	28.7	23.8	19.3	14.0		
	2%	WB	7.2	10.2	13.2	16.9	19.7	23.5	26.4	26.6	24.4	20.4	15.7	9.8		
		MCDB	9.4	12.9	16.3	21.5	23.3	26.4	30.5	30.7	27.5	22.4	18.4	12.8		
	5%	WB	5.7	7.6	11.4	15.3	18.4	22.5	25.7	26.0	23.4	18.9	14.1	8.2		
		MCDB	8.1	11.1	15.1	19.2	22.6	25.7	29.7	29.9	26.3	21.6	17.1	11.1		
	10%	WB	4.3	6.1	9.6	14.1	17.6	21.4	25.1	25.5	22.2	17.5	12.7	6.7		
		MCDB	7.2	9.4	13.9	17.6	22.1	24.8	29.3	29.3	25.0	20.8	15.8	9.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.7	9.0	9.6	9.1	7.2	6.2	6.4	6.8	8.6	9.1	8.7		
		MCDBR	10.0	11.4	11.9	12.8	12.1	9.9	8.4	8.6	8.9	9.9	10.8	11.0		
	5% WB	MCWBR	6.7	7.3	6.8	6.2	5.0	3.9	2.6	2.7	3.6	4.9	6.1	7.2		
		MCWBR	8.1	9.8	9.9	9.5	9.1	7.1	7.3	7.0	6.8	7.5	8.6	9.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.412	0.468	0.548	0.581	0.591	0.630	0.600	0.555	0.497	0.468	0.434	0.404		
		taud	2.062	1.952	1.788	1.765	1.791	1.771	1.903	2.016	2.120	2.082	2.085	2.096		
	Ebn at Noon	Ebn at Noon	748	749	723	727	727	697	715	740	763	743	720	727		
		Edh at Noon	128	160	206	221	219	223	194	170	146	139	124	117		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.68	3.27	4.26	4.96	5.44	4.83	4.48	4.55	3.77	3.51	2.71	2.45		
	RadStd	RadStd	0.22	0.40	0.42	0.39	0.56	0.45	0.70	0.54	0.41	0.34	0.35	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+62	N/A

Nomenclature: See separate page