

YEOSU, Korea, Republic of

WMO: 471680

Lat: 34.7392N

Lon: 127.7406E

Elev: 215

StdP: 14.58

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	26.0	-1.6	5.1	31.6	2.3	6.2	32.3	30.3	34.4	28.0	34.3	14.2	320	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	87.6	77.6	85.6	77.0	83.7	76.2	79.8	84.2	78.8	83.1	77.8	82.1	9.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.6	149.8	82.2	77.5	144.1	81.4	76.4	139.0	80.8	43.6	84.6	42.5	83.2	41.5	82.3	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	23.2	20.6	18.7	90.9	3.3	2.9	16.3	92.9	14.4	94.6	12.5	96.2	10.1	98.3
			15.1	80.1	2.9	1.9	13.0	81.4	11.4	82.5	9.7	83.5	7.6	84.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	37.3	40.3	47.2	56.2	64.6	70.4	76.8	79.4	73.0	64.3	52.8	41.7	(6)
(7)		DBStd	15.09	5.88	6.20	5.72	4.71	3.93	2.96	4.23	3.63	3.80	4.79	6.34	6.48	(7)
(8)		HDD50	1112	396	276	122	8	0	0	0	0	1	44	265		(8)
(9)		HDD65	3584	860	693	553	263	55	1	0	0	69	367	723		(9)
(10)		CDD50	4313	1	3	34	196	453	613	831	912	691	444	128	7	(10)
(11)		CDD65	1311	0	0	0	1	43	165	366	447	241	47	1	0	(11)
(12)		CDH74	7848	0	0	0	1	87	304	2472	3980	966	38	0	0	(12)
(13)		CDH80	1622	0	0	0	0	3	12	522	991	93	1	0	0	(13)
(14)	Wind	WSAvg	9.3	11.3	10.7	10.3	9.3	8.1	7.1	8.0	8.2	9.4	9.3	9.4	10.5	(14)
(15)	Precipitation	PrecAvg	56.0	0.9	1.7	3.0	5.3	5.6	8.0	10.4	9.7	6.1	2.3	1.9	0.9	(15)
(16)		PrecMax	96.5	4.1	5.2	8.8	11.9	17.0	32.8	24.1	26.1	20.0	7.9	8.7	3.8	(16)
(17)		PrecMin	34.0	0.0	0.0	0.4	0.5	0.0	1.1	2.4	0.8	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	12.8	0.8	1.2	1.8	2.4	3.0	5.7	5.5	5.9	5.0	1.9	1.7	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	58.5	63.8	71.1	79.7	81.6	90.6	90.7	85.2	77.5	69.2	58.9	(19)
(20)		MCWB	49.1	52.4	52.8	57.7	61.1	67.8	78.3	78.3	74.8	67.5	60.0	52.6		(20)
(21)		2%	DB	50.2	54.6	60.4	68.2	76.3	79.1	87.1	88.2	82.4	74.7	66.0	55.2	(21)
(22)		MCWB	43.0	47.4	51.6	56.0	60.9	67.9	78.0	77.6	73.2	64.8	58.7	48.3		(22)
(23)		5%	DB	47.7	51.7	58.0	65.7	73.8	77.3	85.0	86.5	80.7	73.0	63.7	52.8	(23)
(24)		MCWB	40.9	44.0	50.3	55.3	60.2	67.4	77.2	77.2	71.8	63.6	56.7	45.7		(24)
(25)		10%	DB	45.4	49.1	55.7	63.6	71.5	75.6	82.8	84.9	78.9	71.1	61.6	50.6	(25)
(26)		MCWB	38.8	41.9	48.3	54.7	60.1	67.5	76.5	76.7	71.0	62.2	54.5	43.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	55.6	58.2	64.3	68.7	74.1	80.9	81.4	77.8	72.5	63.7	54.0	(27)
(28)		MCDWB	53.3	57.2	60.2	65.8	72.0	76.1	85.8	85.3	81.7	74.3	66.3	56.8		(28)
(29)		2%	WB	44.7	49.5	54.9	61.6	66.5	72.9	79.6	80.1	76.2	68.6	60.8	49.7	(29)
(30)		MCDWB	48.7	53.0	58.1	64.4	70.0	74.9	83.9	84.4	80.0	72.9	64.3	54.0		(30)
(31)		5%	WB	42.2	45.5	52.2	59.1	64.8	71.6	78.6	79.2	74.9	66.1	58.2	47.1	(31)
(32)		MCDWB	46.5	50.0	56.3	63.1	69.1	73.9	82.7	83.8	78.9	70.8	62.7	52.0		(32)
(33)		10%	WB	39.8	42.9	49.6	57.1	63.4	70.1	77.7	78.2	73.3	63.8	55.7	44.6	(33)
(34)		MCDWB	44.6	47.9	54.4	61.1	68.1	73.3	81.6	82.8	77.2	69.3	60.8	49.8		(34)
(35)	Mean Daily Temperature Range		MDBR	10.7	11.8	11.9	11.5	10.9	8.2	7.2	7.8	8.8	10.4	10.7	10.8	(35)
(36)		5% DB	MCDBR	11.8	13.4	13.5	14.1	14.6	11.4	10.1	10.0	10.3	11.4	11.6	12.0	(36)
(37)			MCWBR	8.5	9.4	9.5	7.9	7.5	5.4	4.1	4.0	5.2	6.3	8.0	9.2	(37)
(38)			MCDBR	10.7	11.8	11.8	10.6	10.3	6.8	8.9	8.3	8.3	9.2	10.0	10.9	(38)
(39)		5% WB	MCWBR	9.4	10.4	10.6	8.3	7.0	4.6	4.0	3.9	5.0	7.3	8.7	10.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.418	0.463	0.534	0.556	0.572	0.618	0.587	0.544	0.492	0.455	0.430	0.413	(40)	
(41)		taud	2.051	1.974	1.819	1.821	1.833	1.802	1.937	2.050	2.142	2.121	2.099	2.082	(41)	
(42)		Ebn at Noon	238	241	234	238	236	224	230	238	245	241	232	230	(42)	
(43)		Edh at Noon	42	50	64	67	67	69	60	52	46	43	39	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	848	1069	1392	1591	1727	1508	1435	1480	1291	1182	882	771	(44)	
(45)		RadStd	64	95	116	128	193	143	212	188	137	107	89	42	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page