

JEONGEUP, Korea, Republic of

WMO: 471710

Lat: 35.5631N

Lon: 126.8392E

Elev: 151

StdP: 14.62

Time Zone: 9.00 (E09)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 15.3	(c) 18.7	(d) 3.0	(e) 6.5	(f) 22.3	(g) 6.5	(h) 7.7	(i) 24.6	(j) 12.5	(k) 33.5	(l) 11.2	(m) 33.6	(n) 2.1	(o) 110	(p) 0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.3	(c) 92.4	(d) 78.1	(e) 90.3	(f) 77.3	(g) 87.9	(h) 76.1	(i) 80.8	(j) 88.0	(k) 79.4	(l) 86.2	(m) 78.2	(n) 84.6	(o) 5.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.3	85.0	77.6	144.4	83.2	76.4	138.3	82.1	44.7	88.1	43.2	86.0	41.8	84.9	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	9.8	8.4	DB	12.3	96.0	3.9	2.2	9.5	97.6	7.2	98.9	5.1	100.2	2.3	101.8
			WB	11.0	81.6	3.7	1.9	8.3	82.9	6.2	84.1	4.1	85.1	1.5	86.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	30.9	35.8	44.4	54.7	65.8	73.5	79.9	80.5	71.8	60.5	48.6	35.4
	DBStd	18.08	6.92	7.30	6.93	6.29	4.93	3.37	3.99	4.59	4.61	5.56	7.71	7.17
	HDD50	1804	593	402	204	28	0	0	0	0	0	4	119	454
	HDD65	4448	1058	819	638	310	50	0	0	0	0	157	495	917
	CDD50	4336	0	4	31	170	488	706	928	947	655	329	76	2
	CDD65	1505	0	0	0	2	74	256	463	482	209	17	2	0
	CDH74	12900	0	0	4	38	606	1606	4443	4922	1209	67	5	0
	CDH80	4177	0	0	0	3	101	350	1551	1931	237	4	0	0
(14) Wind	WSAvg	3.3	2.8	3.3	3.7	4.0	3.7	3.3	3.4	3.2	2.9	2.7	3.0	3.1
(15) Precipitation	PrecAvg	50.5	1.7	1.7	2.2	3.5	3.5	5.9	10.7	9.8	5.4	2.2	2.4	1.7
	PrecMax	65.2	5.3	3.4	3.5	7.3	7.2	13.5	20.7	19.3	11.9	5.5	6.0	4.1
	PrecMin	30.2	0.4	0.2	0.3	0.7	0.2	0.4	2.6	3.5	0.8	0.0	0.9	0.6
	PrecStd	9.8	1.2	0.9	0.9	1.8	2.0	3.9	4.8	3.7	3.6	1.7	1.4	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	65.1	71.6	78.1	86.0	88.7	93.5	96.0	88.6	79.2	72.6	59.8
		MCWB	47.3	56.2	55.8	58.6	62.3	68.2	78.8	78.8	73.7	67.9	61.8	54.6
	2%	DB	48.9	56.8	65.3	74.1	82.8	86.0	91.6	93.5	85.1	75.7	67.0	53.4
		MCWB	43.4	51.6	52.9	57.0	62.6	68.9	78.0	78.3	71.3	63.0	59.0	47.8
	5%	DB	44.5	51.8	61.5	70.5	80.0	83.8	89.7	91.5	82.6	72.9	63.7	49.6
		MCWB	39.5	44.1	51.9	55.0	62.1	68.5	77.6	77.9	70.5	61.4	57.1	44.7
	10%	DB	41.1	47.2	57.5	67.1	77.5	81.7	87.5	89.1	80.4	70.2	60.6	46.4
		MCWB	36.6	41.1	48.6	54.5	61.8	68.0	76.8	77.5	69.4	61.0	54.5	41.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.4	58.5	59.6	64.7	73.4	75.9	82.5	82.7	77.0	72.2	63.9	56.8
		MCDB	52.0	62.0	64.9	69.3	78.1	80.4	89.7	91.0	85.2	78.0	68.5	59.3
	2%	WB	44.1	51.8	56.9	61.6	68.4	74.0	81.0	81.1	75.3	68.3	61.8	48.8
		MCDB	48.4	54.7	62.0	68.1	74.9	79.7	87.7	88.7	81.1	71.3	66.3	52.7
	5%	WB	40.0	45.6	53.1	58.9	66.1	72.7	79.5	79.8	73.8	65.5	58.2	45.8
		MCDB	43.4	50.5	60.2	65.8	73.7	79.1	85.8	87.2	79.2	68.7	62.1	49.3
	10%	WB	37.2	41.8	49.5	56.7	64.0	71.3	78.2	78.7	72.1	62.7	55.4	42.5
		MCDB	40.5	46.8	56.1	63.7	72.8	78.0	84.2	85.7	77.6	67.4	59.8	46.0
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	15.3	18.6	20.1	20.3	16.1	12.3	13.3	15.4	17.6	15.4	13.3
		MCDBR	17.5	21.7	24.3	26.3	24.5	19.8	15.2	16.7	17.5	20.3	17.8	16.8
		MCWBR	12.3	14.8	14.5	12.8	10.2	7.2	5.5	5.2	6.3	8.7	10.5	12.7
	5% WB	MCDBR	15.9	19.0	20.7	19.0	18.3	13.5	13.3	14.8	13.2	13.4	14.5	15.5
		MCWBR	12.3	14.8	14.6	12.1	10.2	6.6	6.0	5.8	6.8	9.0	10.4	13.2
(40) Clear-Sky Solar Irradiance	taub		0.448	0.487	0.561	0.581	0.597	0.665	0.616	0.565	0.497	0.475	0.461	0.448
	taud		1.928	1.871	1.726	1.730	1.743	1.674	1.835	1.963	2.082	2.005	1.975	1.940
	Ebn at Noon		223	231	226	231	229	213	223	232	242	233	217	212
	Edh at Noon		47	55	69	73	73	78	66	57	48	48	44	43
(44) All-Sky Solar Radiation	RadAvg		758	1018	1381	1597	1758	1588	1414	1446	1315	1162	808	664
(45)	RadStd		58	90	127	127	181	142	192	207	131	97	90	51

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+113	N/A

Nomenclature: See separate page