

JEONGEUP, Korea, Republic of

WMO: 471710

Lat: 35.5631N

Lon: 126.8392E

Elev: 46

StdP: 100.77

Time Zone: 9.00 (E09)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.3	-7.4	-16.1	0.9	-5.4	-14.1	1.1	-4.1	5.6	0.8	5.0	0.9	1.0	110	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	33.5	25.6	32.4	25.1	31.1	24.5	27.1	31.1	26.3	30.1	25.6	29.2	2.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	29.4	25.3	20.6	28.5	24.6	19.8	27.8	86.1	31.2	82.6	30.0	79.4	29.4	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.4	3.8	-11.0	35.6	2.1	1.2	-12.5	36.5	-13.8	37.2	-15.0	37.9	-16.5	38.8		
(5)			-11.7	27.5	2.0	1.1	-13.1	28.3	-14.3	28.9	-15.5	29.5	-17.0	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	-0.6	2.1	6.9	12.6	18.8	23.1	26.6	27.0	22.1	15.8	9.2	1.9	(6)
(7)		DBStd	10.04	3.85	4.05	3.85	3.49	2.74	1.87	2.22	2.55	2.56	3.09	4.28	3.98	(7)
(8)		HDD10.0	1002	329	223	113	16	0	0	0	0	2	66	252		(8)
(9)		HDD18.3	2471	588	455	354	172	28	0	0	2	87	275	509		(9)
(10)		CDD10.0	2409	0	2	17	94	271	392	516	526	364	183	42	1	(10)
(11)		CDD18.3	836	0	0	0	1	41	142	257	268	116	9	1	0	(11)
(12)		CDH23.3	7167	0	0	2	21	337	892	2468	2734	672	37	3	0	(12)
(13)		CDH26.7	2321	0	0	0	2	56	194	862	1073	132	2	0	0	(13)
(14)	Wind	WSAvg	1.5	1.2	1.5	1.7	1.8	1.7	1.5	1.5	1.4	1.3	1.2	1.3	1.4	(14)
(15)	Precipitation	PrecAvg	1282	42	42	55	89	88	151	272	248	136	56	60	42	(15)
(16)		PrecMax	1656	134	86	89	185	182	342	525	489	301	139	153	103	(16)
(17)		PrecMin	768	10	4	8	19	5	9	66	90	20	0	22	14	(17)
(18)		PrecStd	250	30	24	23	45	50	99	121	94	91	43	36	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	18.4	22.0	25.6	30.0	31.5	34.2	35.6	31.5	26.2	22.5	15.5	(19)
MCWB			8.5	13.4	13.2	14.8	16.8	20.1	26.0	26.0	23.2	20.0	16.6	12.6	(20)	
2%		DB	9.4	13.8	18.5	23.4	28.2	30.0	33.1	34.2	29.5	24.3	19.5	11.9	(21)	
		MCWB	6.3	10.9	11.6	13.9	17.0	20.5	25.5	25.7	21.8	17.2	15.0	8.8	(22)	
5%		DB	7.0	11.0	16.4	21.4	26.7	28.8	32.0	33.1	28.1	22.7	17.6	9.8	(23)	
		MCWB	4.2	6.7	11.1	12.8	16.7	20.3	25.3	25.5	21.4	16.3	13.9	7.1	(24)	
10%		DB	5.0	8.5	14.2	19.5	25.3	27.6	30.8	31.7	26.9	21.2	15.9	8.0	(25)	
		MCWB	2.5	5.1	9.2	12.5	16.5	20.0	24.9	25.3	20.8	16.1	12.5	5.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	14.7	15.3	18.2	23.0	24.4	28.1	28.2	25.0	22.3	17.7	13.8	(27)
MCDWB			11.1	16.7	18.3	20.7	25.6	26.9	32.1	32.8	29.5	25.6	20.3	15.2	(28)	
2%		WB	6.7	11.0	13.9	16.4	20.2	23.3	27.2	27.3	24.0	20.2	16.6	9.3	(29)	
		MCDWB	9.1	12.6	16.7	20.0	23.9	26.5	31.0	31.5	27.3	21.8	19.1	11.5	(30)	
5%		WB	4.5	7.5	11.7	15.0	19.0	22.6	26.4	26.6	23.2	18.6	14.6	7.7	(31)	
		MCDWB	6.3	10.3	15.6	18.8	23.2	26.1	29.9	30.7	26.2	20.4	16.7	9.6	(32)	
10%		WB	2.9	5.5	9.7	13.7	17.8	21.8	25.7	25.9	22.3	17.1	13.0	5.8	(33)	
		MCDWB	4.7	8.2	13.4	17.6	22.7	25.6	29.0	29.8	25.3	19.6	15.5	7.8	(34)	
(35)	Mean Daily Temperature Range	MDBR		7.7	8.5	10.3	11.2	11.3	9.0	6.8	7.4	8.5	9.8	8.6	7.4	(35)
5% DB		MCDBR		9.7	12.1	13.5	14.6	13.6	11.0	8.4	9.3	9.7	11.3	9.9	9.3	(36)
		MCWBR		6.8	8.2	8.1	7.1	5.7	4.0	3.0	2.9	3.5	4.8	5.8	7.0	(37)
		MCDBR		8.8	10.6	11.5	10.6	10.1	7.5	7.4	8.2	7.3	7.5	8.1	8.6	(38)
(39)		5% WB	MCWBR		6.9	8.2	8.1	6.7	5.6	3.7	3.4	3.2	3.8	5.0	5.8	7.3
(40)	Clear-Sky Solar Irradiance	taub		0.448	0.487	0.561	0.581	0.597	0.665	0.616	0.565	0.497	0.475	0.461	0.448	(40)
taud		1.928	1.871	1.726	1.730	1.743	1.674	1.835	1.963	2.082	2.005	1.975	1.940	(41)		
Ebn at Noon		702	728	711	727	722	673	704	732	763	733	685	669	(42)		
Edh at Noon		147	174	219	229	229	245	208	179	152	150	139	137	(43)		
(44)	All-Sky Solar Radiation	RadAvg		2.39	3.21	4.35	5.04	5.54	5.01	4.46	4.56	4.15	3.66	2.55	2.09	(44)
(45)		RadStd		0.18	0.28	0.40	0.40	0.57	0.45	0.60	0.65	0.41	0.30	0.28	0.16	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+63	N/A	(47)

Nomenclature: See separate page