

JINDO, Korea, Republic of

WMO: 471750

Lat: 34.4722N

Lon: 126.3240E

Elev: 1568

StdP: 13.88

Time Zone: 9.00 (E09)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.2	20.5	3.2	6.9	33.3	9.1	9.3	33.2	27.2	31.4	24.8	27.3	11.8	340	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	85.3	77.5	82.5	75.9	79.9	74.2	78.3	83.1	77.1	81.0	75.9	78.8	7.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	148.9	80.9	75.9	143.7	79.3	75.0	139.1	77.8	43.2	83.4	41.9	81.2	40.7	79.0	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.4	23.1	20.8	DB	14.6	89.1	3.2	2.5	12.3	90.9	10.5	92.4	8.7	93.8	6.4	95.6	
			WB	13.6	80.9	2.8	1.0	11.6	81.6	10.0	82.2	8.4	82.8	6.4	83.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.1	31.3	34.1	41.9	52.1	61.1	67.2	73.1	75.3	68.6	59.4	48.0	35.5
	DBStd	16.16	6.40	7.55	7.49	6.31	4.88	3.48	4.13	4.20	4.12	5.29	7.12	7.09
	HDD50	1920	581	448	267	50	0	0	0	0	0	5	119	450
	HDD65	4796	1046	867	715	387	141	18	1	0	14	182	511	914
	CDD50	3406	0	1	17	113	343	515	718	784	557	297	59	2
	CDD65	805	0	0	0	0	19	83	254	319	121	9	0	0
	CDH74	3012	0	0	0	1	49	150	933	1605	262	12	0	0
	CDH80	539	0	0	0	0	1	6	164	352	16	0	0	0
Wind	WSAvg	11.2	11.5	12.4	12.3	12.4	12.1	10.0	10.7	10.4	10.0	10.2	11.2	11.7
Precipitation	PrecAvg	59.5	1.1	2.2	3.5	5.9	6.1	6.5	10.6	10.6	6.4	2.4	2.6	1.7
	PrecMax	81.1	2.1	4.9	6.0	11.5	11.3	15.3	22.0	21.0	21.1	6.8	7.0	3.3
	PrecMin	44.2	0.4	0.8	1.3	1.4	1.9	1.6	4.2	1.1	1.3	0.1	0.2	0.7
	PrecStd	10.1	0.5	1.0	1.5	3.0	2.5	3.4	4.4	5.6	5.4	1.6	1.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	56.5	64.8	72.1	78.2	80.7	87.2	89.4	82.0	75.7	68.3	57.1
		MCWB	46.4	50.4	50.7	55.9	61.8	68.8	78.8	78.9	73.1	64.9	59.9	51.1
	2%	DB	46.7	53.3	59.6	68.3	75.0	77.7	84.1	86.5	79.2	72.4	63.6	52.2
		MCWB	41.5	47.1	49.2	53.8	60.7	67.1	77.1	77.8	71.6	63.2	57.7	47.2
	5%	DB	43.3	49.2	56.1	64.9	72.3	75.5	81.5	84.0	77.0	69.7	60.7	48.9
		MCWB	39.1	44.0	48.2	52.2	59.5	66.5	76.0	76.9	70.0	61.3	56.3	44.7
	10%	DB	40.3	45.2	53.0	61.6	69.4	73.3	78.7	81.4	74.9	67.0	57.8	45.8
		MCWB	36.1	40.1	46.8	51.4	58.4	66.0	74.7	75.9	69.8	59.9	53.4	42.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	54.5	56.0	62.0	68.1	73.2	79.9	80.3	76.8	70.2	62.7	53.8
		MCDB	49.7	55.3	58.8	66.9	69.9	75.9	85.2	86.8	79.6	73.0	65.0	55.9
	2%	WB	43.1	49.7	52.8	58.9	64.8	71.5	78.1	78.7	74.5	66.2	60.2	48.4
		MCDB	45.7	50.8	55.7	62.4	69.0	73.2	82.5	84.2	76.2	69.0	62.3	51.7
	5%	WB	39.4	44.3	50.4	56.8	62.9	70.2	76.7	77.6	72.8	63.5	57.2	45.6
		MCDB	42.3	47.8	54.7	60.0	67.9	72.6	80.3	82.1	75.0	67.1	59.9	48.3
	10%	WB	36.7	40.7	47.6	54.5	61.3	68.6	75.5	76.5	70.9	61.3	54.3	42.3
		MCDB	39.8	44.3	52.2	58.6	66.1	71.5	77.9	80.0	73.8	65.4	57.1	45.1
Mean Daily Temperature Range	5% DB	MDBR	9.6	11.9	14.6	14.9	13.9	11.0	8.0	9.5	10.9	12.8	11.4	10.0
		MCDBR	13.2	16.0	17.3	18.0	17.3	15.1	12.4	13.7	13.3	15.2	13.8	13.6
		MCWBR	10.5	12.4	12.1	11.4	11.4	9.8	7.9	7.2	8.0	9.2	9.7	11.1
	5% WB	MCDBR	12.1	14.1	15.2	13.6	13.6	10.5	10.4	11.4	10.3	12.4	12.1	13.0
		MCWBR	10.6	13.2	12.9	11.3	10.6	7.9	6.9	6.5	7.5	8.9	9.9	11.9
Clear-Sky Solar Irradiance	taub	0.412	0.449	0.502	0.514	0.527	0.574	0.549	0.505	0.458	0.431	0.422	0.410	
	taud	2.043	1.978	1.860	1.889	1.911	1.880	2.014	2.147	2.211	2.148	2.093	2.053	
	Ebn at Noon	240	246	244	249	247	235	240	248	255	250	235	231	
	Edh at Noon	42	50	61	62	62	63	55	48	43	42	40	39	
All-Sky Solar Radiation	RadAvg	751	1001	1378	1604	1731	1519	1483	1550	1349	1188	837	669	
	RadStd	62	93	120	129	193	149	201	202	130	111	86	43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page