

JINDO, Korea, Republic of

WMO: 471750

Lat: 34.4722N

Lon: 126.3240E

Elev: 478

StdP: 95.71

Time Zone: 9.00 (E09)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-6.4	-16.0	1.0	0.7	-12.7	1.3	0.7	12.2	-0.3	11.1	-2.6	5.3	340	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	29.6	25.3	28.0	24.4	26.6	23.4	25.7	28.4	25.0	27.2	24.4	26.0	3.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	21.3	27.2	24.4	20.5	26.3	23.9	19.9	25.5	82.6	28.5	79.5	27.3	76.8	26.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	10.3	9.3	-9.7	31.7	1.8	1.4	-10.9	32.7	-12.0	33.5	-13.0	34.3	-14.2	35.3
			-10.2	27.2	1.5	0.6	-11.3	27.6	-12.2	27.9	-13.1	28.2	-14.2	28.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-0.4	1.1	5.5	11.2	16.2	19.5	22.9	24.0	20.3	15.2	8.9	2.0
	DBStd	8.98	3.56	4.19	4.16	3.51	2.71	1.93	2.29	2.33	2.29	2.94	3.96	3.94
	HDD10.0	1067	323	249	148	28	0	0	0	0	0	3	66	250
	HDD18.3	2664	581	482	397	215	78	10	1	0	8	101	284	508
	CDD10.0	1892	0	1	9	63	191	286	399	436	309	165	33	1
	CDD18.3	447	0	0	0	0	11	46	141	177	67	5	0	0
	CDH23.3	1673	0	0	0	1	27	83	518	892	146	7	0	0
	CDH26.7	299	0	0	0	0	1	3	91	196	9	0	0	0
Wind	WSAvg	5.0	5.2	5.5	5.5	5.6	5.4	4.5	4.8	4.6	4.5	4.6	5.0	5.2
Precipitation	PrecAvg	1511	28	55	89	150	154	164	269	269	162	61	66	42
	PrecMax	2060	54	125	153	292	287	389	558	534	536	173	179	85
	PrecMin	1123	9	21	32	36	48	41	106	27	32	3	4	18
	PrecStd	257	13	26	39	75	64	87	113	143	136	41	44	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	13.6	18.2	22.3	25.7	27.1	30.7	31.9	27.8	24.3	20.1	14.0
		MCWB	8.0	10.2	10.4	13.3	16.5	20.5	26.0	26.0	22.8	18.3	15.5	10.6
	2%	DB	8.2	11.8	15.3	20.2	23.9	25.4	29.0	30.3	26.2	22.5	17.5	11.2
		MCWB	5.3	8.4	9.5	12.1	16.0	19.5	25.0	25.5	22.0	17.3	14.3	8.4
	5%	DB	6.3	9.6	13.4	18.3	22.4	24.2	27.5	28.9	25.0	20.9	16.0	9.4
		MCWB	4.0	6.6	9.0	11.2	15.3	19.2	24.5	25.0	21.1	16.3	13.5	7.0
	10%	DB	4.6	7.3	11.7	16.4	20.8	23.0	26.0	27.4	23.8	19.5	14.3	7.7
		MCWB	2.3	4.5	8.2	10.8	14.7	18.9	23.7	24.4	21.0	15.5	11.9	5.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	12.5	13.3	16.7	20.0	22.9	26.6	26.8	24.9	21.2	17.0	12.1
		MCDB	9.9	12.9	14.9	19.4	21.1	24.4	29.6	30.5	26.4	22.8	18.3	13.3
	2%	WB	6.1	9.8	11.6	14.9	18.2	21.9	25.6	26.0	23.6	19.0	15.6	9.1
		MCDB	7.6	10.5	13.2	16.9	20.5	22.9	28.1	29.0	24.6	20.6	16.8	10.9
	5%	WB	4.1	6.8	10.2	13.8	17.2	21.2	24.8	25.3	22.7	17.5	14.0	7.6
		MCDB	5.7	8.8	12.6	15.6	19.9	22.6	26.8	27.8	23.9	19.5	15.5	9.0
	10%	WB	2.6	4.8	8.7	12.5	16.3	20.4	24.2	24.7	21.6	16.3	12.4	5.7
		MCDB	4.3	6.8	11.2	14.8	18.9	21.9	25.5	26.7	23.2	18.6	13.9	7.3
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.6	8.1	8.3	7.7	6.1	4.5	5.3	6.1	7.1	6.3	5.6
		MCDBR	7.3	8.9	9.6	10.0	9.6	8.4	6.9	7.6	7.4	8.4	7.6	7.6
		MCWBR	5.9	6.9	6.7	6.4	6.3	5.4	4.4	4.0	4.4	5.1	5.4	6.2
	5% WB	MCDBR	6.7	7.8	8.4	7.6	7.6	5.8	5.8	6.3	5.7	6.9	6.7	7.2
MCWBR		5.9	7.3	7.1	6.3	5.9	4.4	3.8	3.6	4.1	4.9	5.5	6.6	
Clear-Sky Solar Irradiance	taub	0.412	0.449	0.502	0.514	0.527	0.574	0.549	0.505	0.458	0.431	0.422	0.410	
	taud	2.043	1.978	1.860	1.889	1.911	1.880	2.014	2.147	2.211	2.148	2.093	2.053	
	Ebn at Noon	757	775	768	784	778	740	756	783	803	787	742	729	
	Edh at Noon	133	158	193	196	194	200	174	150	134	131	125	124	
All-Sky Solar Radiation	RadAvg	2.37	3.16	4.34	5.06	5.46	4.79	4.67	4.89	4.25	3.75	2.64	2.11	
	RadStd	0.20	0.29	0.38	0.41	0.61	0.47	0.63	0.64	0.41	0.35	0.27	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page