

JEJU INTL, Korea, Republic of

WMO: 471820

Lat: 33.511N

Lon: 126.493E

Elev: 118

StdP: 14.63

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.8	33.7	17.2	13.2	38.3	19.3	14.6	38.5	30.0	38.4	27.4	38.0	14.8	350	0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	89.7	78.6	87.7	79.0	86.0	78.3	82.3	85.7	80.6	84.4	79.2	83.4	13.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.8	84.7	79.8	155.2	83.6	78.5	148.5	82.5	46.5	86.0	44.5	83.9	43.0	83.0	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.3	24.1	21.5	28.5	94.0	3.1	2.0	26.3	95.4	24.5	96.5	22.7	97.7	20.5	99.1		
			25.6	82.6	2.5	2.7	23.8	84.5	22.4	86.1	21.0	87.6	19.2	89.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	42.0	43.3	48.4	56.1	63.6	70.2	78.8	80.6	73.4	65.1	55.5	46.3
	DBStd	13.97	5.18	5.73	5.61	5.23	4.26	3.82	4.63	3.71	3.73	4.47	5.69	5.44
	HDD50	715	253	201	97	8	0	0	0	0	0	0	14	142
	HDD65	3110	712	608	515	272	78	3	0	0	53	289	580	
	CDD50	4498	6	12	48	190	421	607	893	947	702	468	178	26
	CDD65	1419	0	0	0	4	34	160	428	482	252	56	3	0
	CDH74	10607	0	0	1	17	100	495	3892	4906	1120	74	2	0
	CDH80	3033	0	0	0	1	12	69	1227	1582	137	5	0	0
Wind	WSAvg	9.3	10.6	9.9	9.7	9.1	8.3	8.5	8.8	8.6	9.2	8.9	9.2	10.5
Precipitation	PrecAvg	57.7	2.6	2.5	3.1	3.7	3.7	6.9	8.4	10.2	8.2	3.3	3.0	2.1
	PrecMax	99.4	6.7	6.5	9.0	8.3	11.2	27.3	27.8	26.1	37.0	16.6	9.1	5.2
	PrecMin	30.4	0.5	0.3	0.8	0.6	0.5	0.5	0.6	2.1	0.3	0.2	0.1	0.4
	PrecStd	15.3	1.5	1.4	1.9	1.8	2.0	4.4	5.9	6.0	7.3	3.3	1.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.1	66.4	69.5	76.8	81.0	85.7	93.2	93.0	86.4	79.1	73.2	64.6
		MCWB	56.0	59.3	58.9	61.4	66.1	75.5	78.0	79.3	77.5	71.6	64.3	58.3
	2%	DB	55.8	60.6	64.6	71.4	76.7	82.1	89.8	89.9	82.8	75.5	69.8	60.6
		MCWB	50.2	55.6	56.6	62.3	66.0	74.9	78.2	79.1	76.2	69.2	63.7	55.1
	5%	DB	53.2	55.4	61.0	67.9	73.7	78.9	87.7	88.0	80.9	73.6	66.6	57.3
		MCWB	48.1	50.0	54.5	60.0	64.0	72.4	78.7	79.4	75.0	67.4	61.1	52.1
	10%	DB	50.1	52.0	57.5	64.8	71.6	76.8	85.9	86.3	79.1	71.8	64.4	55.1
		MCWB	45.7	46.8	51.8	58.1	63.1	71.0	78.1	78.9	73.4	65.4	59.2	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	60.2	61.9	67.5	73.5	79.1	84.1	84.6	80.8	74.4	67.6	60.3
		MCDB	60.2	65.0	66.1	71.3	77.8	81.3	88.0	88.4	83.3	77.7	71.0	63.8
	2%	WB	51.7	55.9	58.4	64.8	69.9	76.4	82.1	82.9	78.4	71.3	64.8	55.7
		MCDB	54.9	59.7	63.4	69.6	73.6	80.1	85.5	86.5	81.4	74.0	68.3	59.4
	5%	WB	48.8	51.2	55.5	61.8	66.9	74.5	80.5	81.2	76.5	69.1	62.2	52.8
		MCDB	52.2	54.4	60.3	65.7	71.1	78.2	84.2	85.1	80.0	72.2	66.1	56.8
	10%	WB	46.0	47.9	52.7	59.6	64.6	72.3	79.0	79.7	74.7	66.8	59.8	50.3
		MCDB	49.6	51.7	56.9	63.6	69.3	75.6	83.2	84.1	78.2	71.0	63.8	54.6
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.9	11.7	12.7	12.7	10.1	9.6	9.1	8.6	9.6	9.9	8.9
		MCDBR	13.6	16.1	18.0	17.4	16.4	13.0	12.2	11.3	10.7	11.4	13.3	13.3
		MCWBR	12.4	13.9	14.9	13.0	11.5	8.9	6.4	6.3	7.5	9.3	11.5	12.3
	5% WB	MCDBR	12.3	15.2	16.5	14.8	14.9	11.3	11.0	10.3	9.9	10.2	11.8	12.6
		MCWBR	12.3	14.2	14.6	12.2	12.1	9.1	7.6	7.1	7.7	9.4	11.4	12.4
Clear-Sky Solar Irradiance	taub	0.461	0.501	0.553	0.562	0.571	0.603	0.583	0.539	0.496	0.467	0.460	0.454	
	taud	1.958	1.893	1.786	1.818	1.852	1.865	1.965	2.098	2.153	2.097	2.037	1.980	
	Ebn at Noon	226	231	231	237	237	228	232	240	245	240	225	218	
	Edh at Noon	47	55	66	67	66	64	58	50	45	44	43	43	
All-Sky Solar Radiation	RadAvg	661	924	1304	1554	1661	1458	1557	1596	1330	1171	817	611	
	RadStd	74	108	103	127	179	175	217	161	127	117	89	54	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	-3.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	N/A

Nomenclature: See separate page