

JEJU, Korea, Republic of

WMO: 471840

Lat: 33.5142N

Lon: 126.5297E

Elev: 71

StdP: 14.66

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.6	34.3	18.3	13.8	40.7	20.3	15.3	40.0	25.8	38.6	23.3	38.1	13.1	340	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	89.9	77.9	88.1	77.8	86.4	77.5	80.8	86.5	79.7	85.5	78.6	84.6	10.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.4	85.0	77.9	145.5	84.2	76.8	139.8	83.3	44.5	86.8	43.4	85.4	42.3	84.7	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.1	18.5	16.1	30.2	93.9	2.6	1.9	28.3	95.3	26.8	96.3	25.3	97.4	23.4	98.7	
			DB												
			WB	27.0	81.1	2.0	1.9	25.6	82.4	24.4	83.5	23.3	84.6	21.8	85.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	42.8	44.2	49.7	57.6	65.1	71.3	79.6	81.3	74.2	65.8	56.0	46.9
	DBStd	13.93	5.19	5.73	5.54	5.12	4.14	3.81	4.61	3.71	3.76	4.40	5.66	5.34
	HDD50	626	233	178	74	4	0	0	0	0	0	0	11	126
	HDD65	2902	690	582	475	227	50	1	0	0	43	273	561	
	CDD50	4750	8	15	64	233	468	639	917	970	725	489	192	30
	CDD65	1552	0	0	0	6	53	190	452	505	275	67	4	0
	CDH74	11938	0	0	1	19	128	628	4361	5370	1339	90	2	0
	CDH80	3515	0	0	0	2	11	92	1425	1811	167	7	0	0
Wind	WSAvg	7.3	9.3	8.4	8.0	7.3	6.4	6.1	6.3	6.4	6.3	6.8	7.6	9.1
Precipitation	PrecAvg	57.7	2.6	2.5	3.1	3.7	3.7	6.9	8.4	10.2	8.2	3.3	3.0	2.1
	PrecMax	99.4	6.7	6.5	9.0	8.3	11.2	27.3	27.8	26.1	37.0	16.6	9.1	5.2
	PrecMin	30.4	0.5	0.3	0.8	0.6	0.5	0.5	0.6	2.1	0.3	0.2	0.1	0.4
	PrecStd	15.3	1.5	1.4	1.9	1.8	2.0	4.4	5.9	6.0	7.3	3.3	1.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.4	66.7	68.5	76.5	81.0	86.1	92.5	92.7	87.3	79.9	72.6	64.7
		MCWB	55.4	58.5	58.4	62.7	65.7	74.2	77.9	78.3	77.0	71.8	64.2	58.5
	2%	DB	56.5	60.6	65.3	71.4	77.3	82.6	89.9	90.3	83.8	76.4	69.7	60.3
		MCWB	50.7	55.3	57.0	61.5	64.5	73.2	77.5	78.4	75.7	68.5	62.9	54.4
	5%	DB	53.0	55.8	61.8	68.4	74.7	79.6	88.0	88.6	81.7	74.1	67.1	57.5
		MCWB	47.7	49.9	54.3	59.9	63.7	71.0	77.4	78.4	74.3	66.6	60.9	52.0
	10%	DB	50.6	52.7	58.7	66.0	72.4	77.4	86.3	87.0	79.9	72.4	64.6	55.1
		MCWB	45.6	47.1	52.1	58.0	62.3	70.0	77.2	78.1	73.0	65.0	58.9	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.2	60.1	61.9	67.4	72.3	76.9	81.7	82.5	79.1	74.4	66.9	61.4
		MCDB	60.3	64.9	66.0	71.4	77.8	82.0	88.2	88.2	84.1	78.0	70.6	64.1
	2%	WB	51.6	55.9	58.4	64.5	69.1	75.1	80.3	81.2	77.2	71.3	64.3	55.6
		MCDB	55.2	60.3	63.3	68.9	73.5	81.0	86.3	86.9	82.1	74.5	68.1	58.9
	5%	WB	48.7	51.1	55.7	61.7	66.6	73.6	79.2	80.3	75.6	68.4	62.1	52.8
		MCDB	52.5	54.7	60.4	66.2	71.6	78.3	85.3	86.0	80.2	72.7	66.3	56.9
	10%	WB	46.0	47.9	52.9	59.5	64.7	71.9	78.3	79.3	74.3	66.2	59.6	50.1
		MCDB	50.2	51.8	57.5	64.3	69.9	76.0	84.4	85.2	78.8	71.1	64.2	55.1
Mean Daily Temperature Range	5% DB	MDBR	7.4	9.0	10.5	11.1	10.7	8.5	8.3	7.9	7.9	9.1	9.3	8.0
		MCDBR	12.2	14.5	16.0	14.9	14.0	11.6	10.4	10.1	9.8	10.7	12.3	12.3
		MCWBR	10.8	12.3	13.1	11.1	9.3	6.9	4.9	5.1	6.5	8.3	10.3	11.0
	5% WB	MCDBR	10.7	13.3	14.5	12.4	11.8	9.5	9.0	8.4	9.3	10.3	11.2	11.2
		MCWBR	10.9	12.6	12.9	10.6	9.1	6.4	5.4	5.3	6.1	8.5	10.2	11.2
Clear-Sky Solar Irradiance	taub	0.462	0.502	0.554	0.564	0.572	0.604	0.584	0.540	0.497	0.468	0.461	0.455	
	taud	1.957	1.892	1.784	1.815	1.849	1.862	1.963	2.095	2.149	2.095	2.036	1.980	
	Ebn at Noon	225	231	231	236	236	228	232	240	245	239	225	218	
	Edh at Noon	47	56	67	67	66	65	58	50	46	44	43	43	
All-Sky Solar Radiation	RadAvg	663	925	1305	1554	1662	1458	1558	1596	1329	1171	819	613	
	RadStd	74	108	103	127	180	175	217	162	127	117	89	54	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page