

JEJU, Korea, Republic of

WMO: 471840

Lat: 33.5142N

Lon: 126.5297E

Elev: 22

StdP: 101.07

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.3	1.3	-7.6	2.0	4.8	-6.5	2.2	4.4	11.5	3.6	10.4	3.4	5.9	340	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	32.2	25.5	31.1	25.5	30.2	25.3	27.1	30.3	26.5	29.7	25.9	29.2	4.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	29.4	25.5	20.8	29.0	24.9	20.0	28.5	85.7	30.4	83.0	29.7	80.4	29.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.2	7.2	-1.0	34.4	1.4	1.0	-2.1	35.1	-2.9	35.7	-3.7	36.3	-4.8	37.1		
			-2.8	27.3	1.1	1.0	-3.6	28.0	-4.2	28.6	-4.9	29.2	-5.7	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	6.0	6.8	9.8	14.2	18.4	21.8	26.4	27.4	23.4	18.8	13.4	8.3
	DBStd	7.74	2.88	3.18	3.08	2.84	2.30	2.12	2.56	2.06	2.09	2.45	3.15	2.97
	HDD10.0	348	129	99	41	2	0	0	0	0	0	6	70	
	HDD18.3	1612	383	323	264	126	28	1	0	0	24	152	312	
	CDD10.0	2639	4	8	36	129	260	355	509	539	403	272	107	17
	CDD18.3	862	0	0	0	3	29	106	251	281	153	37	2	0
	CDH23.3	6632	0	0	1	11	71	349	2423	2983	744	50	1	0
	CDH26.7	1953	0	0	0	1	6	51	792	1006	93	4	0	0
Wind	WSAvg	3.3	4.2	3.8	3.6	3.2	2.9	2.7	2.8	2.8	2.8	3.0	3.4	4.1
Precipitation	PrecAvg	1466	65	64	79	95	94	176	214	258	209	83	76	54
	PrecMax	2526	170	164	228	211	284	694	706	663	940	421	231	131
	PrecMin	773	12	8	20	15	13	12	15	53	8	5	2	11
	PrecStd	388	37	36	47	46	52	111	149	153	185	83	49	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.4	19.3	20.3	24.7	27.2	30.1	33.6	33.7	30.7	26.6	22.6	18.2
		MCWB	13.0	14.7	14.7	17.1	18.7	23.4	25.5	25.7	25.0	22.1	17.9	14.7
	2%	DB	13.6	15.9	18.5	21.9	25.1	28.1	32.2	32.4	28.8	24.6	21.0	15.7
		MCWB	10.4	13.0	13.9	16.4	18.0	22.9	25.3	25.8	24.3	20.3	17.2	12.4
	5%	DB	11.7	13.2	16.5	20.2	23.7	26.4	31.1	31.4	27.6	23.4	19.5	14.2
		MCWB	8.7	9.9	12.4	15.5	17.6	21.7	25.2	25.8	23.5	19.2	16.1	11.1
	10%	DB	10.4	11.5	14.8	18.9	22.4	25.2	30.2	30.6	26.6	22.4	18.1	12.8
		MCWB	7.5	8.4	11.1	14.4	16.8	21.1	25.1	25.6	22.8	18.3	14.9	9.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	15.6	16.6	19.7	22.4	25.0	27.6	28.0	26.2	23.5	19.4	16.3
		MCDB	15.7	18.3	18.9	21.9	25.4	27.8	31.2	31.2	29.0	25.5	21.4	17.9
	2%	WB	10.9	13.3	14.7	18.1	20.6	24.0	26.9	27.3	25.1	21.8	18.0	13.1
		MCDB	12.9	15.7	17.4	20.5	23.1	27.2	30.2	30.5	27.9	23.6	20.1	15.0
	5%	WB	9.3	10.6	13.2	16.5	19.2	23.1	26.2	26.8	24.2	20.2	16.7	11.5
		MCDB	11.4	12.6	15.8	19.0	22.0	25.7	29.6	30.0	26.8	22.6	19.0	13.8
	10%	WB	7.8	8.8	11.6	15.3	18.2	22.2	25.7	26.3	23.5	19.0	15.3	10.0
		MCDB	10.1	11.0	14.2	18.0	21.1	24.4	29.1	29.5	26.0	21.7	17.9	12.8
Mean Daily Temperature Range	5% DB	MDBR	4.1	5.0	5.8	6.2	5.9	4.7	4.6	4.4	4.4	5.1	5.2	4.4
		MCDBR	6.8	8.0	8.9	8.3	7.8	6.5	5.8	5.6	5.5	5.9	6.8	6.8
		MCWBR	6.0	6.8	7.3	6.1	5.2	3.8	2.7	2.8	3.6	4.6	5.7	6.1
	5% WB	MCDBR	6.0	7.4	8.0	6.9	6.6	5.3	5.0	4.7	4.7	5.1	5.7	6.2
		MCWBR	6.0	7.0	7.2	5.9	5.1	3.5	3.0	2.9	3.4	4.7	5.6	6.2
Clear-Sky Solar Irradiance	taub	0.462	0.502	0.554	0.564	0.572	0.604	0.584	0.540	0.497	0.468	0.461	0.455	
	taud	1.957	1.892	1.784	1.815	1.849	1.862	1.963	2.095	2.149	2.095	2.036	1.980	
	Ebn at Noon	710	728	727	745	744	718	730	757	771	755	708	688	
	Edh at Noon	148	175	210	212	207	204	184	159	144	140	135	137	
All-Sky Solar Radiation	RadAvg	2.09	2.92	4.11	4.90	5.24	4.59	4.91	5.03	4.19	3.69	2.58	1.93	
	RadStd	0.23	0.34	0.33	0.40	0.57	0.55	0.69	0.51	0.40	0.37	0.28	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page