

SEOGWIPO, Korea, Republic of

WMO: 471890

Lat: 33.2461N

Lon: 126.5653E

Elev: 165

StdP: 14.61

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.7	35.0	16.9	13.0	42.8	19.5	14.7	41.3	17.4	46.5	15.7	46.8	6.2	290	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.3	88.6	79.9	87.1	79.6	85.5	79.0	82.2	85.5	81.0	84.9	80.1	84.2	7.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)															
81.4	164.3	84.1	80.0	156.6	83.6	78.9	150.9	83.2	46.3	85.5	45.0	85.1	43.9	84.5	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.7	14.3	12.3	DB	29.9	91.4	3.1	2.6	27.7	93.2	25.9	94.7	24.2	96.2	22.0	98.1
			WB	26.2	82.8	2.3	1.7	24.6	84.1	23.2	85.1	22.0	86.1	20.3	87.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	45.0	46.8	51.7	59.1	66.1	71.5	78.9	81.5	75.9	68.1	58.5	49.1
	DBStd	13.11	5.48	5.73	5.29	4.26	3.48	2.87	4.10	3.10	3.48	4.29	5.74	5.83
	HDD50	429	171	119	43	2	0	0	0	0	0	0	5	89
	HDD65	2473	619	510	414	182	28	0	0	0	0	20	206	494
	CDD50	5085	17	29	95	273	499	645	895	976	776	560	260	60
	CDD65	1653	0	0	0	3	62	195	430	511	326	115	11	0
	CDH74	11914	0	0	0	0	75	402	3766	5465	1982	220	4	0
	CDH80	2970	0	0	0	0	3	13	934	1731	284	5	0	0
Wind	WSAvg	5.8	5.6	5.7	6.1	6.0	5.4	5.4	5.6	6.1	6.5	6.0	5.5	5.4
Precipitation	PrecAvg	70.4	2.3	3.1	4.4	7.1	8.5	11.0	11.1	9.0	6.3	2.6	3.0	1.8
	PrecMax	127.7	5.6	10.0	8.6	11.9	17.6	35.3	28.9	24.8	24.1	11.8	8.9	6.5
	PrecMin	45.1	0.2	0.3	0.9	2.8	0.6	2.5	2.2	1.0	0.9	0.0	0.4	0.1
	PrecStd	15.9	1.6	2.3	2.1	2.2	4.1	6.3	6.2	5.4	4.8	2.5	2.1	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.6	63.3	66.4	72.4	79.1	81.9	90.8	90.9	87.6	80.3	73.9	65.8
		MCWB	58.5	59.0	57.3	60.9	61.9	69.3	79.3	80.1	77.6	69.7	66.1	60.5
	2%	DB	58.6	60.6	63.9	69.5	75.9	79.1	88.3	89.1	84.7	78.1	71.5	62.6
		MCWB	53.0	56.4	57.7	60.4	63.4	70.1	80.0	80.0	75.5	68.8	64.8	55.7
	5%	DB	55.7	58.0	62.2	67.6	73.9	77.5	86.4	87.7	83.0	76.5	69.3	60.0
		MCWB	49.5	52.3	56.2	59.4	63.5	70.9	79.7	79.9	74.9	67.7	62.5	53.1
	10%	DB	53.0	55.6	60.1	65.9	72.0	76.2	84.6	86.5	81.5	74.7	67.2	57.7
		MCWB	46.9	49.5	54.0	58.9	63.2	70.8	79.0	79.5	74.3	66.4	60.3	51.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	60.9	62.1	66.6	70.9	76.4	83.5	84.5	80.6	75.9	69.2	63.0
		MCDB	61.8	62.4	63.5	68.5	72.0	77.5	86.0	86.6	84.3	77.6	72.0	64.4
	2%	WB	54.0	57.6	60.0	64.6	68.8	75.0	81.8	82.8	79.0	73.1	66.6	57.6
		MCDB	57.3	59.7	62.5	66.8	71.2	76.5	85.1	85.9	82.3	76.1	70.2	60.7
	5%	WB	50.4	53.7	57.7	62.8	67.5	74.0	80.8	81.6	77.8	70.5	64.2	54.4
		MCDB	54.7	57.0	60.8	65.5	70.6	75.7	84.5	85.4	81.1	74.3	68.4	58.7
	10%	WB	47.7	50.7	55.3	60.8	66.1	72.7	79.9	80.7	76.3	68.2	61.4	52.0
		MCDB	52.3	54.7	59.7	64.1	70.0	74.9	83.5	85.0	79.9	73.1	66.1	57.3
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.1	10.6	10.3	9.5	7.4	6.5	7.3	8.6	10.3	10.5	9.9
		MCDBR	11.3	11.1	11.6	11.7	12.0	9.2	8.5	8.8	9.8	10.8	10.8	11.2
		MCWBR	9.6	10.0	10.3	9.7	9.1	6.9	5.4	5.6	6.9	7.9	8.9	9.2
	5% WB	MCDBR	10.6	10.0	10.2	8.0	8.0	5.7	7.1	7.4	7.4	8.2	9.3	9.9
		MCWBR	10.6	11.0	10.9	8.1	7.8	4.9	5.1	5.5	6.4	7.5	9.4	9.9
Clear-Sky Solar Irradiance	taub	0.462	0.501	0.551	0.561	0.567	0.595	0.577	0.534	0.494	0.466	0.459	0.454	
	taud	1.962	1.900	1.795	1.828	1.867	1.891	1.985	2.117	2.168	2.109	2.048	1.985	
	Ebn at Noon	226	232	232	238	238	230	233	242	246	241	226	219	
	Edh at Noon	47	55	66	67	64	63	57	49	45	44	43	43	
All-Sky Solar Radiation	RadAvg	642	907	1293	1543	1650	1440	1595	1633	1344	1177	812	598	
	RadStd	75	114	102	130	185	182	225	161	127	117	92	56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page