

OBIHIRO, Japan

WMO: 474170

Lat: 42.9222N

Lon: 143.2119E

Elev: 44

StdP: 100.80

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-15.9	-21.2	0.6	-16.8	-19.5	0.7	-14.4	9.2	-2.0	8.3	-2.1	1.4	210	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	30.5	22.1	28.5	21.2	26.5	20.2	23.7	28.5	22.6	26.5	21.6	24.9	3.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	17.0	25.9	21.3	16.0	24.8	20.4	15.1	23.6	71.3	28.7	67.1	26.3	63.2	25.0	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.2	6.1	DB	-21.2	33.9	2.1	1.7	-22.8	35.1	-24.0	36.1	-25.2	37.1	-26.7	38.4	(4)
(5)			WB	-21.5	25.4	2.1	1.2	-23.0	26.3	-24.2	26.9	-25.4	27.6	-26.9	28.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-7.3	-6.0	-0.4	6.4	12.1	15.9	19.7	20.9	17.5	10.6	3.6	-4.0	(6)	
	DBStd	10.34	3.56	3.74	3.57	3.54	3.64	3.33	3.30	3.25	3.22	3.19	3.61	3.52	(7)	
	HDD10.0	2106	537	447	323	119	20	1	0	0	0	32	193	433	(8)	
	HDD18.3	4163	796	681	581	358	197	87	24	12	54	241	442	692	(9)	
	CDD10.0	1187	0	0	0	11	84	178	299	339	224	49	1	0	(10)	
	CDD18.3	203	0	0	0	0	2	14	66	93	29	0	0	0	(11)	
	CDH23.3	1351	0	0	0	5	67	150	437	551	138	2	0	0	(12)	
	CDH26.7	402	0	0	0	1	17	36	139	184	25	0	0	0	(13)	
(14) Wind	WSAvg	2.1	2.3	2.5	2.6	2.7	2.2	1.8	1.6	1.5	1.7	2.1	2.4	2.4	(14)	
(15) Precipitation	PrecAvg	998	44	32	45	65	93	84	115	149	152	91	67	60	(15)	
	PrecMax	1351	107	85	127	264	203	244	264	393	353	179	171	150	(16)	
	PrecMin	561	8	6	8	10	30	34	31	63	63	17	8	16	(17)	
	PrecStd	169	31	24	30	52	49	54	59	71	69	48	43	34	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.2	5.7	13.0	23.3	28.7	30.2	32.8	33.7	29.4	22.2	16.2	7.5	(19)	
		MCWB	0.0	1.7	6.3	11.6	15.8	19.5	23.1	24.6	21.0	14.8	10.4	4.3	(20)	
	2%	DB	1.6	3.6	9.5	18.9	24.9	27.2	30.1	30.9	26.7	19.7	13.6	4.7	(21)	
		MCWB	-1.0	0.1	4.2	10.4	14.3	18.4	22.4	23.2	20.2	13.5	8.9	1.7	(22)	
	5%	DB	0.3	1.8	7.1	16.0	22.0	24.8	28.1	28.7	24.8	17.8	11.5	3.1	(23)	
		MCWB	-2.1	-1.1	2.7	8.5	13.3	17.8	21.6	22.2	18.8	12.8	7.7	0.4	(24)	
	10%	DB	-0.9	0.4	5.2	13.2	19.3	22.3	25.6	26.5	22.9	16.2	9.5	1.6	(25)	
		MCWB	-3.1	-2.0	1.4	7.3	12.2	16.6	20.7	21.3	18.2	11.9	6.3	-0.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.8	2.1	7.1	13.1	17.5	20.9	24.5	25.5	23.4	16.9	11.8	4.8	(27)	
		MCDB	2.2	5.1	12.1	19.8	26.4	27.1	29.8	31.2	26.6	19.2	13.9	6.8	(28)	
	2%	WB	-0.6	0.5	4.7	11.1	15.6	19.5	23.3	24.2	21.8	15.1	9.8	2.2	(29)	
		MCDB	1.1	2.9	8.6	17.8	22.2	25.5	28.3	29.6	24.5	18.0	12.4	4.1	(30)	
	5%	WB	-1.9	-0.7	3.2	9.4	14.3	18.2	22.2	23.1	20.5	13.9	8.2	0.7	(31)	
		MCDB	0.1	1.4	6.5	14.8	20.1	23.5	26.9	27.0	23.1	16.3	10.8	2.5	(32)	
	10%	WB	-3.0	-1.8	1.7	7.9	13.1	17.0	21.1	22.0	19.2	12.8	6.6	-0.5	(33)	
		MCDB	-1.0	0.3	4.6	12.3	18.2	21.2	24.8	25.1	21.7	15.1	9.2	1.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.9	9.3	10.6	11.0	9.8	8.5	8.0	8.7	9.8	8.7	9.3	(35)	
		MCDBR	10.1	10.9	11.7	15.9	16.7	14.7	13.0	11.7	11.2	11.7	11.9	9.3	(36)	
	5% WB	MCWBR	8.1	8.4	7.5	8.5	8.1	7.5	6.5	5.6	5.7	6.9	7.9	7.0	(37)	
		MCWBR	9.3	10.2	11.2	14.3	14.0	12.9	11.6	10.2	9.1	9.6	10.9	8.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.318	0.370	0.450	0.508	0.526	0.505	0.489	0.469	0.411	0.394	0.367	0.329	(40)	
		taud	2.083	1.917	1.804	1.814	1.868	2.008	2.122	2.194	2.313	2.230	2.207	2.136	(41)	
	Ebn at Noon	Ebn at Noon	783	791	771	762	763	781	790	793	815	772	725	730	(42)	
		Edh at Noon	105	148	189	203	197	172	152	137	113	108	94	92	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.89	2.75	3.85	4.65	4.95	4.90	4.47	4.10	3.57	2.81	1.87	1.53	(44)	
	RadStd	RadStd	0.12	0.19	0.28	0.37	0.42	0.43	0.45	0.31	0.30	0.17	0.13	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.31	N/A	N/A	+0.83	N/A	N/A	N/A	-95	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page