

TOMAKOMAI, Japan

WMO: 474240

Lat: 42.6233N

Lon: 141.5472E

Elev: 8

StdP: 101.23

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-10.6	-16.9	0.9	-9.8	-15.5	1.0	-8.3	11.1	2.6	10.0	1.8	2.0	350	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	25.8	21.7	24.5	21.0	23.4	20.6	22.8	24.5	22.0	23.5	21.3	22.8	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	16.9	24.0	21.5	16.1	23.2	20.7	15.4	22.4	67.6	24.6	64.8	23.6	62.0	22.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.1	6.9	DB	-14.9	28.8	2.1	1.4	-16.4	29.8	-17.6	30.6	-18.7	31.4	-20.2	32.5	(4)
(5)			WB	-15.4	23.8	2.0	1.1	-16.8	24.6	-18.0	25.2	-19.1	25.8	-20.6	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-3.9	-3.6	0.3	5.2	10.2	14.1	18.5	20.7	17.8	11.2	4.6	-1.4	(6)	
	DBStd	8.95	2.94	3.05	2.88	2.59	2.54	2.44	2.34	2.21	2.77	3.20	3.69	3.35	(7)	
	HDD10.0	1829	432	380	302	145	28	1	0	0	0	24	165	352	(8)	
	HDD18.3	3953	690	613	560	393	252	128	28	4	42	220	412	611	(9)	
	CDD10.0	1058	0	0	0	2	35	125	262	333	234	63	3	0	(10)	
	CDD18.3	139	0	0	0	0	0	2	31	79	27	0	0	0	(11)	
	CDH23.3	266	0	0	0	0	1	7	40	173	46	0	0	0	(12)	
	CDH26.7	20	0	0	0	0	0	1	2	17	1	0	0	0	(13)	
(14) Wind	WSAvg	3.1	3.1	3.1	3.3	3.2	3.0	2.7	2.6	2.9	3.2	3.3	3.2	3.0	(14)	
(15) Precipitation	PrecAvg	1233	53	49	53	78	122	101	160	177	175	102	90	71	(15)	
	PrecMax	1575	82	131	111	146	216	289	344	341	325	153	212	170	(16)	
	PrecMin	962	28	16	22	5	36	34	71	58	34	36	41	40	(17)	
	PrecStd	146	16	25	21	38	46	52	63	78	70	32	38	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.6	5.7	10.2	15.5	20.4	24.0	26.3	28.6	26.2	21.1	15.6	10.4	(19)	
		MCWB	3.4	3.3	5.5	8.8	12.4	17.2	21.2	23.0	21.4	16.1	12.5	8.8	(20)	
	2%	DB	3.7	4.0	7.5	12.5	17.6	20.4	24.4	26.6	24.6	19.3	14.3	8.3	(21)	
		MCWB	2.0	1.9	3.9	7.4	11.8	16.6	20.7	22.5	20.7	15.5	11.8	6.2	(22)	
	5%	DB	2.3	2.9	6.0	10.9	15.7	18.9	23.0	25.1	23.4	18.1	12.9	6.2	(23)	
		MCWB	0.5	1.0	3.2	6.7	11.4	16.1	20.3	21.8	19.9	14.8	10.5	4.0	(24)	
	10%	DB	1.2	1.9	4.9	9.5	14.1	17.6	21.8	24.0	22.4	17.0	11.5	4.2	(25)	
		MCWB	-0.8	0.1	2.6	6.2	10.9	15.3	19.6	21.2	19.4	13.8	9.1	1.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.0	6.2	10.3	14.3	18.6	22.4	24.2	23.3	18.0	13.7	9.2	(27)	
		MCDB	5.1	5.0	8.3	13.5	17.5	21.5	24.6	27.2	24.7	19.4	14.9	10.2	(28)	
	2%	WB	2.3	2.4	4.8	8.8	13.1	17.3	21.4	23.2	22.2	16.5	12.3	6.5	(29)	
		MCDB	3.5	3.5	6.6	11.2	15.7	19.5	23.3	25.4	23.4	18.3	13.8	8.1	(30)	
	5%	WB	0.8	1.4	3.9	7.7	12.2	16.4	20.7	22.5	21.1	15.5	10.9	4.1	(31)	
		MCDB	2.0	2.6	5.5	9.8	14.5	18.4	22.3	24.3	22.6	17.5	12.6	5.9	(32)	
	10%	WB	-0.5	0.3	2.9	6.8	11.4	15.6	20.0	21.9	20.1	14.4	9.3	2.1	(33)	
		MCDB	1.0	1.8	4.5	8.8	13.5	17.2	21.5	23.3	21.8	16.5	11.3	3.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	8.2	7.3	7.3	6.5	5.0	4.3	4.7	7.1	9.0	8.2	7.5	(35)	
		MCDBR	8.0	8.0	8.4	9.9	9.7	7.5	6.6	6.8	7.8	9.3	10.0	9.1	(36)	
	5% WB	MCWBR	7.0	6.7	6.2	6.1	5.4	4.3	3.8	3.7	4.9	6.5	8.4	8.0	(37)	
		MCWBR	8.1	7.8	7.9	8.3	7.7	6.2	5.3	5.4	5.3	8.0	9.2	8.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.346	0.398	0.474	0.535	0.555	0.532	0.519	0.487	0.426	0.412	0.393	0.362	(40)	
		taud	2.061	1.916	1.803	1.769	1.819	1.953	2.059	2.165	2.288	2.184	2.134	2.064	(41)	
	Ebn at Noon	Ebn at Noon	748	763	750	740	741	760	765	777	801	752	693	685	(42)	
		Edh at Noon	109	150	191	213	208	182	162	142	117	114	103	101	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.61	2.42	3.58	4.61	5.10	4.89	4.39	4.21	3.70	2.76	1.70	1.29	(44)	
	RadStd	RadStd	0.10	0.16	0.22	0.47	0.45	0.40	0.48	0.33	0.34	0.15	0.14	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.87	+0.93	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page