

MIYAKO, Japan

WMO: 475850

Lat: 39.6471N

Lon: 141.9658E

Elev: 47

StdP: 100.76

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.5	-5.1	-15.3	1.0	-2.0	-14.0	1.1	-1.8	8.2	1.8	6.7	1.6	2.4	240	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	30.6	24.2	28.6	23.3	26.8	22.5	25.1	29.3	24.2	27.5	23.4	26.0	2.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	18.7	27.1	23.1	18.0	26.4	22.4	17.2	25.4	76.8	29.4	73.3	27.7	70.2	26.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.5	5.5	5.0	DB	-8.9	33.8	1.6	1.2	-10.1	34.6	-11.0	35.3	-11.9	35.9	-13.1	36.8
			WB	-9.8	26.6	1.5	0.9	-10.9	27.3	-11.8	27.8	-12.6	28.2	-13.7	28.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	0.6	0.9	3.9	9.0	13.7	16.7	20.9	22.6	19.4	13.9	8.1	3.1
	DBStd	8.20	2.44	2.78	3.25	3.79	3.61	3.07	3.44	3.04	3.05	2.98	3.27	2.82
	HDD10.0	1106	292	256	192	63	9	0	0	0	0	4	75	214
	HDD18.3	2938	551	489	447	281	148	67	13	2	21	141	307	472
	CDD10.0	1517	0	0	3	33	124	202	337	391	283	124	18	1
	CDD18.3	309	0	0	0	1	5	19	92	135	54	3	0	0
	CDH23.3	1578	0	0	0	8	42	90	469	732	229	8	0	0
	CDH26.7	413	0	0	0	2	5	18	132	213	44	0	0	0
Wind	WSAvg	2.3	2.4	2.4	2.6	2.6	2.4	2.1	1.8	1.9	2.2	2.5	2.4	2.3
Precipitation	PrecAvg	1306	67	68	83	86	96	111	141	165	209	127	89	50
	PrecMax	1826	209	245	256	242	238	299	381	513	487	380	293	264
	PrecMin	826	2	2	12	6	10	31	16	20	28	8	3	0
	PrecStd	279	53	58	47	57	57	56	85	115	112	96	70	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	13.5	18.2	24.0	27.0	29.1	32.7	33.2	30.5	24.4	19.8	14.4
		MCWB	5.9	8.1	10.7	13.4	16.4	20.7	24.8	25.4	24.6	18.5	14.1	10.3
	2%	DB	7.8	9.8	14.8	20.6	24.2	25.8	30.1	31.0	27.7	22.0	17.5	12.1
		MCWB	4.0	5.2	8.7	12.1	15.9	19.4	24.1	24.9	22.7	17.3	12.8	8.4
	5%	DB	6.2	7.3	12.3	17.9	22.0	23.6	27.9	29.1	25.8	20.4	15.7	9.9
		MCWB	2.5	3.3	7.1	10.8	14.9	18.5	23.0	24.3	22.2	16.4	11.6	6.5
	10%	DB	4.8	5.6	9.9	15.5	19.9	21.6	25.9	27.1	24.2	19.0	14.1	8.3
		MCWB	1.4	2.1	5.5	9.9	14.1	17.7	22.4	23.5	21.3	15.6	10.6	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.6	11.6	16.0	19.0	22.2	25.7	26.4	25.2	20.6	15.3	11.7
		MCDB	9.2	12.6	16.1	20.2	23.7	25.6	30.2	31.0	28.9	22.6	17.9	13.4
	2%	WB	4.6	5.7	9.5	13.3	17.2	20.5	24.6	25.4	24.0	18.7	13.8	9.0
		MCDB	7.1	9.2	13.6	18.0	21.5	24.3	28.7	29.8	26.6	20.5	16.1	11.0
	5%	WB	3.2	4.0	7.7	12.0	16.1	19.3	23.7	24.6	23.0	17.4	12.5	7.0
		MCDB	5.5	6.6	11.7	16.3	20.4	22.6	27.0	28.3	25.3	19.3	14.8	9.8
	10%	WB	1.8	2.4	6.0	10.6	14.9	18.2	22.7	23.8	21.7	16.2	11.1	5.1
		MCDB	4.3	5.3	9.3	14.5	18.5	20.9	25.3	26.6	23.6	18.4	13.6	7.8
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.1	8.7	9.4	8.7	6.9	6.1	6.2	6.9	8.7	9.4	8.0
		MCDBR	9.2	10.8	12.9	13.5	13.1	10.9	9.9	9.5	8.9	9.8	11.5	10.3
		MCWBR	6.6	7.5	8.6	7.6	7.0	5.9	5.1	4.7	5.2	6.5	8.1	7.9
	5% WB	MCDBR	8.8	10.4	11.9	11.5	11.1	9.4	8.7	8.5	8.0	8.0	10.1	10.2
		MCWBR	6.9	7.8	8.7	7.3	6.7	5.6	4.9	4.4	5.0	6.0	7.9	8.4
Clear-Sky Solar Irradiance	taub	0.371	0.419	0.500	0.549	0.567	0.546	0.549	0.526	0.468	0.435	0.405	0.378	
	taud	2.131	1.986	1.836	1.791	1.811	1.938	2.005	2.069	2.189	2.162	2.144	2.142	
	Ebn at Noon	759	770	745	740	738	754	747	752	773	750	715	714	
	Edh at Noon	110	147	190	212	212	187	173	159	132	122	109	102	
All-Sky Solar Radiation	RadAvg	2.00	2.84	3.79	4.68	5.02	4.93	4.41	4.37	3.67	2.97	2.12	1.68	
	RadStd	0.13	0.17	0.21	0.40	0.48	0.34	0.55	0.55	0.32	0.28	0.14	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page