

WAJIMA, Japan

WMO: 476000

Lat: 37.3914N

Lon: 136.8953E

Elev: 22

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.7	30.0	17.6	13.4	35.1	19.5	14.6	35.4	25.7	40.5	23.3	39.0	8.9	200	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	90.6	76.7	88.2	76.6	85.9	76.1	78.6	86.1	77.7	85.1	76.8	84.1	11.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.5	138.3	82.8	75.6	133.9	82.0	74.6	129.7	81.2	42.1	86.2	41.2	85.4	40.3	84.4	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	19.7	17.3	DB	25.8	95.1	1.7	2.4	24.6	96.8	23.6	98.2	22.6	99.5	21.4	101.3	(4)
(5)			WB	23.8	80.1	1.7	1.3	22.6	81.0	21.6	81.8	20.7	82.5	19.5	83.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	37.7	38.0	42.7	51.7	61.0	68.0	76.5	79.1	71.7	61.6	51.3	42.5	(6)	
	DBStd	15.13	4.03	4.50	5.57	6.31	5.33	4.51	4.77	3.98	4.97	5.15	5.48	4.93	(7)	
	HDD50	1298	380	338	238	53	1	0	0	0	0	0	49	239	(8)	
	HDD65	4104	845	757	691	402	144	20	0	0	5	131	410	699	(9)	
	CDD50	3827	0	2	12	103	344	540	820	901	652	359	89	5	(10)	
	CDD65	1155	0	0	0	2	21	110	355	436	207	24	0	0	(11)	
	CDH74	8650	0	0	0	18	133	391	2719	4135	1183	71	0	0	(12)	
	CDH80	2566	0	0	0	1	16	50	832	1411	249	7	0	0	(13)	
(14) Wind	WSAvg	8.2	9.4	9.0	9.0	8.7	8.0	6.9	7.3	7.1	7.6	8.0	8.7	9.3	(14)	
(15) Precipitation	PrecAvg	87.6	9.0	5.8	5.4	5.0	4.9	6.2	7.6	7.0	9.4	6.9	9.1	11.1	(15)	
	PrecMax	114.6	14.6	10.5	9.8	9.7	11.4	12.6	20.0	20.2	26.0	14.5	18.0	21.6	(16)	
	PrecMin	62.1	3.5	2.3	2.4	1.3	1.7	1.8	0.3	0.3	1.0	2.0	3.1	4.8	(17)	
	PrecStd	12.6	2.6	1.7	1.5	1.9	2.5	2.9	4.5	4.3	5.0	2.5	3.3	3.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	60.4	67.7	76.9	82.2	84.6	93.0	93.6	89.9	79.8	70.1	60.9	(19)	
		MCWB	49.0	51.6	53.4	58.0	63.3	70.5	76.2	76.9	76.3	69.1	60.2	54.6	(20)	
	2%	DB	49.9	53.2	61.2	70.7	77.5	81.0	90.2	91.3	86.0	75.6	66.6	56.6	(21)	
		MCWB	44.5	46.7	50.3	57.2	61.6	69.2	76.0	77.2	75.4	66.2	59.1	51.0	(22)	
	5%	DB	47.3	49.4	56.7	66.8	74.3	78.2	87.6	89.1	82.6	73.2	63.8	53.9	(23)	
		MCWB	42.6	43.9	48.7	55.0	60.8	68.6	75.9	77.2	74.0	64.8	57.6	48.8	(24)	
	10%	DB	44.9	46.4	52.8	62.7	71.3	75.8	84.8	86.9	80.0	70.9	61.2	51.2	(25)	
		MCWB	40.8	41.5	46.8	53.7	60.6	68.2	75.5	77.1	72.2	63.3	55.4	46.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	53.0	55.6	63.0	68.6	74.6	78.8	80.4	77.9	71.4	63.2	55.7	(27)	
		MCDB	53.0	58.4	63.1	69.3	74.2	79.9	86.7	87.7	85.0	77.5	66.4	59.0	(28)	
	2%	WB	45.7	47.7	52.1	59.1	65.4	72.6	77.7	79.2	76.4	68.6	60.7	51.8	(29)	
		MCDB	49.1	52.1	58.5	66.7	72.1	77.3	85.9	86.6	83.1	73.3	65.3	55.7	(30)	
	5%	WB	43.2	44.5	49.7	56.9	63.5	70.9	76.8	78.4	75.1	66.5	58.4	49.4	(31)	
		MCDB	46.5	48.9	55.4	63.7	70.6	75.7	84.9	85.7	81.5	71.3	62.9	53.1	(32)	
	10%	WB	41.1	41.8	47.3	54.8	61.9	69.2	75.9	77.6	73.7	64.5	56.1	46.9	(33)	
		MCDB	44.6	46.0	52.5	61.2	68.8	74.3	83.3	84.8	78.9	69.4	60.7	50.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	11.5	14.6	16.6	15.7	12.4	11.4	12.9	13.3	15.1	13.9	11.1	(35)	
		MCDBR	14.7	18.6	21.5	22.3	21.4	16.3	15.9	15.8	15.5	16.9	17.8	15.8	(36)	
	5% WB	MCWBR	11.2	13.6	14.0	11.9	10.4	7.8	5.8	5.9	7.2	9.3	11.8	11.9	(37)	
		MCWBR	14.2	17.8	18.6	17.4	16.4	12.1	13.7	13.7	13.7	14.0	15.2	15.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.437	0.469	0.529	0.559	0.559	0.566	0.569	0.531	0.480	0.454	0.441	0.443	(40)	
		taud	1.990	1.926	1.819	1.803	1.869	1.936	1.991	2.109	2.197	2.135	2.082	1.990	(41)	
	Ebn at Noon		222	233	232	234	237	235	233	239	245	237	220	209	(42)	
		Edh at Noon	43	51	62	67	64	60	56	49	43	41	38	40	(43)	
(44) All-Sky Solar Radiation	RadAvg		480	752	1145	1511	1702	1650	1559	1632	1265	998	621	423	(44)	
	RadStd		45	78	89	125	177	133	219	170	96	81	56	46	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page