

WAJIMA, Japan

WMO: 476000

Lat: 37.3914N

Lon: 136.8953E

Elev: 7

StdP: 101.24

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.8	-1.1	-8.0	1.9	1.7	-7.0	2.1	1.9	11.5	4.7	10.4	3.9	4.0	200	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	32.6	24.8	31.2	24.8	29.9	24.5	25.9	30.1	25.4	29.5	24.9	28.9	5.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	19.8	28.2	24.2	19.1	27.8	23.7	18.5	27.3	80.1	30.1	78.0	29.7	76.0	29.1	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.8	7.7	-3.4	35.0	0.9	1.3	-4.1	36.0	-4.7	36.8	-5.2	37.5	-5.9	38.5		
			-4.6	26.7	0.9	0.7	-5.2	27.2	-5.8	27.7	-6.3	28.1	-6.9	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	3.2	3.3	6.0	10.9	16.1	20.0	24.7	26.1	22.1	16.4	10.7	5.8
	DBStd	8.41	2.24	2.50	3.10	3.50	2.96	2.51	2.65	2.21	2.76	2.86	3.05	2.74
	HDD10.0	721	211	188	132	29	1	0	0	0	0	27	133	
	HDD18.3	2280	469	421	384	223	80	11	0	3	73	228	388	
	CDD10.0	2126	0	1	7	57	191	300	456	501	362	199	49	3
	CDD18.3	642	0	0	0	1	12	61	197	242	115	13	0	0
	CDH23.3	4806	0	0	0	10	74	217	1511	2297	657	39	0	0
	CDH26.7	1426	0	0	0	1	9	28	462	784	138	4	0	0
Wind	WSAvg	3.7	4.2	4.0	4.0	3.9	3.6	3.1	3.2	3.2	3.4	3.6	3.9	4.2
Precipitation	PrecAvg	2226	228	147	136	127	125	158	194	177	240	176	232	281
	PrecMax	2911	370	267	249	247	290	320	508	512	661	369	456	549
	PrecMin	1578	89	59	62	33	43	46	7	8	25	50	79	121
	PrecStd	319	65	42	39	49	63	74	114	108	128	63	84	81
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	15.8	19.8	25.0	27.9	29.2	33.9	34.2	32.2	26.6	21.2	16.1
		MCWB	9.4	10.9	11.9	14.5	17.4	21.4	24.6	24.9	24.6	20.6	15.6	12.6
	2%	DB	10.0	11.8	16.2	21.5	25.3	27.2	32.3	32.9	30.0	24.2	19.2	13.7
		MCWB	7.0	8.2	10.2	14.0	16.5	20.7	24.4	25.1	24.1	19.0	15.0	10.5
	5%	DB	8.5	9.7	13.7	19.3	23.5	25.7	30.9	31.7	28.1	22.9	17.7	12.2
		MCWB	5.9	6.6	9.3	12.8	16.0	20.3	24.4	25.1	23.3	18.2	14.2	9.3
	10%	DB	7.2	8.0	11.6	17.1	21.9	24.3	29.3	30.5	26.7	21.6	16.2	10.7
		MCWB	4.9	5.3	8.2	12.0	15.9	20.1	24.2	25.0	22.3	17.4	13.0	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.7	13.1	17.2	20.3	23.7	26.0	26.9	25.5	21.9	17.3	13.2
		MCDB	11.7	14.7	17.3	20.7	23.5	26.6	30.4	30.9	29.5	25.3	19.1	15.0
	2%	WB	7.6	8.7	11.2	15.0	18.5	22.6	25.4	26.2	24.7	20.3	16.0	11.0
		MCDB	9.5	11.1	14.7	19.3	22.3	25.2	29.9	30.4	28.4	23.0	18.5	13.2
	5%	WB	6.2	6.9	9.8	13.8	17.5	21.6	24.9	25.8	24.0	19.1	14.6	9.7
		MCDB	8.1	9.4	13.0	17.6	21.4	24.3	29.4	29.8	27.5	21.8	17.1	11.7
	10%	WB	5.1	5.4	8.5	12.7	16.6	20.7	24.4	25.3	23.1	18.1	13.4	8.3
		MCDB	7.0	7.8	11.4	16.2	20.4	23.5	28.5	29.3	26.1	20.8	15.9	10.3
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.4	8.1	9.2	8.7	6.9	6.3	7.1	7.4	8.4	7.7	6.2
		MCDBR	8.1	10.3	12.0	12.4	11.9	9.0	8.9	8.8	8.6	9.4	9.9	8.8
		MCWBR	6.2	7.6	7.8	6.6	5.8	4.3	3.2	3.3	4.0	5.2	6.5	6.6
	5% WB	MCDBR	7.9	9.9	10.3	9.7	9.1	6.7	7.6	7.6	7.6	7.8	8.4	8.4
		MCWBR	6.4	7.7	7.5	6.2	5.5	3.8	3.1	3.4	3.8	5.0	6.3	6.8
Clear-Sky Solar Irradiance	taub	0.437	0.469	0.529	0.559	0.559	0.566	0.569	0.531	0.480	0.454	0.441	0.443	
	taud	1.990	1.926	1.819	1.803	1.869	1.936	1.991	2.109	2.197	2.135	2.082	1.990	
	Ebn at Noon	699	734	731	739	748	742	736	755	773	746	695	658	
	Edh at Noon	134	161	197	211	201	188	177	154	134	129	121	126	
All-Sky Solar Radiation	RadAvg	1.51	2.37	3.61	4.76	5.37	5.20	4.92	5.15	3.99	3.15	1.96	1.33	
	RadStd	0.14	0.25	0.28	0.40	0.56	0.42	0.69	0.54	0.30	0.25	0.17	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.30	N/A	N/A	N/A	N/A

Nomenclature: See separate page