

GIFU, Japan

WMO: 476320

Lat: 35.4003N

Lon: 136.7630E

Elev: 57

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	31.1	14.6	11.6	42.6	17.0	13.0	42.3	18.9	41.4	17.3	42.1	4.4	290	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.4	95.7	77.3	93.3	76.7	90.9	76.0	79.2	89.9	78.4	88.3	77.6	86.8	9.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	139.9	82.5	76.0	136.0	82.3	75.1	132.1	82.1	42.8	89.8	42.0	88.8	41.2	86.8	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.8	13.9	DB	25.6	99.0	2.2	2.3	24.0	100.7	22.6	102.0	21.4	103.3	19.8	105.0	(4)
(5)			WB	23.7	80.9	1.8	0.9	22.4	81.5	21.4	82.1	20.4	82.6	19.1	83.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.8	40.4	42.2	48.3	58.4	67.6	74.2	81.7	84.3	76.9	66.5	54.9	45.0
	DBStd	15.78	3.98	4.85	5.47	5.81	4.44	4.11	4.67	3.87	4.98	5.00	5.49	5.12
	HDD50	814	297	225	98	7	0	0	0	0	0	0	16	171
	HDD65	3116	762	640	516	206	24	1	0	0	0	42	304	621
	CDD50	5125	0	5	47	260	545	727	983	1062	808	510	164	14
	CDD65	1953	0	0	0	9	104	278	518	597	359	87	1	0
	CDH74	18026	0	0	1	63	596	1774	5434	6971	2837	348	2	0
	CDH80	7042	0	0	0	5	111	479	2302	3205	903	37	0	0
Wind	WSAvg	5.8	5.7	6.2	6.7	6.6	6.3	5.7	5.7	5.9	5.5	5.1	4.8	5.2
Precipitation	PrecAvg	69.9	2.9	3.3	4.9	5.6	7.0	8.3	9.3	6.2	9.7	5.7	3.9	3.1
	PrecMax	86.6	6.5	6.4	9.1	9.5	13.5	14.7	20.7	14.1	20.0	15.7	9.9	5.0
	PrecMin	46.8	1.1	1.6	1.6	0.7	2.6	3.1	1.9	1.0	2.4	0.4	0.5	0.6
	PrecStd	11.1	1.5	1.3	1.9	2.5	2.6	2.9	4.7	3.5	4.6	3.0	2.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	61.8	69.4	79.9	87.3	91.4	98.2	99.5	93.5	83.7	72.8	62.6
		MCWB	45.8	50.1	53.6	59.7	64.2	73.5	77.7	78.1	75.7	69.2	59.9	52.0
	2%	DB	52.8	57.1	65.1	75.4	82.9	87.7	95.4	96.6	90.3	80.5	69.7	59.0
		MCWB	43.6	46.7	51.9	59.0	63.8	71.0	77.4	77.3	74.2	66.4	57.5	49.7
	5%	DB	50.3	54.0	61.8	72.0	80.0	85.1	92.8	94.3	87.8	77.8	66.9	56.2
		MCWB	42.4	44.7	50.0	57.3	62.8	70.0	76.9	77.0	73.2	65.4	56.4	47.9
	10%	DB	48.0	51.2	58.6	69.0	77.2	82.6	90.2	92.0	85.2	75.4	64.2	53.6
		MCWB	40.8	43.1	48.7	56.6	62.0	69.0	76.2	76.6	72.4	63.8	55.6	46.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.4	52.8	58.3	67.7	71.1	77.0	80.5	80.5	78.5	74.2	63.8	56.0
		MCDB	52.2	57.7	61.8	71.5	76.2	84.2	92.8	92.2	85.6	77.8	67.7	59.0
	2%	WB	45.6	49.2	55.6	63.3	68.6	75.2	79.2	79.4	77.2	70.9	61.3	52.0
		MCDB	50.1	54.3	61.3	69.5	75.4	82.3	90.2	90.2	84.1	76.5	65.5	56.2
	5%	WB	43.6	46.5	53.0	61.1	66.5	73.7	78.3	78.7	76.3	68.3	59.3	49.3
		MCDB	48.6	51.5	59.0	67.7	74.5	80.6	88.3	89.1	83.2	74.6	63.8	54.8
	10%	WB	41.7	43.9	50.1	58.9	64.8	72.1	77.4	78.0	75.2	66.1	57.3	47.1
		MCDB	47.1	50.3	57.0	66.0	72.8	79.1	86.4	87.8	82.2	72.6	62.4	52.6
Mean Daily Temperature Range	5% DB	MDBR	13.4	14.8	16.4	17.3	16.6	14.0	13.2	14.4	13.7	14.9	14.9	13.7
		MCDBR	16.6	18.6	21.3	22.1	21.8	18.2	16.8	17.0	16.1	17.4	17.9	17.0
		MCWBR	10.3	11.4	12.0	10.6	9.0	6.8	5.5	5.2	6.0	7.8	9.6	10.4
	5% WB	MCDBR	14.5	16.0	15.8	15.4	15.5	13.3	14.8	14.7	12.8	13.2	13.4	14.2
		MCWBR	10.3	11.5	12.1	9.4	8.7	5.8	5.3	5.0	5.6	7.5	9.2	10.3
Clear-Sky Solar Irradiance	taub	0.396	0.434	0.502	0.542	0.550	0.577	0.565	0.544	0.494	0.456	0.416	0.395	
	taud	2.130	2.042	1.902	1.860	1.905	1.910	1.997	2.049	2.153	2.171	2.185	2.157	
	Ebn at Noon	245	249	243	241	241	233	235	238	244	240	237	236	
	Edh at Noon	38	47	58	64	62	62	56	52	45	41	36	35	
All-Sky Solar Radiation	RadAvg	699	929	1236	1499	1656	1509	1529	1576	1262	1037	778	620	
	RadStd	49	73	91	140	180	134	220	150	114	97	66	55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page