

NAGOYA, Japan

WMO: 476360

Lat: 35.1678N

Lon: 136.9656E

Elev: 185

StdP: 14.60

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.9	31.5	13.7	11.1	41.4	15.8	12.3	40.6	21.0	42.8	19.3	43.2	5.7	350	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	94.9	76.8	92.6	76.4	90.3	75.8	78.9	88.7	78.1	87.4	77.3	86.2	8.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.6	139.8	82.2	75.8	135.7	81.9	74.9	131.9	81.8	42.6	88.9	41.7	87.6	41.0	86.3	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	16.8	14.8	DB	26.3	98.6	2.1	2.6	24.8	100.5	23.5	102.0	22.3	103.4	20.8	105.3	(4)
(5)			WB	23.6	80.7	1.6	1.0	22.5	81.4	21.6	82.0	20.7	82.6	19.5	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	40.8	42.5	48.8	58.7	67.5	74.0	81.4	84.0	76.9	66.4	55.0	45.3
	DBStd	15.52	3.83	4.85	5.42	5.65	4.28	4.03	4.52	3.75	5.00	4.98	5.33	4.94
	HDD50	773	286	217	90	6	0	0	0	0	0	0	14	160
	HDD65	3058	750	631	504	198	23	1	0	0	0	41	300	610
	CDD50	5115	0	6	52	267	544	720	975	1053	808	510	165	15
	CDD65	1925	0	0	0	10	102	270	510	588	358	86	1	0
	CDH74	17227	0	0	0	55	523	1593	5251	6738	2766	300	1	0
	CDH80	6469	0	0	0	3	88	401	2134	2973	842	28	0	0
Wind	WSAvg	6.7	7.0	7.5	7.9	7.4	7.0	6.0	6.2	6.4	6.3	6.0	5.9	6.5
Precipitation	PrecAvg	61.4	1.9	2.5	4.4	5.4	6.1	7.8	8.1	5.7	8.8	5.2	3.1	1.9
	PrecMax	80.0	6.1	6.2	8.3	9.1	13.0	20.2	17.7	14.9	27.9	20.9	9.1	4.9
	PrecMin	35.6	0.0	0.4	0.1	0.3	2.0	2.3	1.1	0.2	1.2	0.4	0.3	0.0
	PrecStd	10.2	1.3	1.5	1.9	2.0	2.5	3.1	4.1	3.7	5.1	3.6	1.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	62.2	69.3	79.3	86.4	90.9	97.3	98.8	92.8	83.1	72.3	63.0
		MCWB	45.9	51.5	53.6	59.4	64.4	74.3	77.0	77.3	75.5	69.2	60.6	54.2
	2%	DB	52.7	57.4	65.1	75.2	82.3	87.0	94.6	95.7	89.8	79.9	69.2	58.7
		MCWB	43.8	46.6	51.8	58.4	63.5	71.1	76.7	77.0	74.5	66.7	58.1	49.6
	5%	DB	50.3	54.1	61.9	71.8	79.4	84.4	92.1	93.5	87.4	77.3	66.5	56.1
		MCWB	42.2	44.8	50.8	57.0	62.5	69.9	76.4	76.8	73.2	65.6	56.7	48.0
	10%	DB	48.1	51.3	58.9	68.8	76.7	81.9	89.8	91.3	85.0	74.9	63.9	53.6
		MCWB	40.6	43.0	48.8	56.4	61.9	68.9	75.8	76.3	72.4	64.3	55.8	46.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	54.0	59.1	67.3	71.6	77.2	79.7	80.5	78.4	74.0	64.6	56.6
		MCDB	52.8	59.3	61.7	69.8	75.8	85.4	90.5	91.7	85.6	77.5	67.5	59.0
	2%	WB	45.8	49.8	56.1	63.5	68.9	75.3	78.6	79.2	77.2	71.0	61.6	52.2
		MCDB	50.0	54.7	61.5	69.1	74.2	81.6	88.7	89.2	84.2	76.4	65.4	56.8
	5%	WB	43.5	46.7	53.4	61.1	66.5	73.8	77.8	78.5	76.2	68.4	59.5	49.3
		MCDB	48.5	51.7	59.0	67.8	73.9	80.0	87.2	87.9	83.0	74.1	63.7	54.2
	10%	WB	41.6	43.9	50.6	58.9	64.8	72.1	77.0	77.8	75.1	66.3	57.3	47.2
		MCDB	47.1	49.9	57.0	65.8	72.4	78.3	85.9	87.0	81.8	72.5	62.4	52.5
Mean Daily Temperature Range	5% DB	MDBR	13.4	14.8	16.3	17.0	16.1	13.4	12.8	13.8	13.0	13.9	14.1	13.3
		MCDBR	16.1	18.3	20.2	21.2	20.7	17.1	16.3	16.3	15.3	15.8	16.6	15.7
		MCWBR	10.0	11.1	11.8	9.9	8.5	6.3	5.4	5.0	5.5	7.3	9.2	9.8
	5% WB	MCDBR	14.1	15.4	15.6	15.1	15.0	12.5	14.1	14.0	12.4	12.5	12.8	13.2
	MCWBR	10.1	11.3	12.7	9.8	8.8	5.8	5.2	5.0	5.5	7.8	9.4	9.8	
Clear-Sky Solar Irradiance	taub	0.388	0.427	0.493	0.536	0.544	0.573	0.562	0.540	0.493	0.456	0.412	0.387	
	taud	2.181	2.085	1.932	1.878	1.925	1.926	2.008	2.058	2.157	2.179	2.210	2.205	
	Ebn at Noon	249	253	246	242	242	235	236	239	244	241	239	241	
	Edh at Noon	36	45	56	63	61	61	56	52	45	40	35	34	
All-Sky Solar Radiation	RadAvg	757	978	1276	1519	1662	1497	1561	1605	1276	1038	805	672	
	RadStd	52	72	89	146	181	136	217	148	115	102	69	53	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page