

KOFU, Japan

WMO: 476380

Lat: 35.6672N

Lon: 138.5539E

Elev: 924

StdP: 14.21

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	26.6	-0.3	5.6	40.4	3.0	6.6	41.0	24.6	43.5	22.5	43.9	2.7	20	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.1	94.9	75.6	92.3	74.8	89.8	74.0	77.7	89.2	76.7	87.2	75.8	85.6	9.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.7	134.7	82.4	73.8	130.5	81.7	72.9	126.5	81.1	42.0	89.3	40.9	87.4	40.0	85.8	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.8	17.7	15.0	20.2	99.2	1.7	1.9	19.0	100.5	18.1	101.6	17.1	102.7	15.9	104.1	
			DB												
			WB	17.6	79.5	1.6	1.1	16.5	80.4	15.6	81.0	14.7	81.7	13.5	82.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.3	38.0	41.0	48.0	58.1	67.1	73.3	80.5	82.5	75.2	64.0	52.2	42.4
	DBStd	16.01	3.91	5.19	5.84	6.18	4.65	4.31	4.73	4.06	5.63	5.61	5.53	4.93
	HDD50	1030	374	257	110	9	0	0	0	0	0	0	39	241
	HDD65	3457	838	672	526	217	32	2	0	0	3	85	383	699
	CDD50	4791	1	5	49	252	529	698	946	1009	755	435	106	6
	CDD65	1742	0	0	0	10	96	249	481	544	307	55	0	0
	CDH74	14202	0	0	3	96	603	1421	4339	5413	2105	221	1	0
	CDH80	5296	0	0	0	12	125	385	1782	2280	675	37	0	0
	WSAvg	4.9	5.1	5.7	6.1	5.9	5.3	4.7	4.7	4.8	4.2	3.9	3.8	4.5
	PrecAvg	52.2	2.0	2.0	3.6	3.6	4.1	5.3	5.8	6.3	8.5	6.2	2.9	1.8
Precipitation	PrecMax	75.8	5.7	4.8	6.5	7.2	11.1	9.3	11.9	14.5	18.0	25.0	7.1	4.3
	PrecMin	34.1	0.0	0.1	1.8	0.9	1.4	2.5	1.6	1.7	2.1	0.5	0.1	0.0
	PrecStd	9.8	1.5	1.2	1.3	1.6	2.1	1.9	2.9	3.5	4.4	4.8	1.8	1.1
	PrecStd	9.8	1.5	1.2	1.3	1.6	2.1	1.9	2.9	3.5	4.4	4.8	1.8	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.4	64.1	72.0	81.3	87.6	91.4	98.1	98.3	93.1	84.5	71.6	62.0
		MCWB	42.9	50.1	52.3	58.9	64.1	70.8	74.9	75.9	73.9	67.9	57.7	48.3
	2%	DB	52.2	58.1	66.9	76.6	83.4	87.2	94.9	95.3	89.8	79.5	67.7	57.4
		MCWB	39.8	45.2	50.5	57.6	62.9	69.5	75.4	76.0	72.8	65.7	55.3	45.7
	5%	DB	49.7	54.2	62.8	72.9	80.3	84.3	92.1	93.0	86.9	75.9	64.7	54.5
		MCWB	38.3	42.4	48.7	56.2	61.9	67.9	74.9	75.5	71.9	63.3	53.9	44.4
	10%	DB	47.2	51.2	59.1	69.5	77.2	81.6	89.2	90.5	83.9	73.2	61.8	51.9
		MCWB	37.0	40.6	47.0	54.8	61.0	67.8	74.4	75.0	70.7	62.3	52.8	42.6
	0.4%	WB	46.2	52.4	56.9	66.4	70.4	75.4	78.9	79.3	76.8	70.5	61.6	53.0
		MCDB	51.4	60.5	63.5	73.2	78.9	85.3	92.0	92.0	88.0	78.3	66.1	57.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.1	47.9	54.1	62.5	67.3	73.4	77.4	78.1	75.2	68.6	59.0	49.1
		MCDB	48.9	55.2	61.9	70.6	76.5	81.2	89.1	89.7	84.4	75.4	63.4	53.9
	5%	WB	40.1	44.8	51.5	59.7	65.3	71.9	76.5	77.2	74.1	66.4	56.8	46.4
		MCDB	47.0	51.2	59.6	68.8	75.0	79.8	87.1	87.7	82.5	73.4	61.9	52.2
	10%	WB	38.1	41.9	48.9	57.4	63.5	70.4	75.5	76.3	73.0	64.4	54.5	44.1
		MCDB	45.3	48.9	57.2	66.0	73.0	78.0	85.3	86.2	80.8	70.9	60.0	49.9
Mean Daily Temperature Range	5% DB	MDBR	18.8	19.1	19.9	20.5	19.3	15.8	15.4	16.1	15.1	15.9	17.9	18.4
		MCDBR	22.1	23.3	25.7	25.3	24.4	20.2	19.7	19.1	18.4	18.9	20.2	20.7
		MCWBR	12.4	13.6	14.0	11.6	9.7	7.1	5.7	5.5	6.2	8.1	10.3	11.7
	5% WB	MCDBR	19.5	20.4	22.0	20.7	20.2	15.3	17.7	17.7	15.9	15.6	15.7	17.4
		MCWBR	12.0	13.1	13.6	11.0	9.3	6.3	5.6	5.5	5.8	7.4	9.2	10.8
Clear-Sky Solar Irradiance	taub		0.372	0.425	0.499	0.559	0.588	0.627	0.605	0.612	0.532	0.486	0.409	0.367
	taud		2.173	2.023	1.876	1.792	1.780	1.756	1.860	1.833	1.995	2.041	2.178	2.243
	Ebn at Noon		253	251	243	236	231	222	226	220	232	230	238	247
	Edh at Noon		36	47	60	68	70	72	64	65	52	46	36	32
	RadAvg		877	1078	1329	1529	1643	1442	1484	1495	1214	1013	844	771
All-Sky Solar Radiation	RadStd		45	77	86	148	165	113	210	133	108	104	69	56

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.82	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page