

KOFU, Japan

WMO: 476380

Lat: 35.6672N

Lon: 138.5539E

Elev: 282

StdP: 97.99

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	-3.0	-18.0	0.8	4.7	-16.1	0.9	5.0	11.0	6.4	10.0	6.6	1.2	20	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	34.9	24.2	33.5	23.8	32.1	23.3	25.4	31.8	24.8	30.7	24.3	29.8	4.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.7	19.2	28.0	23.2	18.6	27.6	22.7	18.1	27.3	79.7	31.9	77.4	30.8	75.2	29.9	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	7.9	6.7		DB	-6.5	37.3	0.9	1.1	-7.2	38.1	-7.7	38.7	-8.3	39.3	-8.9	40.0
				WB	-8.0	26.4	0.9	0.6	-8.6	26.9	-9.1	27.2	-9.6	27.6	-10.3	28.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	3.3	5.0	8.9	14.5	19.5	22.9	26.9	28.1	24.0	17.8	11.2	5.8	(6)
		DBStd	8.89	2.17	2.88	3.24	3.43	2.58	2.40	2.63	2.25	3.13	3.12	3.07	2.74	
		HDD10.0	572	208	143	61	5	0	0	0	0	0	22	134		
		HDD18.3	1921	466	373	292	121	18	1	0	2	47	213	388		
		CDD10.0	2662	1	3	27	140	294	388	526	561	419	242	59	3	
		CDD18.3	968	0	0	0	6	53	138	267	302	171	31	0	0	
		CDH23.3	7890	0	0	2	53	335	789	2411	3007	1169	123	1	0	
		CDH26.7	2942	0	0	0	7	69	214	990	1267	375	21	0	0	
(14)	Wind	WSAvg	2.2	2.3	2.5	2.7	2.6	2.4	2.1	2.1	2.1	1.9	1.7	1.7	2.0	(14)
(15)	Precipitation	PrecAvg	1326	51	52	91	92	105	134	148	161	216	158	73	45	(15)
		PrecMax	1925	146	121	165	182	283	235	303	369	458	636	180	109	
		PrecMin	865	0	2	46	24	35	64	41	44	53	13	2	0	
		PrecStd	250	38	30	33	41	54	48	73	89	111	123	45	28	
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	17.8	22.2	27.4	30.9	33.0	36.7	36.8	33.9	29.1	22.0	16.7	(20)
			MCWB	6.0	10.0	11.3	14.9	17.8	21.5	23.8	24.4	23.3	19.9	14.3	9.1	
		2%	DB	11.2	14.5	19.4	24.8	28.6	30.7	34.9	35.2	32.1	26.4	19.8	14.1	
			MCWB	4.3	7.3	10.3	14.2	17.2	20.8	24.1	24.4	22.6	18.7	13.0	7.6	
		5%	DB	9.9	12.4	17.1	22.7	26.8	29.1	33.4	33.9	30.5	24.4	18.2	12.5	
			MCWB	3.5	5.8	9.3	13.4	16.6	19.9	23.8	24.1	22.2	17.4	12.1	6.9	
		10%	DB	8.4	10.7	15.1	20.8	25.1	27.5	31.8	32.5	28.8	22.9	16.5	11.1	
			MCWB	2.8	4.8	8.4	12.6	16.1	19.9	23.6	23.9	21.5	16.8	11.5	5.9	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	11.3	13.9	19.1	21.3	24.1	26.0	26.3	24.9	21.4	16.4	11.7	(27)
			MCDB	10.8	15.9	17.5	22.9	26.1	29.6	33.4	33.3	31.1	25.7	19.0	14.0	
		2%	WB	5.6	8.8	12.3	16.9	19.6	23.0	25.2	25.6	24.0	20.3	15.0	9.5	
			MCDB	9.4	12.9	16.6	21.5	24.7	27.4	31.7	32.0	29.1	24.1	17.5	12.2	
		5%	WB	4.5	7.1	10.8	15.4	18.5	22.2	24.7	25.1	23.4	19.1	13.8	8.0	
			MCDB	8.4	10.7	15.3	20.4	23.9	26.5	30.6	30.9	28.1	23.0	16.6	11.2	
		10%	WB	3.4	5.5	9.4	14.1	17.5	21.3	24.2	24.6	22.8	18.0	12.5	6.7	
			MCDB	7.4	9.4	14.0	18.9	22.8	25.6	29.6	30.1	27.1	21.6	15.6	9.9	
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	10.6	11.0	11.4	10.7	8.8	8.5	9.0	8.4	8.8	9.9	10.2	(35)
			MCDBR	12.3	12.9	14.3	14.1	13.6	11.2	10.9	10.6	10.2	10.5	11.2	11.5	
		5% WB	MCWBR	6.9	7.6	7.8	6.4	5.4	3.9	3.2	3.1	3.5	4.5	5.7	6.5	
			MCWBR	10.8	11.3	12.2	11.5	11.2	8.5	9.8	9.8	8.8	8.7	8.7	9.7	
(40)	Clear-Sky Solar Irradiance	taub		0.372	0.425	0.499	0.559	0.588	0.627	0.605	0.612	0.532	0.486	0.409	0.367	(40)
			taud	2.173	2.023	1.876	1.792	1.780	1.756	1.860	1.833	1.995	2.041	2.178	2.243	
		Ebn at Noon		799	792	766	743	729	699	712	695	730	724	751	780	
			Edh at Noon	114	149	188	215	221	226	202	204	165	145	113	101	
(44)	All-Sky Solar Radiation	RadAvg		2.76	3.40	4.19	4.82	5.18	4.54	4.68	4.71	3.83	3.19	2.66	2.43	(44)
		RadStd		0.14	0.24	0.27	0.47	0.52	0.36	0.66	0.42	0.34	0.33	0.22	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page