

FUJISAN, Japan

WMO: 476390

Lat: 35.3606N

Lon: 138.7272E

Elev: 12393

StdP: 9.20

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.7	-16.2	-43.9	0.7	4.1	-39.6	0.9	0.1	77.0	-5.3	70.5	-7.2	27.4	310	1.167

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	53.7	42.3	51.2	41.4	48.7	40.5	47.2	49.6	45.7	47.7	44.5	46.1	2.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.5	75.1	47.7	45.0	70.9	46.1	43.8	67.7	45.0	23.3	49.5	22.3	48.1	21.4	46.2	54.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	63.9	55.7	48.9	DB	-25.6	58.5	3.7	2.8	-28.3	60.6	-30.5	62.2	-32.6	63.8	-35.3	65.9
(5)				WB	-25.9	50.1	3.3	2.0	-28.3	51.6	-30.2	52.8	-32.0	53.9	-34.4	55.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	-1.3	0.5	6.0	16.1	26.3	34.5	42.2	44.0	38.6	28.5	16.0	4.4
	DBStd	17.30	8.14	8.95	8.73	8.17	5.99	5.04	3.97	3.46	5.23	6.53	7.66	8.39
	HDD50	10430	1590	1387	1363	1016	734	465	243	187	344	667	1021	1413
	HDD65	15902	2055	1807	1828	1466	1199	915	707	651	793	1132	1471	1878
	CDD50	3	0	0	0	0	0	0	1	1	1	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.4	23.4	22.2	20.8	21.4	16.6	16.8	12.7	10.1	12.1	14.6	18.4	20.1
Precipitation	PrecAvg	69.3	2.7	3.1	5.2	5.4	6.1	7.6	7.7	7.2	10.0	7.4	4.3	2.4
	PrecMax	98.7	6.4	6.9	9.9	11.0	12.1	12.2	16.3	18.6	19.5	29.5	10.1	5.9
	PrecMin	44.7	0.0	0.5	2.2	2.0	2.4	3.8	1.7	1.3	2.8	0.8	0.2	0.1
	PrecStd	13.1	1.7	1.7	1.9	2.2	2.2	2.3	4.0	4.3	5.0	5.6	2.4	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	25.8	28.8	35.1	42.5	48.3	57.7	56.7	55.5	46.0	36.4	28.1
		MCWB	21.8	25.0	27.9	28.9	34.8	33.7	43.5	44.9	42.9	35.7	31.1	27.8
	2%	DB	17.8	21.5	25.3	32.6	39.3	44.8	53.2	53.9	50.9	42.0	31.7	22.9
		MCWB	16.5	20.6	23.4	28.7	33.0	36.9	42.5	42.9	38.8	34.4	28.6	21.2
	5%	DB	13.5	17.4	22.0	30.7	37.2	43.0	50.4	51.6	47.4	39.5	29.6	19.6
		MCWB	11.2	15.1	19.8	27.1	31.9	38.3	41.3	42.1	37.3	33.6	26.0	17.1
	10%	DB	10.3	13.9	18.9	28.1	35.2	41.5	47.8	49.2	44.9	37.4	26.9	16.3
		MCWB	7.6	10.8	16.1	24.1	29.7	37.2	40.7	41.7	37.7	32.5	22.6	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	25.3	28.4	33.5	39.9	44.2	49.0	50.1	46.8	42.7	34.9	27.0
		MCDB	22.8	25.6	28.6	33.9	40.4	44.7	52.2	53.0	49.0	43.2	35.6	27.1
	2%	WB	17.1	20.8	24.5	31.2	37.2	42.5	46.8	47.7	44.7	39.6	30.7	21.9
		MCDB	17.9	21.2	24.9	31.6	37.8	42.9	49.2	50.2	46.2	40.1	31.0	22.2
	5%	WB	12.1	16.1	20.7	28.6	35.0	41.3	45.3	46.3	43.2	37.4	27.9	18.1
		MCDB	13.0	16.8	21.3	29.1	35.7	41.8	47.2	48.3	44.6	37.7	28.4	18.6
	10%	WB	7.9	11.6	16.6	24.8	32.3	39.7	44.0	45.0	41.9	35.0	24.3	13.6
		MCDB	9.9	13.1	17.9	26.7	33.1	40.4	45.7	46.8	43.1	35.7	25.2	15.5
Mean Daily Temperature Range	5% DB	MDBR	10.3	11.2	11.4	10.4	9.7	8.9	8.8	9.4	9.5	9.2	9.8	10.0
		MCDBR	14.1	15.1	15.8	11.8	11.8	10.7	12.4	12.9	12.5	10.8	12.1	14.3
		MCWBR	14.6	16.1	16.6	12.7	12.2	11.6	12.2	12.3	12.1	11.8	13.5	15.6
	5% WB	MCDBR	14.6	15.2	15.6	12.3	10.9	8.7	9.9	10.3	9.9	9.6	12.8	14.6
		MCWBR	15.8	16.7	17.4	14.9	14.5	11.8	11.0	11.1	11.7	13.3	15.6	16.6
Clear-Sky Solar Irradiance	taub	0.203	0.220	0.243	0.266	0.280	0.297	0.296	0.296	0.271	0.253	0.225	0.205	
	taud	2.696	2.648	2.589	2.544	2.521	2.502	2.545	2.544	2.620	2.633	2.687	2.713	
	Ebn at Noon	333	334	331	324	318	311	310	310	316	316	320	327	
	Edh at Noon	21	25	29	32	33	34	32	32	28	25	21	19	
All-Sky Solar Radiation	RadAvg	899	1084	1334	1529	1638	1429	1524	1540	1234	1009	844	789	
	RadStd	52	88	86	155	167	124	223	133	110	105	73	58	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+2.05	+1.53	+1.75	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page