

FUJISAN, Japan

WMO: 476390

Lat: 35.3606N

Lon: 138.7272E

Elev: 3778

StdP: 63.45

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.7	(c) -26.8	(d) -42.2	(e) 0.1	(f) -15.5	(g) -39.8	(h) 0.1	(i) -17.7	(j) 34.4	(k) -20.7	(l) 31.5	(m) -21.8	(n) 12.2	(o) 310	(p) 1.167

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.2	(c) 12.1	(d) 5.7	(e) 10.7	(f) 5.2	(g) 9.3	(h) 4.7	(i) 8.5	(j) 9.8	(k) 7.6	(l) 8.7	(m) 6.9	(n) 7.8	(o) 1.2	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.0	10.7	8.7	7.2	10.1	7.9	6.5	9.7	7.2	36.3	9.7	34.0	8.9	32.0	7.9	12.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 28.5	(b) 24.9	(c) 21.9	(e) -32.0	(f) 14.7	(g) 2.1	(h) 1.6	(i) -33.5	(j) 15.9	(k) -34.7	(l) 16.8	(m) -35.9	(n) 17.7	(o) -37.4	(p) 18.8		
(a) 28.5	(b) 24.9	(c) 21.9	(e) -32.2	(f) 10.1	(g) 1.8	(h) 1.1	(i) -33.5	(j) 10.9	(k) -34.5	(l) 11.6	(m) -35.6	(n) 12.2	(o) -36.9	(p) 13.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.9	-18.5	-17.5	-14.4	-8.8	-3.2	1.4	5.7	6.7	3.6	-2.0	-8.9	-15.3
	DBStd	9.61	4.52	4.97	4.85	4.54	3.33	2.80	2.20	1.92	2.90	3.63	4.26	4.66
	HDD10.0	5794	883	771	757	564	408	258	135	104	191	371	567	785
	HDD18.3	8834	1142	1004	1016	814	666	508	393	362	441	629	817	1043
	CDD10.0	2	0	0	0	0	0	0	1	1	1	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.8	10.4	9.9	9.3	9.6	7.4	7.5	5.7	4.5	5.4	6.5	8.2	9.0
Precipitation	PrecAvg	1760	68	80	133	138	154	194	196	182	255	189	108	62
	PrecMax	2508	162	174	252	280	308	309	414	473	495	750	256	149
	PrecMin	1136	1	12	57	52	62	96	44	33	72	21	6	3
	PrecStd	334	43	43	47	56	57	59	102	110	126	142	61	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-5.1	-3.4	-1.8	1.7	5.8	9.1	14.3	13.7	13.1	7.8	2.4	-2.2
		MCWB	-5.7	-3.9	-2.3	-1.7	1.6	0.9	6.4	7.2	6.0	2.0	-0.5	-2.4
	2%	DB	-7.9	-5.8	-3.7	0.3	4.1	7.1	11.8	12.2	10.5	5.6	-0.1	-5.1
		MCWB	-8.6	-6.3	-4.8	-1.8	0.5	2.7	5.9	6.1	3.8	1.4	-1.9	-6.0
	5%	DB	-10.3	-8.1	-5.6	-0.7	2.9	6.1	10.2	10.9	8.6	4.2	-1.3	-6.9
		MCWB	-11.5	-9.4	-6.8	-2.7	-0.1	3.5	5.2	5.6	2.9	0.9	-3.3	-8.3
	10%	DB	-12.1	-10.1	-7.3	-2.2	1.8	5.3	8.8	9.6	7.2	3.0	-2.8	-8.7
		MCWB	-13.5	-11.8	-8.9	-4.4	-1.3	2.9	4.8	5.4	3.2	0.3	-5.2	-10.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.4	-3.7	-2.0	0.8	4.4	6.8	9.5	10.0	8.2	5.9	1.6	-2.8
		MCDB	-5.1	-3.6	-1.9	1.0	4.7	7.0	11.2	11.7	9.4	6.2	2.0	-2.7
	2%	WB	-8.3	-6.2	-4.2	-0.4	2.9	5.9	8.2	8.7	7.0	4.2	-0.7	-5.6
		MCDB	-7.9	-6.0	-4.0	-0.2	3.2	6.1	9.6	10.1	7.9	4.5	-0.6	-5.5
	5%	WB	-11.1	-8.8	-6.3	-1.9	1.7	5.1	7.4	8.0	6.2	3.0	-2.3	-7.7
		MCDB	-10.6	-8.5	-5.9	-1.6	2.1	5.5	8.5	9.0	7.0	3.2	-2.0	-7.5
	10%	WB	-13.4	-11.3	-8.6	-4.0	0.1	4.3	6.7	7.2	5.5	1.7	-4.3	-10.2
		MCDB	-12.3	-10.5	-7.8	-2.9	0.6	4.7	7.6	8.2	6.2	2.1	-3.8	-9.2
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.2	6.3	5.8	5.4	5.0	4.9	5.2	5.3	5.1	5.4	5.6
		MCDBR	7.8	8.4	8.8	6.6	6.6	5.9	6.9	7.2	6.9	6.0	6.7	8.0
		MCWBR	8.1	9.0	9.2	7.1	6.8	6.4	6.8	6.9	6.7	6.5	7.5	8.7
	5% WB	MCDBR	8.1	8.5	8.7	6.8	6.1	4.8	5.5	5.7	5.5	5.4	7.1	8.1
		MCWBR	8.8	9.3	9.7	8.3	8.1	6.5	6.1	6.2	6.5	7.4	8.7	9.2
Clear-Sky Solar Irradiance	taub	0.203	0.220	0.243	0.266	0.280	0.297	0.296	0.296	0.271	0.253	0.225	0.205	
	taud	2.696	2.648	2.589	2.544	2.521	2.502	2.545	2.544	2.620	2.633	2.687	2.713	
	Ebn at Noon	1050	1053	1042	1021	1002	979	978	976	995	996	1009	1030	
	Edh at Noon	66	78	91	101	105	107	102	100	88	78	66	61	
All-Sky Solar Radiation	RadAvg	2.83	3.42	4.21	4.82	5.16	4.51	4.80	4.85	3.89	3.18	2.66	2.49	
	RadStd	0.16	0.28	0.27	0.49	0.53	0.39	0.70	0.42	0.35	0.33	0.23	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (46 neighbors)	N/A	N/A	N/A	+1.14	+0.85	+0.97	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page