

YOKOTA AB, Japan

WMO: 476420

Lat: 35.749N

Lon: 139.349E

Elev: 144

StdP: 99.61

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 43313

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.8	-2.5	-14.2	1.1	4.7	-12.5	1.3	3.8	11.0	7.0	10.0	6.6	1.6	280	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	34.0	25.9	32.8	25.4	31.2	24.7	26.6	31.9	26.0	30.8	25.5	29.7	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.7	28.7	24.8	20.2	28.5	24.1	19.3	28.1	84.5	32.4	81.5	31.1	79.0	29.7	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.3	7.2	-6.0	36.6	1.1	1.5	-6.8	37.6	-7.4	38.5	-8.0	39.3	-8.8	40.4		
(5)			-7.5	27.8	0.9	1.0	-8.2	28.4	-8.8	29.0	-9.3	29.6	-10.0	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	3.9	4.6	8.3	13.4	18.4	21.5	25.8	27.0	23.0	17.5	11.4	6.3	(6)
(7)		DBStd	8.41	2.29	2.71	3.27	3.44	2.72	2.74	2.99	2.60	3.11	2.88	2.89	2.62	(7)
(8)		HDD10.0	563	190	153	76	9	0	0	0	0	0	0	18	117	(8)
(9)		HDD18.3	1963	448	384	312	150	32	5	0	0	3	49	208	372	(9)
(10)		CDD10.0	2443	1	2	22	112	261	345	490	526	389	233	59	3	(10)
(11)		CDD18.3	803	0	0	0	3	34	100	232	268	142	24	0	0	(11)
(12)		CDH23.3	6469	0	0	1	31	207	532	2069	2619	913	97	1	0	(12)
(13)		CDH26.7	2283	0	0	0	4	27	126	808	1044	260	15	0	0	(13)
(14)	Wind	WSAvg	2.8	2.8	3.1	3.3	3.3	3.1	2.7	2.6	2.7	2.7	2.5	2.3	2.4	(14)
(15)	Precipitation	PrecAvg	1496	52	48	85	104	135	169	170	179	225	192	82	55	(15)
(16)		PrecMax	2088	125	95	159	259	267	394	326	401	405	619	292	160	(16)
(17)		PrecMin	1047	4	2	29	30	57	71	68	42	37	24	3	10	(17)
(18)		PrecStd	209	36	27	34	56	53	65	78	102	110	134	56	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.0	18.2	22.2	26.2	29.1	32.2	35.7	36.0	33.2	28.7	22.0	17.8	(19)
(20)			MCWB	8.4	12.0	12.9	16.0	19.2	24.0	26.1	26.3	24.9	21.3	14.5	11.1	(20)
(21)		2%	DB	12.2	14.2	19.2	23.9	27.1	29.8	34.0	34.2	31.2	25.9	20.0	15.0	(21)
(22)			MCWB	6.1	7.7	11.6	14.9	18.2	22.3	25.7	26.2	24.2	19.5	13.8	9.0	(22)
(23)		5%	DB	10.8	12.1	16.9	22.0	25.8	28.0	32.8	33.0	29.8	24.0	18.2	13.2	(23)
(24)			MCWB	5.1	6.3	10.5	14.5	17.6	21.4	25.4	25.7	23.7	18.5	12.9	7.8	(24)
(25)		10%	DB	9.2	10.1	14.9	20.0	24.1	26.2	31.0	31.9	27.9	22.2	16.8	11.8	(25)
(26)			MCWB	3.8	4.9	9.4	13.5	17.1	20.7	24.8	25.3	22.5	17.4	12.2	7.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	13.2	14.8	19.2	21.6	25.4	27.4	27.7	26.1	22.6	17.1	12.8	(27)
(28)			MCD B	13.1	17.4	19.1	22.7	25.6	29.2	32.6	32.8	30.3	26.2	19.6	15.3	(28)
(29)		2%	WB	7.4	9.2	13.2	16.9	20.1	24.1	26.5	26.7	25.2	21.1	15.5	10.6	(29)
(30)			MCD B	10.5	13.3	17.4	21.4	24.4	28.2	31.8	32.1	28.9	24.4	17.9	13.1	(30)
(31)		5%	WB	5.8	7.2	11.6	15.7	19.2	22.8	25.9	26.2	24.6	19.8	14.2	9.0	(31)
(32)			MCD B	9.5	10.5	15.6	19.8	23.2	26.4	30.7	31.2	27.9	22.7	16.9	12.0	(32)
(33)		10%	WB	4.5	5.7	10.0	14.4	18.2	21.8	25.3	25.7	23.8	18.6	13.1	7.7	(33)
(34)			MCD B	8.3	9.0	13.9	18.6	22.1	24.8	29.7	30.2	26.9	21.3	15.7	10.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.8	10.6	10.6	10.7	9.7	7.6	7.7	7.9	7.4	7.7	9.3	10.4	(35)
(36)			MCD BR	12.7	13.3	13.7	13.4	12.4	10.3	10.1	9.8	9.5	9.8	11.4	12.2	(36)
(37)			MCWBR	8.0	8.4	8.2	6.8	5.9	4.6	4.0	3.8	4.2	5.1	6.7	7.5	(37)
(38)		5% WB	MCD BR	11.4	11.7	12.4	11.2	10.2	8.3	9.2	8.9	8.4	8.1	9.3	10.3	(38)
(39)			MCWBR	7.7	8.1	8.3	6.7	5.7	4.3	4.1	3.8	4.1	4.7	6.3	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.418	0.484	0.538	0.567	0.610	0.599	0.594	0.522	0.483	0.416	0.372	(40)	
(41)		taud	2.252	2.114	1.957	1.870	1.855	1.818	1.895	1.896	2.052	2.084	2.196	2.279	(41)	
(42)		Ebn at Noon	806	804	781	761	745	711	716	709	740	728	745	777	(42)	
(43)		Edh at Noon	105	136	173	199	205	212	195	192	156	139	111	97	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.78	3.34	4.15	4.81	5.16	4.54	4.82	4.84	3.81	3.08	2.56	2.43	(44)	
(45)		RadStd	0.18	0.30	0.26	0.46	0.54	0.41	0.79	0.46	0.34	0.33	0.24	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page