

OMAEZAKI, Japan

WMO: 476550

Lat: 34.6047N

Lon: 138.2133E

Elev: 47

StdP: 100.76

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.2	1.2	-11.2	1.4	3.8	-9.5	1.7	3.9	13.9	7.2	13.0	7.3	6.1	290	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	30.5	26.2	29.8	25.9	29.1	25.5	27.1	29.2	26.6	28.7	26.1	28.2	5.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.2	28.4	26.0	21.5	28.1	25.5	20.9	27.7	85.9	29.4	83.7	28.8	81.6	28.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.2	10.1	-1.8	32.3	1.2	1.5	-2.6	33.4	-3.3	34.3	-4.0	35.2	-4.9	36.3		
(5)			-4.4	27.6	1.1	0.7	-5.2	28.2	-5.8	28.6	-6.4	29.0	-7.2	29.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	6.8	7.5	10.3	14.7	18.7	21.7	25.4	27.1	24.6	20.0	14.7	9.4	(6)	(7)
	DBStd	7.29	2.40	2.78	2.82	2.62	1.74	1.67	1.97	1.41	2.07	2.31	2.88	2.97	(7)	(8)
	HDD10.0	264	102	80	31	2	0	0	0	0	0	0	2	48	(8)	(9)
	HDD18.3	1438	357	304	248	112	16	1	0	0	0	10	113	278	(9)	(10)
	CDD10.0	2744	4	9	41	142	270	351	478	531	438	311	142	29	(10)	(11)
	CDD18.3	875	0	0	0	2	28	101	219	272	188	62	3	0	(11)	(12)
	CDH23.3	5787	0	0	0	0	13	184	1591	2655	1223	120	1	0	(12)	(13)
	CDH26.7	1143	0	0	0	0	0	6	298	664	171	3	0	0	(13)	(14)
(14) Wind	WSAvg	4.9	6.4	5.9	5.7	5.0	4.3	4.0	3.9	3.8	4.1	4.4	5.0	6.0	(14)	(15)
(15) Precipitation	PrecAvg	2077	78	100	168	198	217	264	211	187	226	208	140	73	(15)	(16)
	PrecMax	2831	221	290	335	378	467	477	639	500	693	979	336	258	(16)	(17)
	PrecMin	1173	0	11	8	34	78	84	17	1	44	23	13	2	(17)	(18)
	PrecStd	373	54	65	66	77	90	96	138	104	140	143	73	51	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	16.8	18.9	21.9	24.7	27.5	31.2	31.9	30.4	27.1	22.5	18.8	(19)	(20)
		MCWB	12.5	14.4	14.1	17.3	19.7	23.8	26.3	26.9	25.6	22.0	18.6	16.2	(20)	(21)
	2%	DB	13.3	15.0	17.4	20.7	23.5	26.1	30.1	30.8	29.3	25.7	21.1	16.6	(21)	(22)
		MCWB	9.8	11.7	13.5	16.8	19.0	22.6	26.0	26.5	25.1	21.3	17.1	13.2	(22)	(23)
	5%	DB	12.2	13.4	16.3	19.8	22.6	25.2	29.2	30.2	28.5	24.6	20.1	15.3	(23)	(24)
		MCWB	8.3	9.7	13.0	16.2	18.7	22.2	25.6	26.2	24.7	20.8	16.5	11.5	(24)	(25)
	10%	DB	11.1	12.2	15.2	18.9	21.8	24.4	28.4	29.6	27.7	23.7	19.1	14.1	(25)	(26)
		MCWB	7.1	8.5	11.9	15.4	18.2	21.7	25.2	25.9	24.2	20.1	15.5	10.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	15.3	16.3	19.8	21.8	24.9	27.4	28.0	26.9	24.2	20.2	17.1	(27)	(28)
		MCDB	14.5	16.2	17.1	20.5	23.0	26.4	29.8	30.0	28.8	25.1	21.2	18.0	(28)	(29)
	2%	WB	10.9	12.6	15.0	18.3	20.7	24.0	26.7	27.4	26.1	23.0	18.5	14.1	(29)	(30)
		MCDB	12.8	14.5	16.5	19.9	22.0	25.2	28.9	29.4	28.0	24.6	20.0	16.0	(30)	(31)
	5%	WB	9.0	10.7	13.9	17.2	19.9	23.1	26.2	27.0	25.6	21.8	17.3	12.3	(31)	(32)
		MCDB	11.2	12.4	15.7	18.7	21.5	24.4	28.2	29.0	27.5	24.1	19.2	14.5	(32)	(33)
	10%	WB	7.7	9.3	12.5	16.2	19.1	22.4	25.7	26.5	25.1	20.6	16.2	11.1	(33)	(34)
		MCDB	10.4	11.5	14.6	18.0	20.9	23.7	27.7	28.6	27.0	23.0	18.5	13.7	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.2	7.2	6.4	5.5	4.5	4.3	4.6	4.8	5.4	6.2	6.7	(35)	(36)
		MCDBR	7.2	7.4	7.5	6.7	6.3	5.2	5.2	5.1	5.2	5.9	6.5	6.9	(36)	(37)
	5% WB	MCWBR	6.0	6.3	6.5	5.3	4.1	2.9	2.4	2.4	2.8	4.1	5.1	5.6	(37)	(38)
		MCWBR	6.2	6.4	6.9	5.6	5.1	4.2	4.8	4.7	4.7	5.3	5.7	6.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.373	0.421	0.478	0.525	0.535	0.553	0.544	0.528	0.487	0.467	0.412	0.373	(39)	(40)
		taud	2.275	2.143	1.995	1.927	1.971	2.000	2.074	2.111	2.196	2.168	2.240	2.292	(40)	(41)
	Ebn at Noon		813	809	792	775	771	755	759	765	777	753	761	787	(41)	(42)
		Edh at Noon	105	134	168	189	183	177	164	155	137	130	109	98	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		2.75	3.34	4.24	4.86	5.26	4.64	5.26	5.41	4.20	3.25	2.65	2.45	(43)	(44)
	RadStd		0.19	0.28	0.27	0.52	0.54	0.47	0.71	0.43	0.36	0.34	0.23	0.17	(44)	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	+0.32	+0.49	N/A	N/A	N/A	N/A	(46)
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page