

SHIZUOKA, Japan

WMO: 476560

Lat: 34.9761N

Lon: 138.4039E

Elev: 52

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.7	33.7	6.4	7.6	42.7	11.1	9.7	43.3	16.0	47.8	14.4	48.1	3.4	300	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	91.4	77.6	89.1	77.4	87.3	76.9	79.9	87.1	79.1	86.0	78.3	84.9	8.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.0	145.7	83.9	77.1	141.4	83.4	76.3	137.5	82.8	43.6	87.5	42.7	86.3	41.9	85.1	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.1	12.2	11.2	DB	27.6	96.9	1.7	1.7	26.3	98.2	25.3	99.2	24.4	100.1	23.1	101.3
			WB	23.1	81.2	1.8	0.8	21.8	81.8	20.7	82.2	19.7	82.7	18.3	83.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	44.3	45.8	51.2	59.3	66.8	72.5	79.6	81.9	76.5	67.5	57.8	48.9
	DBStd	13.55	3.99	4.92	5.20	5.28	3.88	4.05	4.01	3.19	4.42	4.57	4.85	4.91
	HDD50	450	183	135	47	2	0	0	0	0	0	0	2	81
	HDD65	2557	642	538	428	181	24	1	0	0	0	24	219	500
	CDD50	5114	6	18	85	281	520	675	918	990	794	544	237	46
	CDD65	1745	0	0	0	10	80	226	453	525	344	103	4	0
	CDH74	14168	0	1	3	45	259	1008	4190	5692	2595	367	8	0
	CDH80	4355	0	0	0	7	29	206	1332	2081	655	45	0	0
Wind	WSAvg	4.8	4.9	5.1	5.4	5.3	4.9	4.6	4.6	4.8	4.7	4.6	4.4	4.7
Precipitation	PrecAvg	85.7	3.2	4.3	7.1	7.8	8.4	9.9	9.7	7.0	10.7	8.8	5.7	3.1
	PrecMax	116.1	7.4	9.2	12.3	14.9	12.2	18.1	22.2	26.7	23.1	35.4	12.9	7.2
	PrecMin	59.4	0.0	1.1	2.6	1.9	4.2	3.6	1.0	0.6	3.2	0.9	0.5	0.0
	PrecStd	16.3	2.0	2.3	2.4	3.1	2.6	3.2	5.4	4.9	5.0	6.5	3.0	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.0	67.2	71.8	79.1	83.6	90.9	94.3	95.2	91.4	84.7	74.7	67.7
		MCWB	50.6	54.3	55.5	61.4	65.1	75.2	77.4	78.1	76.9	69.2	62.6	57.5
	2%	DB	57.7	61.6	67.0	74.0	79.5	85.2	90.8	91.8	88.0	80.5	71.2	63.2
		MCWB	47.7	52.0	54.4	58.9	64.7	73.7	77.5	78.2	75.9	69.1	61.0	53.0
	5%	DB	54.9	57.8	63.7	71.0	76.7	81.7	88.4	89.6	85.7	77.8	68.9	60.4
		MCWB	45.3	48.4	53.2	59.3	64.9	71.9	77.3	78.2	75.0	67.6	59.4	51.1
	10%	DB	52.6	54.7	61.0	68.5	74.4	79.0	86.4	87.9	83.7	75.7	66.6	57.8
		MCWB	43.5	45.6	52.0	58.6	64.3	70.8	76.8	77.7	74.4	66.3	57.7	49.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.0	59.1	61.3	68.6	72.8	77.7	80.4	81.2	79.7	74.5	67.5	61.7
		MCDB	58.6	63.2	64.4	71.7	77.6	86.7	87.8	89.0	85.5	79.0	70.6	65.0
	2%	WB	50.3	53.8	58.6	64.9	69.9	75.9	79.4	80.3	78.2	72.2	64.1	55.9
		MCDB	55.2	59.5	63.2	69.7	74.4	82.3	86.6	87.7	84.3	77.6	68.3	60.2
	5%	WB	47.1	50.3	56.2	62.6	67.9	74.4	78.6	79.6	77.2	70.1	61.8	52.9
		MCDB	52.5	55.2	61.5	68.1	73.1	79.7	85.6	86.7	83.1	75.7	66.3	57.7
	10%	WB	44.8	47.6	53.6	60.5	66.2	72.6	77.8	78.9	76.1	68.1	59.6	50.6
		MCDB	50.7	52.5	59.0	66.0	71.9	77.4	84.4	85.6	82.0	73.6	64.7	56.0
Mean Daily Temperature Range	5% DB	MDBR	15.6	15.4	15.4	14.8	13.4	11.1	10.7	11.3	11.7	12.9	14.2	15.4
		MCDBR	18.1	18.6	19.9	19.0	17.4	15.0	14.1	13.6	13.7	15.4	16.3	17.2
		MCWBR	11.2	12.1	12.2	10.3	8.6	6.1	5.2	5.4	6.2	7.9	9.9	10.9
	5% WB	MCDBR	15.6	15.8	15.8	14.7	13.7	12.9	12.0	11.9	12.0	12.9	13.7	14.4
		MCWBR	11.6	11.9	12.8	9.8	8.4	6.0	5.0	5.3	6.2	7.6	10.2	10.9
Clear-Sky Solar Irradiance	taub	0.379	0.432	0.496	0.550	0.567	0.590	0.576	0.567	0.513	0.484	0.420	0.377	
	taud	2.236	2.091	1.935	1.856	1.876	1.890	1.975	1.986	2.105	2.104	2.201	2.267	
	Ebn at Noon	254	252	245	239	237	231	233	232	239	232	237	246	
	Edh at Noon	35	44	56	64	64	63	57	56	47	43	36	32	
All-Sky Solar Radiation	RadAvg	883	1073	1340	1534	1652	1451	1589	1622	1285	1025	846	781	
	RadStd	56	87	86	161	169	136	220	132	113	105	72	56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page