

SHIZUOKA, Japan

WMO: 476560

Lat: 34.9761N

Lon: 138.4039E

Elev: 16

StdP: 101.13

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.2	(c) 0.9	(d) -14.2	(e) 1.1	(f) 6.0	(g) -11.6	(h) 1.4	(i) 6.3	(j) 7.2	(k) 8.8	(l) 6.5	(m) 8.9	(n) 1.5	(o) 300	(p) 0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	33.0	25.3	31.7	25.2	30.7	24.9	26.6	30.6	26.2	30.0	25.7	29.4	3.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	20.8	28.8	25.1	20.2	28.6	24.6	19.6	28.2	83.4	30.8	81.4	30.2	79.5	29.5	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.3	5.5	5.0	-2.5	36.1	1.0	0.9	-3.1	36.8	-3.7	37.3	-4.2	37.8	-4.9	38.5		
			-4.9	27.4	1.0	0.4	-5.7	27.7	-6.3	27.9	-6.8	28.2	-7.6	28.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	6.8	7.7	10.7	15.2	19.3	22.5	26.5	27.7	24.7	19.7	14.4	9.4
	DBStd	7.53	2.22	2.73	2.89	2.93	2.16	2.25	2.23	1.77	2.45	2.54	2.69	2.73
	HDD10.0	250	102	75	26	1	0	0	0	0	0	0	1	45
	HDD18.3	1421	357	299	238	101	13	1	0	0	0	13	122	278
	CDD10.0	2841	3	10	47	156	289	375	510	550	441	302	132	26
	CDD18.3	969	0	0	0	6	44	126	252	292	191	57	2	0
	CDH23.3	7871	0	1	2	25	144	560	2328	3162	1442	204	4	0
	CDH26.7	2419	0	0	0	4	16	114	740	1156	364	25	0	0
Wind	WSAvg	2.2	2.2	2.3	2.4	2.4	2.2	2.1	2.1	2.1	2.1	2.1	2.0	2.1
Precipitation	PrecAvg	2177	81	109	180	199	213	252	246	179	271	224	144	78
	PrecMax	2950	187	234	312	379	311	460	563	678	588	899	328	184
	PrecMin	1510	1	28	67	48	107	92	25	14	81	23	13	1
	PrecStd	415	50	59	60	79	65	81	136	125	127	166	75	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.7	19.5	22.1	26.2	28.7	32.7	34.6	35.1	33.0	29.3	23.7	19.8
		MCWB	10.3	12.4	13.1	16.3	18.4	24.0	25.2	25.6	25.0	20.7	17.0	14.1
	2%	DB	14.3	16.4	19.4	23.3	26.4	29.6	32.7	33.2	31.1	26.9	21.8	17.3
		MCWB	8.7	11.1	12.5	15.0	18.2	23.2	25.3	25.7	24.4	20.6	16.1	11.6
	5%	DB	12.7	14.3	17.6	21.7	24.8	27.6	31.3	32.0	29.8	25.5	20.5	15.8
		MCWB	7.4	9.1	11.8	15.2	18.3	22.2	25.2	25.7	23.9	19.8	15.2	10.6
	10%	DB	11.5	12.6	16.1	20.3	23.5	26.1	30.2	31.0	28.7	24.3	19.2	14.3
		MCWB	6.4	7.5	11.1	14.8	17.9	21.6	24.9	25.4	23.6	19.0	14.3	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.8	15.1	16.3	20.3	22.7	25.4	26.9	27.4	26.5	23.6	19.7	16.5
		MCDB	14.8	17.3	18.0	22.1	25.3	30.4	31.0	31.7	29.7	26.1	21.5	18.3
	2%	WB	10.2	12.1	14.8	18.3	21.0	24.4	26.3	26.9	25.7	22.3	17.8	13.3
		MCDB	12.9	15.3	17.3	21.0	23.5	28.0	30.3	31.0	29.0	25.4	20.2	15.7
	5%	WB	8.4	10.2	13.4	17.0	20.0	23.5	25.9	26.5	25.1	21.2	16.5	11.6
		MCDB	11.4	12.9	16.4	20.0	22.8	26.5	29.8	30.4	28.4	24.3	19.0	14.3
	10%	WB	7.1	8.6	12.0	15.9	19.0	22.5	25.4	26.0	24.5	20.1	15.3	10.3
		MCDB	10.4	11.4	15.0	18.9	22.1	25.2	29.1	29.8	27.8	23.1	18.1	13.3
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.6	8.5	8.2	7.4	6.2	5.9	6.3	6.5	7.2	7.9	8.5
		MCDBR	10.0	10.3	11.0	10.5	9.7	8.4	7.8	7.6	7.6	8.5	9.1	9.5
		MCWBR	6.2	6.7	6.8	5.7	4.8	3.4	2.9	3.0	3.5	4.4	5.5	6.1
	5% WB	MCDBR	8.7	8.8	8.8	8.2	7.6	7.2	6.7	6.6	6.7	7.2	7.6	8.0
		MCWBR	6.5	6.6	7.1	5.4	4.7	3.4	2.8	2.9	3.4	4.2	5.7	6.1
Clear-Sky Solar Irradiance	taub	0.379	0.432	0.496	0.550	0.567	0.590	0.576	0.567	0.513	0.484	0.420	0.377	
	taud	2.236	2.091	1.935	1.856	1.876	1.890	1.975	1.986	2.105	2.104	2.201	2.267	
	Ebn at Noon	801	793	773	753	746	727	734	732	752	732	748	777	
	Edh at Noon	109	140	178	202	201	198	181	176	149	137	112	100	
All-Sky Solar Radiation	RadAvg	2.78	3.38	4.22	4.83	5.21	4.58	5.01	5.11	4.05	3.23	2.67	2.46	
	RadStd	0.17	0.27	0.27	0.51	0.53	0.43	0.69	0.42	0.35	0.33	0.23	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+65	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page