

IROZAKI, Japan

WMO: 476660

Lat: 34.6036N

Lon: 138.8428E

Elev: 175

StdP: 14.60

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.2	39.0	18.0	13.7	41.4	21.4	16.1	42.2	30.9	47.3	29.0	46.8	13.5	280	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	85.9	79.8	84.5	78.9	83.1	78.0	80.7	84.3	79.8	83.2	78.9	82.1	8.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.7	154.9	83.2	78.8	150.3	82.4	77.9	145.8	81.6	44.5	84.4	43.5	83.4	42.6	82.3	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.7	24.9	22.4	33.7	88.0	2.0	1.7	32.2	89.3	31.0	90.3	29.9	91.2	28.4	92.5		
			27.7	82.3	2.1	1.0	26.2	83.0	25.0	83.6	23.8	84.2	22.3	84.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	46.7	47.2	51.7	58.8	65.4	70.2	76.8	79.8	75.3	67.7	59.5	51.4
	DBStd	11.93	3.96	4.51	4.93	4.74	3.31	3.13	3.71	2.86	3.97	4.10	4.62	4.66
	HDD50	300	116	103	39	3	0	0	0	0	0	0	1	38
	HDD65	2313	566	500	412	189	34	2	0	0	0	18	171	421
	CDD50	4914	15	23	92	267	479	606	830	925	760	549	286	82
	CDD65	1453	0	0	0	4	48	157	365	460	310	102	7	0
	CDH74	8497	0	0	0	0	11	200	2337	4082	1724	143	0	0
	CDH80	1323	0	0	0	0	0	6	335	790	190	2	0	0
Wind	WSAvg	10.2	11.9	11.2	11.3	10.7	9.5	8.9	8.4	8.8	9.8	10.3	10.3	11.8
Precipitation	PrecAvg	76.8	3.1	4.2	6.2	6.7	7.4	9.3	8.0	6.1	8.5	8.1	5.6	3.1
	PrecMax	97.1	6.9	8.4	10.0	11.5	12.9	15.2	20.8	17.7	15.2	22.5	16.0	6.6
	PrecMin	53.7	0.1	1.1	2.9	1.9	3.3	4.8	0.4	0.1	2.2	1.2	1.0	0.2
	PrecStd	11.8	2.0	2.1	2.0	2.5	2.5	2.8	5.2	3.9	3.6	4.6	3.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	62.0	65.9	71.1	75.5	80.5	86.8	88.1	85.6	79.9	72.0	66.5
		MCWB	56.0	57.9	58.6	64.1	68.9	74.4	79.8	81.2	79.1	72.8	65.1	62.5
	2%	DB	57.3	59.2	63.1	68.8	73.4	77.9	85.0	86.5	83.9	77.3	69.7	62.9
		MCWB	51.4	54.1	57.4	63.0	66.9	72.9	79.1	80.3	77.8	71.1	63.5	57.3
	5%	DB	55.0	56.6	61.4	67.2	71.9	76.2	83.5	85.3	82.3	75.5	68.2	60.4
		MCWB	48.6	51.0	56.3	61.5	65.8	72.0	78.3	79.5	76.7	69.9	62.4	53.9
	10%	DB	52.9	54.3	59.6	65.5	70.5	74.8	81.8	84.0	80.6	73.8	66.6	58.3
		MCWB	46.0	48.1	54.5	59.8	65.0	71.0	77.3	78.7	75.9	68.1	60.7	51.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.8	59.5	61.5	67.8	71.2	76.3	81.2	82.4	80.5	75.4	68.1	64.2
		MCDB	59.4	61.1	62.9	68.7	73.6	78.6	85.0	86.6	83.8	77.4	69.8	65.7
	2%	WB	53.3	55.8	59.6	65.0	69.1	74.6	80.0	81.2	79.0	73.1	65.8	58.6
		MCDB	56.3	58.4	62.0	67.7	71.5	76.5	83.6	84.9	82.2	76.1	68.3	62.0
	5%	WB	49.3	52.1	57.7	63.0	67.8	73.1	79.1	80.3	77.8	71.1	63.6	55.2
		MCDB	53.9	55.7	60.7	65.8	70.2	75.2	82.2	83.7	81.0	74.7	67.1	59.4
	10%	WB	46.6	48.9	55.2	61.2	66.4	71.8	78.1	79.5	76.8	69.0	61.5	52.4
		MCDB	52.1	53.6	59.0	64.5	69.3	74.1	81.0	82.8	80.0	73.1	65.8	57.4
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.2	9.6	9.0	8.1	6.9	6.8	7.2	7.1	7.1	7.8	8.1
		MCDBR	9.9	10.8	10.6	10.0	9.3	8.1	8.2	8.3	8.3	8.4	9.0	9.8
		MCWBR	9.5	10.4	9.9	8.0	7.1	5.3	4.8	4.9	5.5	7.2	8.7	9.5
	5% WB	MCDBR	9.7	10.2	10.1	8.7	8.2	6.8	7.6	8.0	8.0	7.8	8.8	9.6
		MCWBR	10.9	11.5	11.1	8.4	7.2	5.0	4.7	5.0	5.7	7.6	9.8	10.6
Clear-Sky Solar Irradiance	taub	0.379	0.428	0.484	0.530	0.542	0.559	0.551	0.536	0.493	0.477	0.421	0.379	
	taud	2.262	2.126	1.984	1.918	1.958	1.990	2.060	2.093	2.185	2.137	2.212	2.276	
	Ebn at Noon	256	254	249	245	243	238	239	240	245	236	238	247	
	Edh at Noon	34	43	54	60	59	57	53	50	44	43	36	32	
All-Sky Solar Radiation	RadAvg	853	1033	1312	1517	1649	1447	1664	1700	1322	1005	818	764	
	RadStd	63	101	85	166	171	148	240	132	113	103	71	59	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page