

AJIRO, Japan

WMO: 476680

Lat: 35.0464N

Lon: 139.0919E

Elev: 225

StdP: 14.58

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.1	36.7	11.0	9.7	41.8	16.5	12.7	41.6	33.7	46.8	30.2	47.5	8.5	250	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	90.2	78.1	88.0	77.6	85.6	76.7	79.7	86.6	78.7	85.2	77.7	83.9	8.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.9	146.0	83.4	76.8	140.7	82.7	75.8	135.8	82.0	43.5	87.0	42.4	85.5	41.4	83.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.3	19.8	31.5	93.8	1.9	1.5	30.2	94.9	29.1	95.8	28.0	96.6	26.7	97.7
			25.1	81.6	2.1	1.0	23.6	82.3	22.4	82.9	21.3	83.5	19.8	84.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	44.7	45.3	50.6	58.5	66.0	70.9	78.3	80.6	74.7	66.2	57.4	49.4
	DBStd	13.08	3.90	4.83	5.71	5.70	4.60	4.48	4.88	4.19	4.81	4.55	4.68	4.64
	HDD50	458	171	147	64	6	0	0	0	0	0	0	2	68
	HDD65	2631	628	550	447	205	43	5	0	0	1	38	231	483
	CDD50	4833	8	17	82	261	497	628	877	947	740	503	223	50
	CDD65	1530	0	0	0	9	75	183	412	482	291	76	2	0
	CDH74	10572	0	0	0	19	162	655	3405	4567	1612	152	0	0
	CDH80	2756	0	0	0	1	11	98	957	1375	300	14	0	0
(14) Wind	WSAvg	6.3	7.7	7.1	7.5	6.7	5.8	5.2	5.4	5.3	5.5	6.2	6.2	7.4
(15) Precipitation	PrecAvg	75.6	3.0	3.5	5.7	6.2	6.8	8.8	8.5	7.1	10.2	8.0	4.9	2.8
	PrecMax	102.6	6.7	7.4	11.1	12.7	13.5	14.9	19.2	20.0	19.3	29.6	11.3	6.7
	PrecMin	50.8	0.0	0.6	1.7	2.7	2.6	4.5	0.4	0.3	2.5	0.8	0.5	0.2
	PrecStd	13.0	1.8	1.8	2.3	2.5	2.8	2.6	4.7	4.8	4.9	5.7	2.8	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.2	66.2	69.8	76.7	81.4	86.8	92.1	93.6	89.5	81.9	71.7	66.0
		MCWB	52.3	56.0	55.9	61.2	67.6	75.3	78.7	78.8	76.9	70.5	62.7	58.6
	2%	DB	56.4	60.6	65.7	72.4	78.0	82.6	89.7	90.9	85.9	77.9	68.5	62.0
		MCWB	47.9	52.8	55.6	60.5	65.8	72.4	78.1	78.4	76.0	69.6	61.2	54.0
	5%	DB	53.2	55.9	62.8	69.7	75.4	80.0	87.5	88.8	83.3	75.2	66.3	58.8
		MCWB	45.8	48.1	53.7	59.3	64.9	71.5	77.4	78.0	75.1	67.7	59.5	51.1
	10%	DB	51.0	52.7	59.7	66.9	73.2	77.7	85.0	86.4	81.1	72.7	64.2	56.3
		MCWB	43.6	45.3	51.8	58.1	63.9	70.5	76.5	77.4	74.1	66.0	57.8	49.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	58.3	61.1	67.9	72.1	76.6	80.8	81.5	79.1	73.7	65.8	61.4
		MCDB	59.0	63.9	65.2	71.5	77.1	83.7	88.8	88.8	85.1	78.6	69.1	65.1
	2%	WB	50.4	53.8	58.0	63.7	69.4	74.7	79.3	80.1	77.5	71.1	63.1	55.7
		MCDB	54.2	59.4	63.0	69.1	74.8	80.5	86.7	86.8	82.9	76.3	66.8	59.8
	5%	WB	47.0	49.4	55.5	61.3	67.4	73.3	78.2	79.1	76.4	69.0	61.1	52.7
		MCDB	52.0	54.4	61.1	67.2	73.0	78.7	85.3	85.5	81.4	73.9	64.8	57.0
	10%	WB	44.5	46.4	52.8	59.3	65.5	71.4	77.1	78.2	75.2	67.0	59.0	50.4
		MCDB	50.2	51.6	58.5	64.8	71.1	76.5	83.8	84.3	80.1	71.6	63.2	55.3
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	10.8	11.7	12.1	11.2	9.5	9.7	9.7	8.9	8.5	8.9	9.6
		MCDBR	13.1	15.3	15.3	15.7	14.8	12.8	12.5	12.5	11.6	11.4	11.0	12.0
		MCWBR	9.3	11.2	10.7	9.0	9.0	6.9	6.3	5.9	6.4	7.5	8.5	9.0
	5% WB	MCDBR	11.6	13.5	13.5	13.0	12.7	11.3	11.5	10.9	10.3	10.2	10.2	10.9
		MCWBR	9.7	11.4	11.5	9.1	9.1	6.7	6.3	5.9	6.4	7.6	8.8	9.8
(40) Clear-Sky Solar Irradiance	taub		0.380	0.430	0.491	0.541	0.561	0.585	0.576	0.565	0.510	0.485	0.423	0.378
	taud		2.249	2.109	1.959	1.881	1.895	1.907	1.980	1.996	2.115	2.100	2.193	2.270
	Ebn at Noon		254	252	247	241	238	232	233	233	239	232	236	246
	Edh at Noon		34	44	55	62	62	62	57	55	47	44	36	32
(44) All-Sky Solar Radiation	RadAvg		872	1046	1309	1518	1639	1432	1599	1618	1268	991	816	771
	RadStd		61	101	85	159	171	137	246	136	112	104	73	60

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+2.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page