

AJIRO, Japan

WMO: 476680

Lat: 35.0464N

Lon: 139.0919E

Elev: 69

StdP: 100.50

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	2.6	-11.7	1.4	5.5	-8.6	1.8	5.3	15.1	8.2	13.5	8.6	3.8	250	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	32.3	25.6	31.1	25.3	29.8	24.9	26.5	30.3	25.9	29.5	25.4	28.8	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.9	28.6	24.9	20.1	28.2	24.3	19.4	27.8	83.3	30.6	80.7	29.7	78.3	28.8	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.4	8.9	DB	-0.3	34.4	1.0	0.8	-1.0	35.0	-1.6	35.4	-2.2	35.9	-3.0	36.5	(4)
(5)			WB	-3.8	27.6	1.1	0.6	-4.6	28.0	-5.3	28.3	-6.0	28.6	-6.8	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	7.1	7.4	10.3	14.7	18.9	21.6	25.7	27.0	23.7	19.0	14.1	9.7	(6)	
	DBStd	7.27	2.17	2.68	3.17	3.17	2.55	2.49	2.71	2.33	2.67	2.53	2.60	2.58	(7)	
	HDD10.0	254	95	82	36	3	0	0	0	0	0	0	1	38	(8)	
	HDD18.3	1462	349	306	248	114	24	3	0	0	1	21	128	268	(9)	
	CDD10.0	2685	4	9	46	145	276	349	487	526	411	279	124	28	(10)	
	CDD18.3	850	0	0	0	5	42	102	229	268	162	42	1	0	(11)	
	CDH23.3	5873	0	0	0	11	90	364	1892	2537	896	84	0	0	(12)	
(13) Wind	CDH26.7	1531	0	0	0	1	6	54	532	764	167	8	0	0	(13)	
	WSAvg	2.8	3.4	3.2	3.4	3.0	2.6	2.3	2.4	2.4	2.4	2.8	2.8	3.3	(14)	
	PrecAvg	1919	77	90	146	157	173	223	215	180	259	203	124	70	(15)	
	PrecMax	2606	169	188	281	323	342	378	488	507	491	751	286	170	(16)	
	PrecMin	1290	0	15	43	69	65	115	11	7	63	20	12	5	(17)	
	PrecStd	331	46	46	59	64	70	65	120	123	124	144	71	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	19.0	21.0	24.8	27.4	30.5	33.4	34.2	32.0	27.7	22.1	18.9	(19)	
		MCWB	11.3	13.3	13.3	16.2	19.8	24.0	25.9	26.0	24.9	21.4	17.1	14.8	(20)	
	2%	DB	13.5	15.9	18.7	22.5	25.5	28.1	32.1	32.7	29.9	25.5	20.3	16.6	(21)	
		MCWB	8.8	11.6	13.1	15.8	18.8	22.5	25.6	25.8	24.4	20.9	16.2	12.2	(22)	
	5%	DB	11.8	13.3	17.1	20.9	24.1	26.6	30.8	31.5	28.5	24.0	19.1	14.9	(23)	
		MCWB	7.7	9.0	12.0	15.1	18.3	21.9	25.2	25.5	23.9	19.9	15.3	10.6	(24)	
	10%	DB	10.6	11.5	15.4	19.4	22.9	25.4	29.5	30.2	27.3	22.6	17.9	13.5	(25)	
		MCWB	6.5	7.4	11.0	14.5	17.7	21.4	24.7	25.2	23.4	18.9	14.3	9.6	(26)	
	0.4%	WB	12.6	14.6	16.2	20.0	22.3	24.8	27.1	27.5	26.2	23.2	18.8	16.3	(27)	
		MCDB	15.0	17.7	18.5	22.0	25.0	28.7	31.6	31.6	29.5	25.9	20.6	18.4	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	10.2	12.1	14.4	17.6	20.8	23.7	26.3	26.7	25.3	21.7	17.3	13.1	(29)	
		MCDB	12.4	15.2	17.2	20.6	23.8	26.9	30.4	30.5	28.3	24.6	19.3	15.4	(30)	
	5%	WB	8.3	9.7	13.1	16.3	19.7	22.9	25.7	26.2	24.6	20.6	16.2	11.5	(31)	
		MCDB	11.1	12.4	16.2	19.5	22.8	25.9	29.6	29.7	27.4	23.3	18.2	13.9	(32)	
	10%	WB	7.0	8.0	11.5	15.2	18.6	21.9	25.1	25.7	24.0	19.5	15.0	10.2	(33)	
		MCDB	10.1	10.9	14.7	18.2	21.7	24.7	28.8	29.1	26.7	22.0	17.3	13.0	(34)	
	5% DB	MDBR	5.7	6.0	6.5	6.7	6.2	5.3	5.4	5.4	5.0	4.7	5.0	5.3	(35)	
		MCDBR	7.3	8.5	8.5	8.7	8.2	7.1	6.9	6.9	6.4	6.4	6.1	6.7	(36)	
		MCWBR	5.2	6.2	5.9	5.0	5.0	3.8	3.5	3.3	3.6	4.2	4.7	5.0	(37)	
		MCWBR	6.4	7.5	7.5	7.2	7.1	6.3	6.4	6.0	5.7	5.7	5.7	6.1	(38)	
(39) Mean Daily Temperature Range	5% WB	MCWBR	5.4	6.3	6.4	5.0	5.0	3.7	3.5	3.3	3.6	4.2	4.9	5.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.380	0.430	0.491	0.541	0.561	0.585	0.576	0.565	0.510	0.485	0.423	0.378	(40)	
	taud		2.249	2.109	1.959	1.881	1.895	1.907	1.980	1.996	2.115	2.100	2.193	2.270	(41)	
	Ebn at Noon		800	796	778	760	751	731	734	733	754	731	743	775	(42)	
	Edh at Noon		107	138	174	197	197	195	180	174	148	138	113	100	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.75	3.30	4.13	4.79	5.17	4.51	5.04	5.10	4.00	3.12	2.57	2.43	(44)	
	RadStd		0.19	0.32	0.27	0.50	0.54	0.43	0.78	0.43	0.35	0.33	0.23	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+1.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page