

MIYAKEJIMA, Japan

WMO: 476770

Lat: 34.1239N

Lon: 139.5214E

Elev: 131

StdP: 14.63

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.4	41.6	24.2	18.4	44.1	26.6	20.7	44.8	41.6	46.2	37.1	48.0	11.6	170	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	86.1	79.2	85.1	78.8	84.0	78.4	80.6	84.2	79.8	83.4	79.0	82.7	11.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.6	83.0	78.7	149.7	82.5	77.9	145.7	81.9	44.4	84.2	43.5	83.7	42.7	82.9	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.2	30.5	27.0	DB	34.9	88.1	2.1	0.7	33.4	88.6	32.2	89.0	31.0	89.4	29.5	89.9	(4)
			WB	31.5	81.6	1.8	1.0	30.1	82.3	29.1	82.9	28.0	83.5	26.7	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	49.0	49.4	53.6	60.1	66.5	71.2	78.0	80.1	76.1	69.4	61.9	53.8	(6)
		DBStd	11.39	4.23	4.82	5.07	4.84	3.40	3.62	3.41	2.60	3.64	3.69	4.34	4.88	(7)
		HDD50	174	70	63	21	1	0	0	0	0	0	0	19		(8)
		HDD65	1931	495	437	353	156	23	1	0	0	0	111	349		(9)
		CDD50	5349	40	46	133	305	511	636	868	934	782	602	357	135	(10)
		CDD65	1630	0	0	0	9	69	187	403	469	332	142	18	1	(11)
		CDH74	10719	0	0	0	1	53	506	3222	4535	2138	262	2	0	(12)
		CDH80	1957	0	0	0	0	22	558	1077	295	5	0	0		(13)
(14)	Wind	WSAvg	12.7	15.2	14.6	14.1	12.6	11.1	10.6	10.9	9.8	11.5	13.7	13.0	15.2	(14)
(15)	Precipitation	PrecAvg	114.2	5.8	6.6	10.1	9.0	9.6	12.9	8.1	8.5	13.1	14.4	9.3	6.2	(15)
(16)		PrecMax	150.5	13.8	11.7	19.5	19.3	18.0	29.4	18.9	22.1	23.7	38.2	20.5	13.2	(16)
(17)		PrecMin	75.2	0.7	2.0	3.7	2.9	4.9	3.4	0.4	0.4	2.7	3.5	2.3	0.7	(17)
(18)		PrecStd	19.6	2.8	2.6	4.0	3.3	2.9	5.4	5.6	6.2	5.5	7.5	4.1	2.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	63.7	65.4	68.2	72.9	77.6	82.6	86.9	87.8	86.1	80.6	73.7	69.7		(19)
(20)		MCWB	59.8	60.8	61.3	66.6	71.4	77.0	79.1	79.8	78.7	74.8	68.1	65.5		(20)
(21)		DB	60.2	62.5	66.0	70.9	75.5	80.0	85.5	86.6	84.6	78.7	71.8	65.9		(21)
(22)		MCWB	55.1	57.9	60.6	64.9	69.4	75.4	78.7	79.5	78.2	73.9	65.9	60.8		(22)
(23)		DB	57.5	59.6	64.1	69.2	73.8	78.3	84.4	85.6	83.1	77.0	70.3	63.4		(23)
(24)		MCWB	51.7	54.5	59.0	63.2	67.7	74.4	78.3	79.1	77.6	72.2	64.2	57.7		(24)
(25)		DB	55.6	57.1	62.1	67.5	72.3	76.9	83.2	84.7	81.7	75.2	68.9	61.2		(25)
(26)		MCWB	49.7	51.7	56.7	61.6	66.7	73.3	77.8	78.8	76.9	70.3	62.9	55.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	60.8	62.4	64.7	69.5	74.1	78.0	81.0	82.1	80.8	77.3	70.2	66.7		(27)
(28)		MCDB	62.9	64.8	66.0	71.7	76.4	80.9	84.5	85.4	83.6	79.5	72.6	69.0		(28)
(29)		WB	55.9	59.1	61.9	66.8	71.9	76.5	79.9	81.0	79.5	74.9	67.6	62.3		(29)
(30)		MCDB	59.1	62.2	64.5	69.4	73.9	79.2	83.5	84.5	82.6	77.6	70.4	64.9		(30)
(31)		WB	52.9	55.6	59.6	64.5	69.9	75.4	79.1	80.3	78.5	73.3	65.7	58.9		(31)
(32)		MCDB	56.4	59.1	63.3	67.9	72.5	77.8	82.7	83.9	81.9	76.3	68.7	62.3		(32)
(33)		WB	50.6	52.8	57.3	62.6	68.1	74.1	78.3	79.6	77.6	71.6	63.9	56.4		(33)
(34)		MCDB	54.7	56.6	61.5	66.3	71.3	76.5	81.9	83.3	81.0	74.6	67.6	60.4		(34)
(35)	Mean Daily Temperature Range	MDBR	7.6	8.4	9.1	9.4	9.1	7.5	7.3	7.5	7.0	6.9	7.8	7.6		(35)
(36)		5% DB	9.8	11.3	11.5	10.8	10.8	8.2	8.5	8.4	8.8	9.0	9.3	10.2		(36)
(37)		MCWBR	9.7	11.6	10.6	8.7	7.4	5.4	4.7	4.5	5.3	7.0	8.2	9.4		(37)
(38)		5% WB	9.2	11.0	10.6	9.5	9.0	7.6	7.9	7.6	8.1	7.8	8.3	9.2		(38)
(39)		MCWBR	10.1	12.1	11.5	9.4	8.2	5.7	4.9	4.5	5.5	7.3	8.6	9.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.393	0.442	0.497	0.533	0.537	0.545	0.538	0.517	0.483	0.479	0.433	0.396		(40)
(41)		taud	2.225	2.090	1.958	1.917	1.979	2.045	2.105	2.168	2.232	2.144	2.189	2.220		(41)
(42)		Ebn at Noon	251	250	246	244	245	242	242	246	248	236	235	241		(42)
(43)		Edh at Noon	36	45	56	61	58	54	50	47	42	42	37	34		(43)
(44)	All-Sky Solar Radiation	RadAvg	775	951	1237	1475	1627	1430	1730	1757	1355	976	774	711		(44)
(45)		RadStd	69	111	88	155	172	151	250	125	109	99	60	62		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	+1.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page