

MIYAKEJIMA, Japan

WMO: 476770

Lat: 34.1239N

Lon: 139.5214E

Elev: 40

StdP: 100.85

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	5.3	-4.3	2.6	6.7	-3.0	3.0	7.1	18.6	7.9	16.6	8.9	5.2	170	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	30.1	26.2	29.5	26.0	28.9	25.8	27.0	29.0	26.6	28.6	26.1	28.2	5.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.1	28.4	25.9	21.4	28.0	25.5	20.8	27.7	85.5	29.0	83.3	28.7	81.5	28.3	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	13.7	12.1	1.6	31.2	1.2	0.4	0.8	31.4	0.1	31.7	-0.6	31.9	-1.4	32.2
			-0.3	27.5	1.0	0.6	-1.0	27.9	-1.6	28.3	-2.2	28.6	-2.9	29.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	9.5	9.7	12.0	15.6	19.1	21.8	25.6	26.7	24.5	20.8	16.6	12.1
	DBStd	6.33	2.35	2.68	2.81	2.69	1.89	2.01	1.89	1.45	2.02	2.05	2.41	2.71
	HDD10.0	97	39	35	12	1	0	0	0	0	0	0	0	11
	HDD18.3	1073	275	243	196	87	13	1	0	0	3	62	194	
	CDD10.0	2972	22	26	74	169	284	353	482	519	434	334	198	75
	CDD18.3	906	0	0	0	5	38	104	224	261	184	79	10	1
	CDH23.3	5955	0	0	0	1	29	281	1790	2519	1188	146	1	0
	CDH26.7	1087	0	0	0	0	0	12	310	598	164	3	0	0
Wind	WSAvg	5.7	6.8	6.5	6.3	5.6	5.0	4.7	4.9	4.4	5.1	6.1	5.8	6.8
Precipitation	PrecAvg	2900	148	167	256	229	243	328	207	215	333	365	237	158
	PrecMax	3822	351	297	496	491	457	748	480	561	601	971	520	336
	PrecMin	1910	19	51	95	73	125	87	11	11	68	88	59	19
	PrecStd	497	72	67	101	85	73	136	142	157	140	190	105	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	18.6	20.1	22.7	25.3	28.1	30.5	31.0	30.0	27.0	23.2	21.0
		MCWB	15.4	16.0	16.3	19.2	21.9	25.0	26.1	26.6	26.0	23.8	20.1	18.6
	2%	DB	15.7	16.9	18.9	21.6	24.1	26.7	29.7	30.3	29.2	25.9	22.1	18.8
		MCWB	12.9	14.4	15.9	18.3	20.8	24.1	26.0	26.4	25.7	23.3	18.8	16.0
	5%	DB	14.1	15.3	17.8	20.7	23.2	25.7	29.1	29.8	28.4	25.0	21.3	17.4
		MCWB	11.0	12.5	15.0	17.4	19.8	23.5	25.7	26.2	25.3	22.3	17.9	14.3
	10%	DB	13.1	13.9	16.7	19.7	22.4	25.0	28.4	29.3	27.6	24.0	20.5	16.2
		MCWB	9.8	10.9	13.7	16.4	19.3	22.9	25.5	26.0	24.9	21.3	17.1	13.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.9	18.1	20.9	23.4	25.6	27.2	27.9	27.1	25.2	21.2	19.3
		MCDB	17.2	18.2	18.9	22.1	24.7	27.1	29.2	29.7	28.7	26.4	22.5	20.5
	2%	WB	13.3	15.0	16.6	19.3	22.2	24.7	26.6	27.2	26.4	23.8	19.8	16.8
		MCDB	15.0	16.8	18.0	20.8	23.3	26.2	28.6	29.2	28.1	25.3	21.3	18.3
	5%	WB	11.6	13.1	15.3	18.1	21.1	24.1	26.2	26.8	25.9	23.0	18.7	14.9
		MCDB	13.6	15.0	17.4	19.9	22.5	25.5	28.2	28.8	27.7	24.6	20.4	16.9
	10%	WB	10.3	11.6	14.0	17.0	20.1	23.4	25.7	26.4	25.3	22.0	17.7	13.5
		MCDB	12.6	13.7	16.4	19.1	21.8	24.7	27.7	28.5	27.2	23.7	19.8	15.8
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.7	5.1	5.2	5.0	4.2	4.0	4.1	3.9	3.8	4.3	4.2
		MCDBR	5.4	6.3	6.4	6.0	6.0	4.6	4.7	4.7	4.9	5.0	5.2	5.7
		MCWBR	5.4	6.5	5.9	4.8	4.1	3.0	2.6	2.5	3.0	3.9	4.5	5.2
	5% WB	MCDBR	5.1	6.1	5.9	5.3	5.0	4.2	4.4	4.2	4.5	4.3	4.6	5.1
		MCWBR	5.6	6.7	6.4	5.2	4.6	3.2	2.7	2.5	3.0	4.1	4.8	5.5
Clear-Sky Solar Irradiance	taub	0.393	0.442	0.497	0.533	0.537	0.545	0.538	0.517	0.483	0.479	0.433	0.396	
	taud	2.225	2.090	1.958	1.917	1.979	2.045	2.105	2.168	2.232	2.144	2.189	2.220	
	Ebn at Noon	792	788	776	769	771	762	764	774	783	744	741	761	
	Edh at Noon	112	142	175	191	182	170	159	147	132	133	116	107	
All-Sky Solar Radiation	RadAvg	2.44	3.00	3.90	4.65	5.13	4.51	5.46	5.54	4.27	3.08	2.44	2.24	
	RadStd	0.22	0.35	0.28	0.49	0.54	0.48	0.79	0.40	0.34	0.31	0.19	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page