

HAMAMATSU AB, Japan

WMO: 476810

Lat: 34.750N

Lon: 137.703E

Elev: 49

StdP: 100.74

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	0.1	-11.8	1.4	3.4	-10.1	1.6	4.0	10.5	5.8	10.0	6.8	4.1	280	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	33.1	25.8	31.9	25.4	30.8	25.3	26.7	30.3	26.2	29.6	25.9	29.1	5.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.5	28.8	25.2	20.4	28.1	25.0	20.2	27.9	84.2	31.0	82.3	29.7	80.3	29.7	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.8	8.0	DB	-2.7	36.0	0.9	1.4	-3.4	36.9	-4.0	37.7	-4.5	38.5	-5.2	39.5	(4)
			WB	-4.8	27.8	1.0	0.5	-5.6	28.1	-6.1	28.4	-6.7	28.7	-7.4	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	5.9	6.7	9.8	14.6	19.0	22.4	26.3	27.7	24.6	19.4	13.7	8.3	(6)
(7)		DBStd	7.87	2.32	2.76	2.95	2.97	2.07	2.16	2.23	1.73	2.44	2.57	2.91	2.91	(7)
(8)		HDD10.0	343	129	99	40	3	0	0	0	0	0	3	68		(8)
(9)		HDD18.3	1574	386	327	264	114	16	1	0	0	17	139	309		(9)
(10)		CDD10.0	2749	2	6	34	142	281	371	506	547	437	292	116	17	(10)
(11)		CDD18.3	939	0	0	0	4	38	121	248	289	187	52	1	0	(11)
(12)		CDH23.3	7303	0	0	0	12	132	531	2173	2968	1317	169	2	0	(12)
(13)		CDH26.7	2189	0	0	0	1	10	94	696	1048	323	17	0	0	(13)
(14)	Wind	WSAvg	3.7	4.5	4.4	4.3	4.0	3.5	3.2	3.2	3.1	3.0	3.4	4.1	(14)	
(15)	Precipitation	PrecAvg	1864	66	89	145	176	196	221	199	140	256	187	124	66	(15)
(16)		PrecMax	2542	159	226	246	343	306	366	424	413	646	689	235	143	(16)
(17)		PrecMin	1314	1	23	62	29	85	52	23	23	77	28	15	5	(17)
(18)		PrecStd	333	40	50	44	75	66	69	106	83	131	120	61	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.0	17.9	20.8	25.0	28.0	31.9	35.0	36.0	32.9	28.8	23.1	18.8	(19)
MCWB			10.6	12.2	13.4	16.7	19.5	24.3	26.2	26.2	24.6	21.6	17.3	14.5	(20)	
2%		DB	13.0	15.1	18.2	23.0	26.1	29.1	32.9	33.8	31.0	26.8	21.2	16.2	(21)	
		MCWB	8.2	10.3	12.0	15.8	18.3	22.7	25.8	26.0	24.5	20.6	15.8	11.8	(22)	
5%		DB	11.8	13.2	17.0	21.1	24.9	27.2	31.2	32.1	29.9	25.1	20.0	14.9	(23)	
		MCWB	7.2	8.3	11.8	15.1	18.0	22.0	25.6	25.6	24.2	19.8	15.3	10.3	(24)	
10%		DB	10.2	11.9	15.2	20.0	23.2	26.1	30.1	31.0	28.8	23.9	18.9	13.2	(25)	
		MCWB	5.8	7.3	10.5	14.7	17.5	21.5	25.2	25.6	23.8	18.9	14.5	9.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	14.9	16.1	20.0	22.5	25.9	27.2	27.7	26.5	23.7	19.6	16.1	(27)
MCD B			13.7	16.5	17.6	21.4	24.8	29.6	31.4	32.0	29.4	25.5	20.9	17.6	(28)	
2%		WB	9.6	11.7	14.5	18.4	20.9	24.7	26.6	27.0	25.9	22.4	17.6	13.0	(29)	
		MCD B	11.4	14.5	16.8	20.7	23.2	27.3	30.4	30.7	28.7	25.0	19.8	15.3	(30)	
5%		WB	7.7	9.9	13.1	17.0	19.9	23.8	26.1	26.5	25.4	21.1	16.3	11.2	(31)	
		MCD B	10.2	11.9	15.7	19.5	22.7	25.9	29.7	30.0	28.2	24.0	18.8	13.7	(32)	
10%		WB	6.4	8.2	11.6	15.8	18.9	22.8	25.7	26.1	24.7	19.9	15.2	9.9	(33)	
		MCD B	9.6	10.7	14.7	18.8	22.1	25.0	29.0	29.4	27.4	22.8	17.9	12.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	8.6	9.1	8.8	8.1	6.5	6.3	6.7	6.8	7.4	8.0	7.9	(35)
MCD BR			9.2	9.9	10.6	10.2	10.1	8.2	8.2	8.2	7.8	8.4	9.1	9.1	(36)	
MCWBR			6.5	7.1	7.3	6.2	5.5	4.1	3.4	3.3	3.8	4.8	5.8	6.3	(37)	
5% WB		MCD BR	8.1	8.9	8.8	8.0	7.7	6.2	7.0	6.9	6.6	7.0	7.5	7.9	(38)	
		MCWBR	6.9	7.7	7.8	6.2	5.3	3.8	3.3	3.2	3.7	4.8	6.2	6.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.375	0.419	0.478	0.525	0.534	0.556	0.548	0.527	0.486	0.460	0.409	0.375	(40)	
taud		2.262	2.140	1.988	1.921	1.968	1.984	2.060	2.106	2.194	2.184	2.244	2.278	(41)		
Ebn at Noon		809	809	790	775	772	753	756	764	777	759	764	782	(42)		
Edh at Noon		106	134	169	190	183	180	166	156	137	127	108	99	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.71	3.34	4.25	4.90	5.30	4.70	5.23	5.36	4.18	3.28	2.67	2.41	(44)	
(45)		RadStd	0.18	0.24	0.28	0.50	0.56	0.45	0.69	0.46	0.37	0.34	0.23	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page