

YOKOSUKA, Japan

WMO: 476960

Lat: 35.2833N

Lon: 139.6667E

Elev: 174

StdP: 14.60

Time Zone: 9.00 (E09)

Period: 94-05

WBAN: 43323

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	37.2	10.2	9.3	41.4	14.0	11.3	41.8	34.5	45.3	30.0	44.1	10.4	330	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	93.5	78.6	89.8	77.2	86.4	76.6	79.9	88.3	78.8	86.3	78.0	84.6	7.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.8	145.2	83.7	76.9	140.9	83.3	75.8	135.8	82.3	43.7	87.6	42.5	88.2	41.5	85.0	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.6	25.0	22.3	31.4	96.0	2.2	5.9	29.8	100.2	28.6	103.7	27.3	107.0	25.8	111.3
			25.1	83.0	2.2	2.3	23.5	84.7	22.2	86.1	20.9	87.4	19.3	89.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	45.0	45.1	49.9	59.2	66.7	71.8	79.5	81.9	76.2	67.3	58.8	50.3	(6)
(7)		DBStd	13.50	3.82	4.31	5.19	5.57	4.57	4.53	4.83	4.83	5.01	5.01	4.57	4.30	(7)
(8)		HDD50	427	162	147	65	5	0	0	0	0	0	0	0	48	(8)
(9)		HDD65	2547	619	557	467	186	35	5	0	0	0	30	192	456	(9)
(10)		CDD50	5082	8	11	63	280	518	654	915	990	786	537	264	56	(10)
(11)		CDD65	1727	0	0	0	10	89	209	450	525	336	102	6	0	(11)
(12)		CDH74	12824	0	0	0	11	182	744	3931	5381	2276	293	6	0	(12)
(13)		CDH80	3781	0	0	0	0	16	102	1232	1896	513	22	0	0	(13)
(14)	Wind	WSAvg	9.7	10.2	9.5	10.4	9.2	8.7	8.4	8.8	9.1	10.2	11.1	10.6	10.0	(14)
(15)	Precipitation	PrecAvg	62.1	2.1	2.7	4.6	5.6	6.0	7.8	5.6	5.4	7.1	6.9	4.3	2.0	(15)
(16)		PrecMax	81.7	6.2	6.5	8.5	9.4	15.1	19.4	18.2	12.9	17.2	19.4	11.3	9.4	(16)
(17)		PrecMin	39.4	0.1	0.2	0.6	1.1	1.7	1.5	0.8	0.4	1.3	0.7	0.6	0.0	(17)
(18)		PrecStd	10.9	1.4	1.9	1.9	1.9	3.0	4.0	3.3	3.5	3.7	4.1	2.8	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.2	63.0	67.7	75.3	82.2	85.9	96.4	98.9	91.6	82.7	74.9	66.5	(19)
(20)			MCWB	53.8	49.0	56.5	61.8	66.1	72.4	80.1	80.2	76.5	72.6	65.3	58.1	(20)
(21)		2%	DB	57.5	59.0	64.1	72.0	78.5	82.6	91.8	95.4	87.7	79.1	70.7	62.5	(21)
(22)			MCWB	48.5	49.2	57.3	62.8	65.8	71.8	77.8	79.5	74.7	70.6	63.1	52.7	(22)
(23)		5%	DB	55.0	55.5	61.2	70.0	75.5	80.4	89.4	91.7	84.4	77.2	68.3	59.5	(23)
(24)			MCWB	46.7	46.0	54.1	61.8	65.1	71.2	77.1	77.9	74.9	68.2	60.6	49.7	(24)
(25)		10%	DB	51.9	52.0	58.9	67.6	73.5	78.3	86.1	87.7	82.7	75.2	66.0	57.2	(25)
(26)			MCWB	43.3	43.0	50.9	58.6	65.0	70.7	76.4	77.8	75.0	66.8	58.5	48.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.3	54.2	60.5	69.8	72.3	76.4	80.9	83.6	79.3	75.1	67.7	60.7	(27)
(28)			MCD B	59.9	59.9	63.3	72.0	74.9	81.8	91.3	92.6	84.7	80.5	71.0	67.3	(28)
(29)		2%	WB	50.6	49.5	58.0	66.3	70.6	74.9	79.1	80.8	78.2	72.5	65.1	55.2	(29)
(30)			MCD B	55.3	57.5	62.4	70.9	74.1	79.4	88.2	89.6	83.3	78.3	69.5	59.7	(30)
(31)		5%	WB	47.5	46.0	55.5	62.9	68.1	73.8	78.2	79.4	77.3	70.0	62.4	51.8	(31)
(32)			MCD B	54.0	53.7	60.7	68.1	73.1	77.7	86.0	87.2	82.4	75.6	66.4	57.9	(32)
(33)		10%	WB	44.3	43.7	52.3	60.1	66.3	72.2	77.3	78.5	76.4	67.7	59.4	49.8	(33)
(34)			MCD B	50.6	51.3	57.0	65.6	72.0	76.5	84.0	85.5	81.7	73.6	64.4	55.9	(34)
(35)	Mean Daily Temperature Range	MDBR	11.0	11.5	11.3	12.1	11.2	10.2	10.5	10.4	8.7	8.9	9.8	10.5		(35)
(36)		5% DB	MCD BR	15.6	16.9	14.5	15.2	15.1	13.6	16.1	17.1	11.8	11.5	13.8	13.9	(36)
(37)			MCWBR	12.3	11.9	11.7	9.5	9.1	7.2	7.3	7.2	7.0	8.4	11.7	11.2	(37)
(38)		5% WB	MCD BR	14.2	14.9	12.9	12.5	12.5	10.9	12.8	12.9	9.2	11.2	12.4	12.5	(38)
(39)			MCWBR	12.6	12.0	12.4	10.4	9.2	7.1	6.2	6.6	6.8	9.4	12.8	11.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.381	0.429	0.492	0.539	0.558	0.582	0.576	0.563	0.505	0.482	0.426	0.382	(40)	
(41)		taud	2.252	2.112	1.956	1.886	1.899	1.911	1.972	2.000	2.130	2.118	2.190	2.263	(41)	
(42)		Ebn at Noon	253	252	246	241	239	232	233	233	240	233	234	244	(42)	
(43)		Edh at Noon	34	43	55	62	62	62	57	55	46	43	36	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	873	1028	1290	1511	1629	1427	1597	1611	1243	964	794	766	(44)	
(45)		RadStd	65	109	85	155	173	139	267	143	111	103	75	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page