

YOKOSUKA, Japan

WMO: 476960

Lat: 35.2833N

Lon: 139.6667E

Elev: 53

StdP: 100.69

Time Zone: 9.00 (E09)

Period: 94-05

WBAN: 43323

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	2.9	-12.1	1.3	5.2	-10.0	1.6	5.5	15.4	7.4	13.4	6.7	4.7	330	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.8	34.2	25.9	32.1	25.1	30.2	24.8	26.6	31.3	26.0	30.1	25.5	29.2	3.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	20.7	28.7	24.9	20.1	28.5	24.3	19.4	28.0	83.8	30.9	80.9	31.2	78.6	29.4	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.8	11.2	9.9	-0.3	35.6	1.2	3.3	-1.2	37.9	-1.9	39.8	-2.6	41.7	-3.5	44.0
			-3.8	28.4	1.2	1.3	-4.7	29.3	-5.5	30.0	-6.1	30.8	-7.0	31.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	7.2	7.3	10.0	15.1	19.3	22.1	26.4	27.7	24.6	19.6	14.9	10.2
	DBStd	7.50	2.12	2.40	2.88	3.09	2.54	2.51	2.68	2.68	2.79	2.78	2.54	2.39
	HDD10.0	237	90	82	36	3	0	0	0	0	0	0	0	27
	HDD18.3	1415	344	309	259	103	19	3	0	0	17	107	253	
	CDD10.0	2823	4	6	35	156	288	363	508	550	437	298	147	31
	CDD18.3	959	0	0	0	6	49	116	250	292	187	57	3	0
	CDH23.3	7124	0	0	0	6	101	413	2184	2989	1264	163	3	0
	CDH26.7	2101	0	0	0	0	9	57	684	1053	285	12	0	0
Wind	WSAvg	4.3	4.6	4.3	4.7	4.1	3.9	3.8	3.9	4.1	4.6	5.0	4.7	4.5
Precipitation	PrecAvg	1577	54	69	117	143	153	197	141	136	181	175	108	51
	PrecMax	2074	157	165	216	240	384	494	463	328	436	494	287	240
	PrecMin	1002	2	4	16	28	42	38	21	9	32	18	14	0
	PrecStd	278	35	48	48	48	76	102	84	88	94	103	70	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.8	17.2	19.9	24.1	27.9	30.0	35.8	37.2	33.1	28.2	23.9	19.2
		MCWB	12.1	9.5	13.6	16.5	18.9	22.4	26.7	26.8	24.7	22.6	18.5	14.5
	2%	DB	14.2	15.0	17.8	22.2	25.9	28.1	33.2	35.2	30.9	26.2	21.5	17.0
		MCWB	9.2	9.5	14.1	17.1	18.8	22.1	25.5	26.4	23.7	21.4	17.3	11.5
	5%	DB	12.8	13.1	16.2	21.1	24.1	26.9	31.9	33.2	29.1	25.1	20.2	15.3
		MCWB	8.2	7.8	12.3	16.5	18.4	21.8	25.1	25.5	23.9	20.1	15.9	9.8
	10%	DB	11.1	11.1	14.9	19.8	23.1	25.7	30.0	31.0	28.2	24.0	18.9	14.0
		MCWB	6.3	6.1	10.5	14.8	18.3	21.5	24.7	25.4	23.9	19.4	14.7	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.3	15.9	21.0	22.4	24.7	27.2	28.7	26.3	23.9	19.8	15.9
		MCDB	15.5	15.5	17.4	22.2	23.8	27.7	32.9	33.7	29.3	27.0	21.7	19.6
	2%	WB	10.3	9.7	14.5	19.0	21.4	23.9	26.2	27.1	25.7	22.5	18.4	12.9
		MCDB	12.9	14.2	16.9	21.6	23.4	26.3	31.2	32.0	28.5	25.7	20.8	15.4
	5%	WB	8.6	7.8	13.1	17.2	20.0	23.2	25.6	26.4	25.2	21.1	16.9	11.0
		MCDB	12.2	12.1	16.0	20.0	22.8	25.4	30.0	30.7	28.0	24.2	19.1	14.4
	10%	WB	6.8	6.5	11.3	15.6	19.1	22.4	25.2	25.8	24.7	19.8	15.2	9.9
		MCDB	10.3	10.7	13.9	18.7	22.2	24.7	28.9	29.7	27.6	23.1	18.0	13.3
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.4	6.3	6.7	6.2	5.6	5.8	5.8	4.8	5.0	5.4	5.8
		MCDBR	8.7	9.4	8.1	8.5	8.4	7.6	8.9	9.5	6.6	6.4	7.7	7.7
		MCWBR	6.8	6.6	6.5	5.3	5.0	4.0	4.1	4.0	3.9	4.7	6.5	6.2
	5% WB	MCDBR	7.9	8.3	7.2	6.9	6.9	6.1	7.1	7.2	5.1	6.2	6.9	7.0
		MCWBR	7.0	6.7	6.9	5.8	5.1	3.9	3.4	3.7	3.8	5.2	7.1	6.4
Clear-Sky Solar Irradiance	taub	0.381	0.429	0.492	0.539	0.558	0.582	0.576	0.563	0.505	0.482	0.426	0.382	
	taud	2.252	2.112	1.956	1.886	1.899	1.911	1.972	2.000	2.130	2.118	2.190	2.263	
	Ebn at Noon	797	795	775	761	752	732	734	734	757	733	737	768	
	Edh at Noon	107	137	174	196	196	194	181	173	145	135	113	100	
All-Sky Solar Radiation	RadAvg	2.75	3.24	4.07	4.76	5.14	4.50	5.04	5.08	3.92	3.04	2.50	2.42	
	RadStd	0.20	0.34	0.27	0.49	0.54	0.44	0.84	0.45	0.35	0.33	0.24	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page