

HYAKURI AB, Japan

WMO: 477150

Lat: 36.182N

Lon: 140.415E

Elev: 36

StdP: 100.90

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-4.9	-12.9	1.2	2.7	-11.1	1.5	1.8	10.4	6.5	9.2	6.4	1.1	350	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	32.9	26.2	31.8	25.9	30.1	25.3	27.2	30.9	26.4	29.9	25.9	29.1	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.2	25.2	20.5	28.2	25.0	20.1	27.9	86.2	31.1	82.9	30.3	80.1	29.6	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.3	7.3	-8.8	34.9	1.2	1.3	-9.7	35.8	-10.4	36.6	-11.0	37.3	-11.9	38.2		
			-9.4	28.7	1.1	1.2	-10.3	29.6	-10.9	30.3	-11.5	31.0	-12.4	31.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	2.6	3.4	6.7	11.9	16.7	20.2	24.4	25.7	22.1	16.4	10.3	5.1
	DBStd	8.47	2.40	2.75	3.31	3.49	2.91	2.77	3.00	2.54	3.23	3.03	3.14	2.91
	HDD10.0	740	230	186	114	20	0	0	0	0	0	1	34	156
	HDD18.3	2272	488	418	361	194	65	13	1	0	6	76	240	411
	CDD10.0	2146	0	1	11	77	209	305	448	487	363	199	44	3
	CDD18.3	637	0	0	0	1	16	68	189	228	119	16	0	0
	CDH23.3	4613	0	0	0	12	111	336	1456	1921	718	60	0	0
	CDH26.7	1497	0	0	0	1	13	66	516	703	191	9	0	0
Wind	WSAvg	3.0	2.5	2.8	3.3	3.7	3.5	3.1	3.2	3.2	3.2	2.9	2.3	2.3
Precipitation	PrecAvg	1367	50	49	80	114	140	152	150	132	193	174	83	50
	PrecMax	1874	115	149	147	218	311	288	294	376	402	535	194	181
	PrecMin	1098	4	7	33	28	75	69	27	22	13	14	0	0
	PrecStd	175	33	33	31	52	50	46	67	85	91	115	46	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.8	21.0	24.9	28.2	30.2	34.1	34.2	32.2	28.0	21.1	17.1
		MCWB	9.4	12.4	13.1	16.3	19.8	24.1	26.5	26.8	25.4	21.5	16.1	13.6
	2%	DB	11.9	13.2	18.1	22.5	26.0	28.8	32.8	33.1	30.9	24.9	19.2	14.9
		MCWB	6.7	8.3	11.7	15.7	18.5	22.5	26.1	26.5	25.2	20.4	15.0	10.5
	5%	DB	10.1	11.2	15.9	20.8	24.2	26.9	31.2	32.0	29.0	23.1	18.0	13.0
		MCWB	5.2	6.4	10.8	15.1	18.1	21.7	25.8	26.2	24.3	19.1	13.9	8.5
	10%	DB	8.9	9.8	14.0	18.9	22.9	25.1	29.9	30.8	27.1	21.8	16.8	11.2
		MCWB	4.3	5.3	9.7	13.8	17.6	21.2	25.2	26.0	23.5	18.2	13.5	7.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	13.9	15.4	19.7	22.4	25.8	28.0	28.5	26.7	23.3	18.0	15.1
		MCDB	13.0	16.4	17.5	22.0	24.7	28.6	31.5	31.9	29.9	25.7	19.4	16.5
	2%	WB	8.0	9.8	13.9	17.5	20.5	24.1	27.0	27.5	25.9	21.5	16.5	11.6
		MCDB	10.3	12.3	16.7	20.4	23.6	26.7	30.9	31.1	28.9	23.7	18.1	13.5
	5%	WB	6.1	7.5	12.1	15.9	19.5	23.0	26.2	26.7	25.1	20.2	15.4	9.6
		MCDB	8.9	9.9	15.2	18.9	22.8	25.3	29.8	30.4	28.0	22.2	16.9	11.9
	10%	WB	4.6	5.8	10.1	14.8	18.4	21.9	25.6	26.1	24.3	18.9	14.1	8.1
		MCDB	7.6	8.6	12.8	17.7	21.6	24.3	28.9	29.4	26.6	20.8	16.0	10.4
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.7	11.6	11.2	9.7	7.7	7.6	7.7	7.8	9.0	10.8	11.9
		MCDBR	14.0	14.3	14.7	13.9	12.7	10.5	10.0	9.8	9.5	10.2	12.0	13.2
		MCWBR	9.4	9.9	9.7	8.2	6.9	5.5	4.7	4.4	4.8	6.2	8.3	9.2
	5% WB	MCDBR	12.1	12.7	12.9	11.2	10.4	8.6	9.1	8.9	8.6	8.4	9.6	11.3
		MCWBR	9.2	9.9	10.1	7.7	6.8	5.4	4.9	4.6	4.8	5.9	7.7	8.9
Clear-Sky Solar Irradiance	taub	0.373	0.423	0.495	0.547	0.566	0.600	0.594	0.577	0.508	0.473	0.420	0.377	
	taud	2.247	2.099	1.925	1.852	1.860	1.844	1.908	1.942	2.095	2.115	2.178	2.256	
	Ebn at Noon	799	795	769	753	745	718	719	720	751	736	735	764	
	Edh at Noon	105	137	179	202	204	207	193	183	149	134	113	99	
All-Sky Solar Radiation	RadAvg	2.70	3.23	4.04	4.73	5.09	4.62	4.88	4.85	3.80	3.00	2.46	2.35	
	RadStd	0.16	0.31	0.23	0.43	0.51	0.38	0.78	0.50	0.31	0.29	0.22	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.36	+0.57	N/A	N/A	N/A	N/A	N/A	N/A	+140	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page