

MIHO AB, Japan

WMO: 477430

Lat: 35.493N

Lon: 133.239E

Elev: 23

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.0	31.7	18.0	13.6	38.1	20.9	15.7	39.1	33.9	36.2	30.6	36.1	11.3	180	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.8	92.8	78.1	90.0	77.5	87.9	77.2	79.9	88.0	79.0	86.8	78.1	85.4	12.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	142.4	84.2	76.9	140.1	83.8	75.5	133.5	82.6	43.5	88.4	42.5	86.8	41.4	86.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	23.7	20.9	DB	26.2	96.7	2.0	2.5	24.7	98.5	23.5	99.9	22.4	101.3	20.9	103.1	(4)
(5)			WB	24.3	81.7	2.1	1.7	22.7	82.9	21.5	83.9	20.3	84.8	18.7	86.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	40.1	41.0	46.4	55.5	64.4	71.1	79.3	81.4	73.7	63.9	54.0	44.8	(6)
(7)		DBStd	14.97	4.11	4.84	5.56	5.90	4.80	4.55	4.68	3.87	4.89	4.88	5.27	4.88	(7)
(8)		HDD50	914	309	256	142	16	0	0	0	0	0	0	20	171	(8)
(9)		HDD65	3422	773	672	578	290	69	3	0	0	1	79	331	626	(9)
(10)		CDD50	4469	1	4	29	180	448	634	907	974	711	431	140	10	(10)
(11)		CDD65	1500	0	0	0	4	52	187	442	509	261	44	1	0	(11)
(12)		CDH74	12177	0	0	1	40	304	882	4010	5242	1560	135	3	0	(12)
(13)		CDH80	4038	0	0	0	3	45	184	1426	1999	364	17	0	0	(13)
(14)	Wind	WSAvg	9.4	10.5	9.8	10.2	10.2	9.5	8.6	8.8	8.7	8.8	8.6	9.0	10.0	(14)
(15)	Precipitation	PrecAvg	70.8	6.4	4.7	5.1	4.3	5.3	6.5	8.9	5.2	7.8	5.0	5.4	6.2	(15)
(16)		PrecMax	90.7	9.8	6.8	7.7	7.8	14.5	14.3	22.2	12.7	16.4	11.9	8.8	10.7	(16)
(17)		PrecMin	57.3	3.9	3.0	2.5	1.5	1.8	1.1	0.3	1.1	2.0	1.9	1.5	1.9	(17)
(18)		PrecStd	9.2	1.7	1.2	1.4	1.8	2.9	3.5	5.9	2.9	4.4	2.7	2.0	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	62.7	70.0	78.6	84.4	88.2	94.6	96.4	91.4	82.2	72.0	62.2	(19)
(20)			MCWB	50.5	53.2	55.1	61.1	64.2	75.4	78.2	78.0	78.0	70.2	61.4	54.5	(20)
(21)		2%	DB	52.1	55.8	64.4	73.7	80.6	84.4	91.6	93.3	87.6	77.2	68.3	58.6	(21)
(22)			MCWB	45.2	48.4	52.6	58.9	63.3	72.5	77.7	78.4	76.5	67.9	59.6	51.4	(22)
(23)		5%	DB	49.9	52.2	60.5	70.0	77.2	82.0	89.7	91.3	84.2	74.9	66.0	55.6	(23)
(24)			MCWB	43.9	45.8	51.2	57.6	62.7	70.9	77.3	78.1	74.8	65.9	58.4	49.1	(24)
(25)		10%	DB	47.9	49.9	57.0	66.4	74.6	78.9	87.6	89.3	80.9	72.0	63.0	53.4	(25)
(26)			MCWB	42.4	44.3	49.4	56.3	61.8	69.9	77.1	77.8	73.3	63.9	56.8	47.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.2	55.3	58.0	66.1	70.2	77.4	80.7	81.5	79.8	72.5	64.7	56.8	(27)
(28)			MCD B	55.1	61.6	65.2	71.5	76.6	85.7	89.7	89.8	85.9	78.5	69.2	60.3	(28)
(29)		2%	WB	46.9	50.6	54.7	62.3	67.3	75.3	79.5	80.3	77.9	70.0	61.8	52.3	(29)
(30)			MCD B	50.4	54.1	60.9	70.6	74.0	81.6	88.0	88.4	84.2	75.1	66.3	56.5	(30)
(31)		5%	WB	44.3	47.5	52.3	59.8	65.6	73.3	78.5	79.6	76.3	67.5	59.7	50.2	(31)
(32)			MCD B	48.0	51.6	58.3	67.0	72.8	78.8	86.7	87.4	82.2	72.5	64.4	53.9	(32)
(33)		10%	WB	42.4	44.6	50.2	57.6	63.9	71.5	77.6	78.7	74.8	65.5	57.5	48.1	(33)
(34)			MCD B	46.6	48.5	55.8	64.5	71.2	76.7	85.1	86.1	80.0	70.7	62.2	52.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.3	12.8	15.8	17.4	16.5	12.5	11.8	12.8	12.3	14.5	14.2	12.0	(35)
(36)			MCDBR	16.4	19.3	23.3	24.0	22.6	17.3	15.7	16.2	15.3	17.1	18.4	16.6	(36)
(37)			MCWBR	11.1	13.3	14.2	12.3	10.3	7.9	6.2	6.3	7.3	9.2	11.2	11.3	(37)
(38)		5% WB	MCDBR	14.5	16.9	19.2	18.4	16.2	12.6	14.2	14.2	12.8	13.4	15.1	14.9	(38)
(39)			MCWBR	11.2	13.2	13.4	11.1	9.4	6.8	6.4	6.4	6.8	8.4	10.6	11.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.439	0.474	0.542	0.560	0.557	0.574	0.572	0.534	0.492	0.454	0.436	0.430	(40)	
(41)		taud	1.996	1.937	1.804	1.816	1.880	1.914	1.982	2.087	2.154	2.150	2.102	2.041	(41)	
(42)		Ebn at Noon	227	236	231	236	239	234	234	240	244	241	228	221	(42)	
(43)		Edh at Noon	43	52	64	67	63	61	57	50	45	41	39	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	537	771	1137	1506	1664	1556	1538	1600	1238	1008	685	489	(44)	
(45)		RadStd	43	78	102	124	159	120	230	179	107	89	56	41	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page