

MIHO AB, Japan

WMO: 477430

Lat: 35.493N

Lon: 133.239E

Elev: 7

StdP: 101.24

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	-0.1	-7.8	1.9	3.4	-6.2	2.2	3.9	15.2	2.3	13.7	2.3	5.1	180	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	33.8	25.6	32.2	25.3	31.0	25.1	26.6	31.1	26.1	30.4	25.6	29.7	5.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.3	29.0	24.9	20.0	28.8	24.1	19.1	28.1	83.4	31.3	81.0	30.5	78.5	30.2	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	10.6	9.4	-3.2	36.0	1.1	1.4	-4.1	36.9	-4.7	37.7	-5.3	38.5	-6.2	39.5		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-4.3	27.6	1.2	0.9	-5.1	28.3	-5.8	28.8	-6.5	29.3	-7.4	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	4.5	5.0	8.0	13.0	18.0	21.7	26.3	27.5	23.2	17.7	12.2	7.1
	DBStd	8.32	2.29	2.69	3.09	3.28	2.66	2.53	2.60	2.15	2.71	2.71	2.93	2.71
	HDD10.0	508	172	142	79	9	0	0	0	0	0	0	11	95
	HDD18.3	1901	429	373	321	161	38	2	0	0	1	44	184	348
	CDD10.0	2483	1	2	16	100	249	352	504	541	395	239	78	6
	CDD18.3	833	0	0	0	2	29	104	246	283	145	24	1	0
	CDH23.3	6765	0	0	1	22	169	490	2228	2912	867	75	2	0
	CDH26.7	2243	0	0	0	2	25	102	792	1111	202	9	0	0
Wind	WSAvg	4.2	4.7	4.4	4.6	4.6	4.2	3.8	3.9	3.9	3.9	3.8	4.0	4.5
Precipitation	PrecAvg	1798	163	120	129	110	134	165	227	131	199	126	137	157
	PrecMax	2304	248	173	195	197	368	362	565	323	417	301	223	272
	PrecMin	1455	100	75	63	39	45	28	8	27	52	49	37	48
	PrecStd	234	44	31	36	45	74	89	150	74	111	69	51	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	17.0	21.1	25.9	29.1	31.2	34.8	35.8	33.0	27.9	22.2	16.8
		MCWB	10.3	11.8	12.8	16.1	17.9	24.1	25.7	25.5	25.5	21.2	16.3	12.5
	2%	DB	11.2	13.2	18.0	23.2	27.0	29.1	33.1	34.0	30.9	25.1	20.1	14.8
		MCWB	7.3	9.1	11.4	14.9	17.4	22.5	25.4	25.8	24.7	19.9	15.3	10.8
	5%	DB	10.0	11.2	15.8	21.1	25.1	27.8	32.0	33.0	29.0	23.9	18.9	13.1
		MCWB	6.6	7.7	10.7	14.2	17.1	21.6	25.2	25.6	23.8	18.9	14.6	9.5
	10%	DB	8.8	9.9	13.9	19.1	23.7	26.1	30.9	31.8	27.2	22.2	17.2	11.9
		MCWB	5.8	6.8	9.7	13.5	16.6	21.1	25.0	25.4	22.9	17.7	13.8	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	13.0	14.4	19.0	21.2	25.2	27.1	27.5	26.5	22.5	18.1	13.8
		MCDB	12.8	16.5	18.5	22.0	24.8	29.9	32.0	32.1	29.9	25.8	20.7	15.7
	2%	WB	8.3	10.3	12.6	16.8	19.6	24.1	26.4	26.8	25.5	21.1	16.6	11.3
		MCDB	10.2	12.3	16.1	21.4	23.3	27.6	31.1	31.3	29.0	24.0	19.1	13.6
	5%	WB	6.8	8.6	11.3	15.4	18.6	22.9	25.9	26.4	24.6	19.7	15.4	10.1
		MCDB	8.9	10.9	14.6	19.4	22.7	26.0	30.4	30.8	27.9	22.5	18.0	12.2
	10%	WB	5.8	7.0	10.1	14.2	17.7	22.0	25.3	25.9	23.8	18.6	14.2	8.9
		MCDB	8.1	9.2	13.2	18.1	21.8	24.9	29.5	30.1	26.7	21.5	16.8	11.4
Mean Daily Temperature Range	5% DB	MDBR	6.3	7.1	8.8	9.7	9.2	6.9	6.5	7.1	6.8	8.1	7.9	6.7
		MCDBR	9.1	10.7	12.9	13.4	12.5	9.6	8.7	9.0	8.5	9.5	10.2	9.2
		MCWBR	6.1	7.4	7.9	6.8	5.7	4.4	3.4	3.5	4.1	5.1	6.2	6.3
	5% WB	MCDBR	8.1	9.4	10.7	10.2	9.0	7.0	7.9	7.9	7.1	7.5	8.4	8.3
		MCWBR	6.2	7.3	7.5	6.2	5.2	3.8	3.5	3.6	3.8	4.7	5.9	6.5
Clear-Sky Solar Irradiance	taub	0.439	0.474	0.542	0.560	0.557	0.574	0.572	0.534	0.492	0.454	0.436	0.430	
	taud	1.996	1.937	1.804	1.816	1.880	1.914	1.982	2.087	2.154	2.150	2.102	2.041	
	Ebn at Noon	717	743	729	744	753	738	737	757	768	759	720	696	
	Edh at Noon	137	163	203	210	200	193	179	159	141	130	123	124	
All-Sky Solar Radiation	RadAvg	1.69	2.43	3.58	4.75	5.25	4.91	4.85	5.04	3.90	3.18	2.16	1.54	
	RadStd	0.14	0.24	0.32	0.39	0.50	0.38	0.72	0.56	0.34	0.28	0.17	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page