

TOTTORI, Japan

WMO: 477460

Lat: 35.4878N

Lon: 134.2383E

Elev: 52

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.5	31.1	20.0	15.0	39.0	22.3	16.8	39.4	22.9	39.8	20.7	39.4	8.0	110	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.2	94.0	77.7	91.8	77.0	89.6	76.5	79.2	89.5	78.3	88.2	77.4	86.8	9.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	138.9	83.9	75.6	134.2	83.3	74.7	130.0	82.8	42.8	89.8	41.9	88.5	41.0	87.2	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	17.0	14.7	DB	26.2	97.7	2.3	1.7	24.5	98.9	23.1	99.8	21.8	100.8	20.1	102.0
			WB	24.5	80.8	2.4	1.1	22.8	81.5	21.3	82.2	20.0	82.8	18.2	83.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	39.7	40.7	46.3	55.7	64.9	72.1	80.0	82.1	73.8	63.8	53.8	44.4	(6)
	DBStd	15.41	4.34	5.06	6.00	6.31	5.05	4.51	4.63	4.05	5.22	5.01	5.47	5.33	(7)
	HDD50	962	320	266	150	18	0	0	0	0	0	0	23	185	(8)
	HDD65	3454	783	680	580	285	65	2	0	0	1	82	338	638	(9)
	CDD50	4572	1	5	35	189	462	662	931	996	715	428	136	12	(10)
	CDD65	1591	0	0	0	6	62	214	466	531	267	44	1	0	(11)
	CDH74	14137	0	0	0	51	438	1280	4535	5769	1860	202	2	0	(12)
	CDH80	5347	0	0	0	6	68	294	1829	2572	551	27	0	0	(13)
(14) Wind	WSAvg	6.8	7.2	7.2	7.6	7.5	7.2	6.1	6.2	6.2	5.9	6.1	6.6	7.2	(14)
(15) Precipitation	PrecAvg	69.2	6.3	4.9	5.1	4.1	5.4	6.1	7.7	5.0	8.0	5.2	5.1	6.3	(15)
	PrecMax	85.7	11.7	7.9	8.3	6.9	13.5	11.1	17.0	13.7	17.8	11.7	9.7	11.0	(16)
	PrecMin	52.3	3.9	3.0	2.2	1.5	1.9	2.6	0.8	1.3	2.5	1.6	2.2	2.9	(17)
	PrecStd	7.2	2.0	1.3	1.5	1.7	2.6	2.0	3.9	2.8	4.3	2.5	1.9	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	65.0	70.8	79.4	85.4	89.6	96.0	97.4	92.5	83.2	72.9	64.0	(19)
		MCWB	51.2	56.7	55.2	59.8	65.0	72.2	78.3	78.2	76.5	71.4	61.2	55.3	(20)
	2%	DB	53.5	58.0	65.4	74.5	81.8	86.0	93.2	94.9	88.9	78.8	69.4	59.4	(21)
		MCWB	45.9	49.6	52.9	58.7	63.6	71.0	77.5	77.9	75.5	67.8	59.9	51.7	(22)
	5%	DB	50.5	53.6	61.7	71.3	78.9	83.3	90.9	92.9	85.8	75.8	66.7	56.7	(23)
		MCWB	43.9	46.2	51.6	57.8	62.6	70.4	76.9	77.5	74.3	65.8	58.5	49.5	(24)
	10%	DB	47.5	50.2	58.3	67.9	75.9	81.0	88.8	90.9	83.0	73.1	63.9	53.9	(25)
		MCWB	41.9	44.0	50.1	56.5	62.0	69.5	76.4	77.0	72.9	64.1	56.6	47.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	56.9	58.4	65.9	70.2	75.9	80.1	80.9	78.4	73.3	64.7	57.8	(27)
		MCDB	56.8	63.6	64.8	72.0	77.2	84.2	91.0	91.6	87.5	81.1	69.0	61.2	(28)
	2%	WB	47.5	50.9	55.6	62.1	67.9	74.5	79.0	79.7	76.8	70.3	62.1	53.6	(29)
		MCDB	52.3	56.4	61.6	70.3	74.9	81.9	89.2	90.2	85.4	76.3	67.2	57.6	(30)
	5%	WB	44.5	47.5	53.0	59.9	65.8	73.2	78.1	78.9	75.6	67.9	59.9	50.5	(31)
		MCDB	48.9	52.2	59.5	67.8	73.8	80.0	87.8	89.2	83.2	73.2	65.1	55.2	(32)
	10%	WB	42.4	44.4	50.6	58.1	64.3	71.6	77.2	78.0	74.4	65.7	57.7	48.1	(33)
		MCDB	47.0	49.5	57.6	65.6	72.6	78.2	86.5	87.7	81.2	70.9	63.0	53.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	13.2	16.5	18.7	18.2	14.6	13.6	15.2	14.4	15.8	14.9	12.7	(35)
		MCDBR	16.8	20.9	23.1	24.1	24.0	18.7	17.0	18.0	17.1	18.8	18.9	17.7	(36)
	5% WB	MCWBR	11.2	13.9	14.1	12.2	10.4	7.7	6.1	6.3	7.0	9.6	11.1	11.4	(37)
		MCWBR	15.4	18.0	19.1	18.0	17.0	13.2	15.7	16.2	14.4	14.4	15.5	15.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.439	0.474	0.541	0.562	0.561	0.583	0.582	0.549	0.500	0.459	0.439	0.431	(40)
		taud	1.999	1.935	1.804	1.811	1.870	1.890	1.952	2.037	2.127	2.138	2.095	2.041	(41)
	Ebn at Noon		227	236	232	235	238	232	231	236	241	239	227	221	(42)
		Edh at Noon	43	52	64	67	64	63	59	53	46	42	39	39	(43)
(44) All-Sky Solar Radiation	RadAvg		539	767	1112	1478	1637	1514	1501	1561	1207	978	673	497	(44)
	RadStd		44	83	102	130	160	117	224	177	112	90	56	45	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) +0.76	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page