

MAIZURU, Japan

WMO: 477500

Lat: 35.4503N

Lon: 135.3181E

Elev: 14

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.9	30.3	20.9	15.7	38.1	23.5	17.8	39.2	21.1	41.9	18.9	41.1	4.3	230	0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.1	93.8	77.7	91.7	77.2	89.3	76.7	79.4	89.0	78.5	87.8	77.6	86.3	7.8	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.1	141.0	83.4	76.1	136.2	82.7	75.2	132.0	82.1	43.0	89.2	42.0	87.9	41.1	86.8	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.0	13.6	26.0	97.7	2.0	1.6	24.5	98.8	23.3	99.7	22.2	100.6	20.7	101.7		
			24.6	81.0	2.4	1.2	22.9	81.8	21.5	82.5	20.2	83.2	18.4	84.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.5	39.0	39.9	45.7	55.3	64.7	71.7	79.8	82.0	74.1	63.7	53.1	43.7
	DBStd	15.65	4.17	4.99	5.96	6.37	5.03	4.64	4.52	3.92	5.30	5.04	5.38	5.00
	HDD50	1049	343	287	164	22	0	0	0	0	0	0	28	205
	HDD65	3582	807	703	599	297	68	3	0	0	2	84	357	662
	CDD50	4514	1	4	30	181	455	650	924	993	722	425	121	8
	CDD65	1572	0	0	0	5	58	203	459	528	274	44	1	0
	CDH74	13225	0	0	0	60	422	1141	4187	5495	1775	144	1	0
	CDH80	4878	0	0	0	8	71	276	1633	2356	519	15	0	0
Wind	WSAvg	5.2	5.1	5.5	6.0	5.8	5.5	4.9	4.8	4.9	5.0	4.9	5.0	5.1
Precipitation	PrecAvg	73.3	6.8	5.5	5.3	4.4	5.7	6.3	7.0	5.7	8.7	6.3	5.4	6.1
	PrecMax	89.6	11.4	8.1	8.0	7.8	19.2	14.3	16.5	16.9	18.1	18.7	11.4	12.2
	PrecMin	59.1	3.2	3.1	2.6	1.6	1.7	2.6	1.7	0.6	2.4	1.8	1.8	2.4
	PrecStd	7.2	1.9	1.3	1.5	1.7	3.5	2.6	3.4	3.4	4.1	3.3	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	63.3	70.4	80.0	85.4	89.9	95.7	97.0	92.8	82.0	71.5	61.6
		MCWB	50.8	55.7	55.7	60.8	66.1	73.3	77.8	77.9	76.6	71.0	62.4	55.7
	2%	DB	51.5	56.3	65.4	74.8	81.9	86.0	93.2	94.6	89.2	77.7	67.6	57.2
		MCWB	45.9	48.7	53.7	59.1	64.6	72.0	77.6	78.0	75.9	68.4	60.1	51.5
	5%	DB	48.6	52.0	61.0	70.9	78.8	83.1	90.9	92.7	85.7	74.8	64.8	54.5
		MCWB	43.7	46.5	51.9	57.9	63.3	70.8	77.2	77.7	74.6	66.1	58.7	49.6
	10%	DB	46.1	48.8	56.9	67.4	75.6	80.4	88.3	90.6	82.5	72.2	62.1	51.9
		MCWB	41.8	43.8	49.9	56.6	62.4	70.2	76.7	77.4	73.2	64.7	56.8	47.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	57.1	59.6	66.0	71.1	76.6	80.3	81.2	78.7	73.5	64.7	57.4
		MCDB	56.1	63.0	64.6	71.8	77.8	85.4	89.7	91.1	87.7	78.7	67.9	59.7
	2%	WB	47.1	50.6	55.8	62.2	68.3	74.9	79.1	80.0	77.2	70.4	62.2	53.2
		MCDB	50.0	54.4	62.4	70.3	74.9	81.7	88.8	89.6	85.5	75.4	65.8	56.0
	5%	WB	44.2	47.3	53.1	60.2	66.0	73.6	78.1	79.0	75.9	68.0	59.9	50.2
		MCDB	47.8	51.2	59.0	67.8	74.6	80.1	87.6	88.4	83.3	72.6	63.6	53.5
	10%	WB	42.2	44.1	50.4	58.0	64.3	71.8	77.2	78.2	74.6	66.0	57.6	47.9
		MCDB	45.6	48.1	56.4	65.0	72.8	77.9	86.1	87.0	81.0	70.5	61.5	51.3
Mean Daily Temperature Range	5% DB	MDBR	11.1	12.9	16.5	18.6	18.3	14.5	13.8	15.1	13.6	14.5	14.2	12.2
		MCDBR	15.9	20.2	24.9	25.8	25.1	19.3	18.0	18.4	17.4	17.2	17.6	16.2
		MCWBR	10.9	13.3	14.6	12.5	10.5	7.7	5.9	5.8	6.7	8.8	10.8	11.1
	5% WB	MCDBR	14.7	17.6	19.8	19.0	19.2	14.2	16.1	16.3	15.2	13.9	14.5	14.5
		MCWBR	10.9	13.1	13.6	11.0	9.9	6.5	5.9	5.7	6.3	8.0	10.2	11.2
Clear-Sky Solar Irradiance	taub		0.435	0.469	0.534	0.558	0.561	0.583	0.584	0.551	0.500	0.460	0.437	0.428
	taud		2.022	1.954	1.826	1.824	1.876	1.894	1.949	2.030	2.131	2.145	2.107	2.056
	Ebn at Noon		229	238	233	236	238	232	231	236	241	239	228	222
	Edh at Noon		43	51	63	66	64	62	59	53	46	42	39	39
All-Sky Solar Radiation	RadAvg		559	763	1117	1451	1616	1499	1519	1574	1224	977	685	513
	RadStd		43	85	101	127	165	126	237	177	108	90	56	45

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page