

MAIZURU, Japan

WMO: 477500

Lat: 35.4503N

Lon: 135.3181E

Elev: 4

StdP: 101.27

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.7	(c) -0.9	(d) -6.2	(e) 2.2	(f) 3.4	(g) -4.7	(h) 2.5	(i) 4.0	(j) 9.5	(k) 5.5	(l) 8.4	(m) 5.1	(n) 1.9	(o) 230	(p) 0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.4	(c) 34.3	(d) 25.4	(e) 33.2	(f) 25.1	(g) 31.9	(h) 24.8	(i) 26.4	(j) 31.7	(k) 25.8	(l) 31.0	(m) 25.3	(n) 30.2	(o) 3.5	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.1	28.6	24.5	19.5	28.2	24.0	18.9	27.8	82.1	31.8	79.9	31.1	77.7	30.4	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.4	7.2	6.1	DB	-3.3	36.5	1.1	0.9	-4.2	37.1	-4.8	37.6	-5.5	38.1	-6.3	38.7
			WB	-4.1	27.2	1.3	0.7	-5.0	27.7	-5.8	28.1	-6.6	28.4	-7.6	28.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	3.9	4.4	7.6	12.9	18.2	22.0	26.6	27.8	23.4	17.6	11.7	6.5		
	DBStd	8.70	2.32	2.77	3.31	3.54	2.79	2.58	2.51	2.18	2.95	2.80	2.99	2.78		
	HDD10.0	583	191	159	91	12	0	0	0	0	0	0	16	114		
	HDD18.3	1990	448	391	333	165	38	2	0	0	1	47	198	368		
	CDD10.0	2508	1	2	17	101	253	361	513	552	401	236	67	4		
	CDD18.3	873	0	0	0	3	32	113	255	293	152	24	1	0		
	CDH23.3	7347	0	0	0	33	234	634	2326	3053	986	80	1	0		
	CDH26.7	2710	0	0	0	4	39	153	907	1309	288	8	0	0		
(14) Wind	WSAvg	2.3	2.3	2.4	2.7	2.6	2.4	2.2	2.2	2.2	2.2	2.2	2.2	2.3		
(15) Precipitation	PrecAvg	1862	173	140	135	112	146	160	179	144	222	161	136	154		
	PrecMax	2277	289	205	204	198	487	364	418	430	460	475	289	311		
	PrecMin	1501	82	80	65	41	43	67	43	16	62	46	46	60		
	PrecStd	182	49	34	39	44	89	67	86	87	105	84	56	50		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	17.4	21.4	26.7	29.7	32.2	35.4	36.1	33.8	27.8	21.9	16.4		
		MCWB	10.4	13.1	13.1	16.0	18.9	22.9	25.5	25.5	24.8	21.7	16.9	13.2		
	2%	DB	10.8	13.5	18.6	23.8	27.7	30.0	34.0	34.8	31.8	25.4	19.8	14.0		
		MCWB	7.7	9.3	12.1	15.0	18.1	22.2	25.3	25.6	24.4	20.2	15.6	10.8		
	5%	DB	9.2	11.1	16.1	21.6	26.0	28.4	32.7	33.7	29.8	23.8	18.2	12.5		
		MCWB	6.5	8.1	11.1	14.4	17.4	21.6	25.1	25.4	23.7	18.9	14.8	9.8		
	10%	DB	7.9	9.3	13.8	19.6	24.2	26.9	31.3	32.5	28.1	22.3	16.7	11.0		
		MCWB	5.4	6.5	10.0	13.7	16.9	21.2	24.8	25.2	22.9	18.2	13.8	8.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	13.9	15.3	18.9	21.7	24.8	26.8	27.3	26.0	23.0	18.2	14.1		
		MCDB	13.4	17.2	18.1	22.1	25.4	29.6	32.0	32.9	30.9	26.0	20.0	15.4		
	2%	WB	8.4	10.3	13.2	16.8	20.2	23.9	26.1	26.6	25.1	21.3	16.8	11.8		
		MCDB	10.0	12.4	16.9	21.3	23.9	27.6	31.6	32.0	29.7	24.1	18.8	13.3		
	5%	WB	6.8	8.5	11.7	15.7	18.9	23.1	25.6	26.1	24.4	20.0	15.5	10.1		
		MCDB	8.8	10.7	15.0	19.9	23.7	26.7	30.9	31.4	28.5	22.5	17.5	11.9		
	10%	WB	5.7	6.7	10.2	14.4	18.0	22.1	25.1	25.6	23.7	18.9	14.2	8.8		
		MCDB	7.5	8.9	13.6	18.3	22.7	25.5	30.0	30.6	27.2	21.4	16.4	10.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.2	9.2	10.3	10.1	8.0	7.6	8.4	7.5	8.0	7.9	6.8		
		MCDBR	8.9	11.2	13.9	14.3	13.9	10.7	10.0	10.2	9.6	9.6	9.8	9.0		
	5% WB	MCWBR	6.1	7.4	8.1	6.9	5.8	4.3	3.3	3.2	3.7	4.9	6.0	6.2		
		MCWBR	8.2	9.8	11.0	10.5	10.7	7.9	8.9	9.1	8.4	7.7	8.1	8.0		
(40) Clear-Sky Solar Irradiance	taub		0.435	0.469	0.534	0.558	0.561	0.583	0.584	0.551	0.500	0.460	0.437	0.428		
		taud	2.022	1.954	1.826	1.824	1.876	1.894	1.949	2.030	2.131	2.145	2.107	2.056		
	Ebn at Noon		723	749	736	745	750	731	728	743	761	753	719	700		
		Edh at Noon	134	160	198	209	201	197	185	168	145	131	122	122		
(44) All-Sky Solar Radiation	RadAvg		1.76	2.40	3.52	4.57	5.09	4.72	4.79	4.96	3.86	3.08	2.16	1.62		
	RadStd		0.14	0.27	0.32	0.40	0.52	0.40	0.75	0.56	0.34	0.28	0.17	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A		
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page