

KYOTO, Japan

WMO: 477590

Lat: 35.0147N

Lon: 135.7328E

Elev: 53

StdP: 100.69

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.8	0.0	-8.9	1.8	4.7	-7.1	2.1	4.9	5.8	5.4	5.3	5.9	1.6	260	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	35.3	24.8	34.1	24.5	32.9	24.2	25.9	32.3	25.4	31.6	25.0	30.9	3.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.2	28.4	23.7	18.6	28.4	23.2	18.1	28.3	80.2	32.6	78.2	31.7	76.4	31.0	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	5.0	4.4	DB	-2.6	37.0	1.1	1.1	-3.4	37.8	-4.1	38.4	-4.7	39.0	-5.5	39.8	(4)
			WB	-4.2	26.6	1.4	0.7	-5.2	27.0	-6.0	27.4	-6.8	27.8	-7.8	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	5.0	5.7	9.0	14.6	19.8	23.6	27.9	29.2	24.9	18.9	12.7	7.4	(6)
		DBStd	8.76	2.11	2.70	3.18	3.44	2.61	2.36	2.44	1.97	2.87	2.85	3.03	2.69	(7)
		HDD10.0	441	156	124	59	5	0	0	0	0	0	8	89		(8)
		HDD18.3	1723	413	353	289	119	14	0	0	1	26	168	339		(9)
		CDD10.0	2858	1	4	27	143	306	407	554	594	448	277	91	8	(10)
		CDD18.3	1099	0	0	0	7	62	157	296	336	198	45	1	0	(11)
		CDH23.3	10460	0	0	1	52	400	1058	3187	4000	1582	179	1	0	(12)
		CDH26.7	4182	0	0	0	4	83	300	1372	1881	521	21	0	0	(13)
(14)	Wind	WSAvg	1.9	1.7	1.8	2.0	2.1	2.1	2.0	2.1	1.9	1.7	1.5	1.6		(14)
(15)	Precipitation	PrecAvg	1596	88	91	114	113	153	186	197	142	188	139	98	87	(15)
(16)		PrecMax	2036	162	142	174	186	420	459	383	464	409	370	195	128	(16)
(17)		PrecMin	1038	37	40	40	29	42	66	50	46	59	24	18	34	(17)
(18)		PrecStd	254	30	28	36	45	84	82	104	97	93	76	47	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	13.8	17.3	21.5	27.1	31.1	33.0	36.6	37.1	34.2	28.7	22.7	17.0		(19)
(20)		MCWB	9.7	11.3	12.8	15.7	18.3	22.7	25.3	24.9	24.1	21.2	15.7	12.9		(20)
(21)		DB	11.6	14.3	18.9	24.8	28.9	31.1	35.1	35.7	32.5	26.8	20.8	15.0		(21)
(22)		MCWB	7.3	9.2	11.7	14.8	17.6	21.5	24.8	24.8	23.5	19.6	14.9	10.7		(22)
(23)		DB	10.3	12.3	16.7	22.8	27.2	29.8	33.9	34.6	31.1	25.3	19.3	13.5		(23)
(24)		MCWB	6.3	7.7	10.5	14.0	17.1	20.9	24.6	24.7	23.0	18.5	14.3	9.5		(24)
(25)		DB	9.0	10.7	14.9	20.9	25.6	28.4	32.6	33.5	29.7	23.9	17.8	12.1		(25)
(26)		MCWB	5.4	6.8	9.8	13.5	16.5	20.6	24.3	24.5	22.3	17.8	13.5	8.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	11.1	12.7	14.9	19.5	21.8	24.8	26.5	26.6	25.4	23.1	17.9	14.3		(27)
(28)		MCDB	13.0	15.4	17.4	22.2	25.9	30.0	33.9	33.5	30.7	26.6	19.6	15.8		(28)
(29)		WB	8.4	10.4	13.3	17.3	20.3	23.9	25.7	26.1	24.7	21.4	16.6	11.7		(29)
(30)		MCDB	10.5	13.2	17.0	21.4	24.5	28.3	32.4	32.6	29.9	25.1	19.0	14.1		(30)
(31)		WB	6.9	8.6	11.8	15.9	19.1	23.1	25.2	25.6	24.1	20.0	15.4	10.1		(31)
(32)		MCDB	9.6	11.3	15.5	20.5	23.6	27.3	31.4	31.9	29.0	23.6	18.4	12.6		(32)
(33)		WB	5.6	7.0	10.3	14.7	18.1	22.1	24.8	25.2	23.6	18.8	14.2	8.7		(33)
(34)		MCDB	8.5	10.3	14.2	19.1	23.4	26.3	30.5	31.3	28.2	22.7	17.4	11.7		(34)
(35)	Mean Daily Temperature Range	MDBR	6.9	7.6	9.0	10.0	9.8	8.1	7.7	8.3	7.7	8.2	8.1	7.3		(35)
(36)		5% DB	8.8	10.4	12.1	13.1	12.8	10.5	9.6	9.7	9.1	9.6	9.4	9.0		(36)
(37)		MCWBR	5.4	6.4	6.9	6.0	5.4	4.0	3.0	2.9	3.2	4.3	5.2	5.6		(37)
(38)		5% WB	7.6	8.6	9.5	9.1	8.9	7.3	8.5	8.4	7.6	7.2	7.4	7.7		(38)
(39)		MCWBR	5.6	6.6	6.9	5.7	5.2	3.4	2.9	2.8	3.1	4.1	5.2	5.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.434	0.474	0.541	0.573	0.577	0.599	0.598	0.562	0.510	0.469	0.441	0.427		(40)
(41)		taud	2.025	1.940	1.807	1.787	1.835	1.848	1.902	1.982	2.087	2.113	2.089	2.059		(41)
(42)		Ebn at Noon	729	746	731	735	739	721	718	735	753	746	718	707		(42)
(43)		Edh at Noon	134	163	203	217	209	206	194	176	152	136	125	123		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.08	2.73	3.77	4.68	5.15	4.70	4.89	5.04	3.96	3.18	2.37	1.89		(44)
(45)		RadStd	0.15	0.24	0.30	0.42	0.54	0.43	0.69	0.49	0.34	0.31	0.20	0.14		(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page