

KURE, Japan

WMO: 477660

Lat: 34.2411N

Lon: 132.5503E

Elev: 16

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.0	(c) 33.7	(d) 17.4	(e) 13.3	(f) 40.0	(g) 19.7	(h) 14.8	(i) 39.7	(j) 19.6	(k) 45.0	(l) 17.7	(m) 45.3	(n) 6.4	(o) 40	(p) 0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.4	(c) 90.8	(d) 77.6	(e) 89.1	(f) 77.2	(g) 87.5	(h) 76.6	(i) 79.1	(j) 87.3	(k) 78.3	(l) 86.1	(m) 77.5	(n) 85.1	(o) 7.8	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	139.6	83.7	76.0	135.7	83.2	75.2	132.3	82.7	42.6	87.5	41.8	86.5	41.1	85.4	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.4	(b) 14.5	(c) 12.4	(e) 28.7	(f) 93.2	(g) 2.5	(h) 1.5	(i) 26.9	(j) 94.3	(k) 25.5	(l) 95.2	(m) 24.1	(n) 96.1	(o) 22.3	(p) 97.2		
(a) 17.4	(b) 14.5	(c) 12.4	(e) 25.6	(f) 80.1	(g) 2.3	(h) 1.1	(i) 23.9	(j) 81.0	(k) 22.5	(l) 81.6	(m) 21.2	(n) 82.2	(o) 19.6	(p) 83.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.1	42.7	43.8	49.3	58.1	66.6	72.8	80.4	82.9	76.6	67.0	56.6	47.1
	DBStd	14.47	3.99	4.74	5.14	5.07	3.65	3.34	3.80	2.93	4.37	4.75	5.33	4.85
	HDD50	615	228	183	77	5	0	0	0	0	0	0	7	115
	HDD65	2855	691	594	488	212	26	0	0	0	0	33	256	555
	CDD50	5030	2	9	54	246	516	684	942	1020	799	528	204	26
	CDD65	1793	0	0	0	4	76	234	477	555	349	95	3	0
	CDH74	14913	0	0	0	9	185	968	4610	6278	2610	253	0	0
	CDH80	4549	0	0	0	0	7	106	1480	2353	590	13	0	0
(14) Wind	WSAvg	5.2	5.9	5.5	5.5	5.1	4.6	4.3	4.9	5.1	5.1	5.2	5.4	5.9
(15) Precipitation	PrecAvg	55.6	1.9	2.6	4.4	5.0	6.3	8.5	9.3	4.4	5.5	3.7	2.8	1.8
	PrecMax	85.5	5.7	4.6	9.0	8.4	13.6	18.9	23.0	12.4	9.8	10.4	5.9	4.1
	PrecMin	32.6	0.4	1.0	1.9	1.4	1.5	1.5	1.3	0.5	2.0	0.6	0.6	0.1
	PrecStd	12.1	1.2	1.1	1.7	1.9	2.7	4.1	6.3	3.3	2.5	2.8	1.6	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	61.9	66.9	75.0	80.7	85.4	92.2	93.3	89.5	81.8	71.7	62.4
		MCWB	50.2	53.9	55.9	60.5	64.2	73.3	78.1	78.1	76.6	72.0	62.2	54.2
	2%	DB	53.8	57.0	63.6	71.4	78.1	82.7	90.1	91.5	87.2	78.8	69.4	59.6
		MCWB	47.0	49.6	53.7	58.5	63.9	71.2	77.5	77.8	75.2	69.3	61.2	52.3
	5%	DB	51.8	54.0	60.7	69.0	76.0	81.0	88.6	90.0	85.3	76.8	67.4	57.4
		MCWB	45.1	47.2	52.1	57.7	63.1	70.2	77.1	77.5	74.3	67.2	59.8	50.4
	10%	DB	49.9	51.7	58.1	66.6	74.1	79.1	86.8	88.5	83.4	74.8	65.3	55.2
		MCWB	43.2	45.2	50.2	56.5	62.5	69.6	76.5	77.0	73.6	65.6	58.1	48.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	56.9	58.7	65.4	69.9	75.6	80.1	80.2	78.5	74.5	66.0	57.8
		MCDB	55.2	60.4	62.8	69.6	74.0	81.5	88.5	89.1	85.5	79.3	68.9	60.5
	2%	WB	48.6	51.6	55.8	62.5	68.0	74.4	78.9	79.3	77.2	72.0	63.5	53.8
		MCDB	52.3	55.6	60.6	66.9	72.6	79.7	86.9	87.7	83.8	77.1	67.4	57.6
	5%	WB	46.2	48.7	53.8	60.6	66.3	73.3	78.0	78.7	76.2	69.5	61.4	51.7
		MCDB	50.4	52.6	58.8	65.8	71.8	78.3	85.7	86.8	82.7	74.8	66.1	56.1
	10%	WB	44.1	46.2	51.7	58.8	64.8	72.0	77.2	78.0	75.3	67.0	59.1	49.5
		MCDB	49.1	51.0	57.4	64.6	71.1	76.8	84.7	85.9	81.6	73.1	64.5	54.6
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	11.8	13.1	13.6	13.3	10.7	9.8	10.4	10.6	11.8	12.0	11.5
		MCDBR	13.3	14.5	16.2	16.5	16.2	13.3	11.8	12.0	11.7	12.6	13.1	13.6
		MCWBR	9.8	10.2	10.7	8.8	7.6	5.6	4.2	4.2	5.0	7.3	8.9	9.6
	5% WB	MCDBR	12.2	12.6	13.7	12.6	11.9	9.1	11.0	11.0	9.8	10.2	11.3	12.0
		MCWBR	10.1	10.2	10.9	8.2	7.2	4.6	4.2	4.2	4.6	7.3	9.1	10.0
(40) Clear-Sky Solar Irradiance	taub		0.405	0.449	0.511	0.540	0.541	0.559	0.559	0.529	0.488	0.442	0.418	0.399
	taud		2.140	2.045	1.898	1.880	1.943	1.977	2.029	2.113	2.188	2.221	2.192	2.174
	Ebn at Noon		245	247	242	242	244	238	237	243	246	247	239	239
	Edh at Noon		38	47	59	63	60	58	55	49	44	39	36	35
(44) All-Sky Solar Radiation	RadAvg		707	915	1243	1523	1684	1462	1559	1612	1295	1077	791	619
	RadStd		54	75	98	140	167	155	208	156	128	105	64	43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page