

KURE, Japan

WMO: 477660

Lat: 34.2411N

Lon: 132.5503E

Elev: 5

StdP: 101.26

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	1.0	-8.1	1.9	4.4	-6.8	2.1	4.3	8.8	7.2	7.9	7.4	2.9	40	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.8	32.6	25.3	31.7	25.1	30.8	24.8	26.2	30.7	25.7	30.1	25.3	29.5	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	19.9	28.7	24.4	19.4	28.4	24.0	18.9	28.2	81.3	30.8	79.3	30.3	77.6	29.7	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.5	5.6	DB	-1.8	34.0	1.4	0.9	-2.8	34.6	-3.6	35.1	-4.4	35.6	-5.4	36.2	(4)
(5)			WB	-3.6	26.7	1.3	0.6	-4.5	27.2	-5.3	27.6	-6.0	27.9	-6.9	28.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	6.0	6.5	9.6	14.5	19.2	22.7	26.9	28.3	24.8	19.5	13.6	8.4	(6)	
	DBStd	8.04	2.22	2.63	2.86	2.82	2.03	1.85	2.11	1.63	2.43	2.64	2.96	2.70	(7)	
	HDD10.0	342	127	102	43	3	0	0	0	0	0	0	4	64	(8)	
	HDD18.3	1586	384	330	271	118	14	0	0	0	0	18	142	308	(9)	
	CDD10.0	2794	1	5	30	137	287	380	523	567	444	293	113	14	(10)	
	CDD18.3	996	0	0	0	2	42	130	265	308	194	53	2	0	(11)	
	CDH23.3	8285	0	0	0	5	103	538	2561	3488	1450	141	0	0	(12)	
	CDH26.7	2527	0	0	0	0	4	59	822	1307	328	7	0	0	(13)	
(14) Wind	WSAvg	2.3	2.7	2.5	2.5	2.3	2.1	1.9	2.2	2.3	2.3	2.3	2.4	2.7	(14)	
(15) Precipitation	PrecAvg	1413	49	65	112	126	160	215	235	111	139	93	72	46	(15)	
	PrecMax	2172	144	117	228	214	345	481	583	314	248	264	151	104	(16)	
	PrecMin	829	9	26	48	36	38	38	33	13	50	16	16	3	(17)	
	PrecStd	308	30	27	43	47	69	105	159	85	64	70	41	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	16.6	19.4	23.9	27.1	29.7	33.5	34.0	31.9	27.7	22.1	16.9	(19)	
		MCWB	10.1	12.2	13.3	15.8	17.9	23.0	25.6	25.6	24.8	22.2	16.8	12.3	(20)	
	2%	DB	12.1	13.9	17.5	21.9	25.6	28.2	32.3	33.1	30.7	26.0	20.8	15.3	(21)	
		MCWB	8.3	9.8	12.0	14.7	17.7	21.8	25.3	25.5	24.0	20.7	16.2	11.3	(22)	
	5%	DB	11.0	12.2	16.0	20.5	24.4	27.2	31.4	32.2	29.6	24.9	19.7	14.1	(23)	
		MCWB	7.3	8.5	11.2	14.3	17.3	21.2	25.0	25.3	23.5	19.6	15.5	10.2	(24)	
	10%	DB	10.0	10.9	14.5	19.2	23.4	26.2	30.5	31.4	28.6	23.8	18.5	12.9	(25)	
		MCWB	6.2	7.3	10.1	13.6	17.0	20.9	24.7	25.0	23.1	18.7	14.5	9.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	13.8	14.8	18.5	21.1	24.2	26.7	26.8	25.8	23.6	18.9	14.3	(27)	
		MCDB	12.9	15.8	17.1	20.9	23.3	27.5	31.4	31.7	29.7	26.3	20.5	15.9	(28)	
	2%	WB	9.2	10.9	13.2	16.9	20.0	23.6	26.1	26.3	25.1	22.2	17.5	12.1	(29)	
		MCDB	11.3	13.1	15.9	19.4	22.5	26.5	30.5	31.0	28.8	25.0	19.7	14.2	(30)	
	5%	WB	7.9	9.3	12.1	15.9	19.1	23.0	25.5	25.9	24.6	20.8	16.3	10.9	(31)	
		MCDB	10.2	11.4	14.9	18.8	22.1	25.7	29.8	30.5	28.2	23.8	19.0	13.4	(32)	
	10%	WB	6.7	7.9	10.9	14.9	18.2	22.2	25.1	25.6	24.0	19.4	15.0	9.7	(33)	
		MCDB	9.5	10.6	14.1	18.1	21.7	24.9	29.3	30.0	27.5	22.9	18.1	12.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.6	7.3	7.5	7.4	5.9	5.4	5.8	5.9	6.5	6.7	6.4	(35)	
		MCDBR	7.4	8.1	9.0	9.1	9.0	7.4	6.6	6.7	6.5	7.0	7.3	7.5	(36)	
	5% WB	MCWBR	5.4	5.7	6.0	4.9	4.2	3.1	2.4	2.3	2.8	4.1	5.0	5.3	(37)	
		MCWBR	6.8	7.0	7.6	7.0	6.6	5.1	6.1	6.1	5.4	5.7	6.3	6.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.405	0.449	0.511	0.540	0.541	0.559	0.559	0.529	0.488	0.442	0.418	0.399	(40)	
		taud	2.140	2.045	1.898	1.880	1.943	1.977	2.029	2.113	2.188	2.221	2.192	2.174	(41)	
	Ebn at Noon		773	779	763	763	768	751	748	765	777	780	755	753	(42)	
		Edh at Noon	121	148	186	198	188	182	172	155	138	123	115	111	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.23	2.89	3.92	4.80	5.31	4.61	4.91	5.08	4.08	3.40	2.49	1.95	(44)	
	RadStd		0.17	0.24	0.31	0.44	0.53	0.49	0.66	0.49	0.41	0.33	0.20	0.14	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page