

KANSAI INTL, Japan

WMO: 477740

Lat: 34.434N

Lon: 135.233E

Elev: 27

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.2	37.0	17.5	13.3	38.4	19.6	14.8	39.7	32.1	41.4	29.6	40.9	15.5	290	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.5	91.5	77.9	89.7	77.6	87.9	77.4	80.3	86.4	79.6	85.6	78.9	84.7	11.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.1	83.9	77.4	142.5	83.3	77.0	140.8	83.1	44.1	87.1	43.2	85.8	42.4	85.3	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.0	24.3	21.3	DB	31.8	94.5	2.7	1.6	29.8	95.6	28.2	96.6	26.7	97.5	24.7	98.7	(4)
(5)			WB	26.6	81.7	2.2	1.4	25.0	82.7	23.7	83.6	22.5	84.4	20.9	85.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	43.8	44.1	49.3	58.1	66.9	73.6	81.0	83.9	77.7	68.1	58.1	48.8	(6)
(7)		DBStd	14.44	3.64	4.21	4.75	4.98	3.81	3.50	3.67	2.84	4.39	4.54	4.98	4.55	(7)
(8)		HDD50	522	194	173	72	4	0	0	0	0	0	0	2	77	(8)
(9)		HDD65	2699	657	586	486	211	24	0	0	0	0	20	213	502	(9)
(10)		CDD50	5225	2	7	51	246	525	707	960	1051	831	562	243	40	(10)
(11)		CDD65	1929	0	0	0	4	84	257	495	586	381	117	5	0	(11)
(12)		CDH74	16009	0	0	0	5	162	1060	4796	6766	2936	282	2	0	(12)
(13)		CDH80	5035	0	0	0	0	7	144	1501	2667	698	18	0	0	(13)
(14)	Wind	WSAvg	9.9	11.9	10.5	10.3	9.4	8.6	8.3	9.0	9.1	9.3	9.8	10.2	11.9	(14)
(15)	Precipitation	PrecAvg	57.8	2.0	2.8	4.1	4.2	6.1	7.7	6.4	4.5	7.8	5.7	4.1	2.5	(15)
(16)		PrecMax	75.8	4.9	6.6	7.4	9.0	17.2	15.0	16.1	18.5	16.9	13.2	12.3	6.0	(16)
(17)		PrecMin	29.5	0.2	0.9	2.2	1.5	1.7	3.1	1.7	0.4	1.4	1.3	0.7	0.2	(17)
(18)		PrecStd	11.2	1.2	1.5	1.3	1.7	3.6	3.0	3.8	3.7	4.0	3.1	2.6	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	60.9	64.8	73.7	80.7	86.3	93.2	93.6	89.9	82.3	71.9	64.1	(19)
(20)			MCWB	49.9	56.6	56.5	62.5	65.9	74.8	78.6	78.1	77.4	73.0	64.4	58.6	(20)
(21)		2%	DB	53.4	55.7	62.4	70.1	77.4	83.9	91.0	91.8	87.9	79.0	69.7	59.3	(21)
(22)			MCWB	47.6	49.9	55.7	60.7	65.5	73.6	78.2	77.8	76.4	70.0	63.2	53.5	(22)
(23)		5%	DB	51.6	53.2	59.3	68.1	75.4	81.0	89.2	91.0	86.0	77.1	67.9	57.4	(23)
(24)			MCWB	45.8	47.8	52.7	59.7	64.5	71.3	77.9	77.7	75.1	68.8	61.2	51.2	(24)
(25)		10%	DB	49.8	50.3	57.2	66.0	73.5	79.1	86.4	89.4	84.1	75.1	66.1	55.6	(25)
(26)			MCWB	44.2	45.3	51.1	58.4	63.8	70.9	77.2	77.5	74.3	66.4	59.6	49.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.8	56.8	59.8	66.9	71.7	77.6	81.3	81.9	80.0	75.7	67.3	60.0	(27)
(28)			MCD B	55.3	59.8	62.9	70.2	75.5	83.2	87.1	86.7	85.8	79.5	69.7	62.6	(28)
(29)		2%	WB	49.2	51.8	56.6	63.9	69.3	76.1	80.0	80.7	78.9	72.6	64.8	55.2	(29)
(30)			MCD B	51.3	54.9	60.6	67.5	73.4	80.8	86.3	86.7	84.1	77.1	68.4	58.8	(30)
(31)		5%	WB	46.8	49.1	54.2	61.5	67.4	74.8	79.3	79.9	77.8	70.3	62.6	52.5	(31)
(32)			MCD B	50.2	51.5	58.5	66.1	72.1	78.8	85.3	86.0	83.0	75.1	66.6	56.6	(32)
(33)		10%	WB	44.5	46.5	51.9	59.6	65.7	73.3	78.4	79.3	76.5	68.3	60.3	50.5	(33)
(34)			MCD B	48.5	49.8	56.4	64.4	71.0	77.3	84.3	85.2	81.9	73.4	64.9	54.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.1	10.8	12.0	12.2	10.3	9.9	10.5	9.6	9.3	8.7	8.1	(35)
(36)			MCDBR	10.0	12.2	13.9	14.6	14.8	12.5	12.1	12.1	11.1	10.8	10.4	10.2	(36)
(37)			MCWBR	8.6	9.8	10.2	8.4	7.4	5.5	4.7	4.7	5.4	6.9	8.7	8.9	(37)
(38)		5% WB	MCD BR	9.6	11.1	13.2	12.4	11.9	10.0	11.2	10.7	9.7	9.5	10.1	10.0	(38)
(39)			MCWBR	9.3	10.4	11.4	9.1	8.1	5.5	4.8	4.8	5.5	7.8	9.7	10.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.403	0.448	0.509	0.543	0.547	0.566	0.568	0.536	0.494	0.454	0.423	0.398	(40)	
(41)		taud	2.157	2.050	1.904	1.876	1.933	1.963	2.004	2.083	2.172	2.199	2.187	2.183	(41)	
(42)		Ebn at Noon	246	247	242	241	242	237	235	240	245	243	237	239	(42)	
(43)		Edh at Noon	38	47	59	63	60	58	56	51	44	40	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	756	955	1264	1525	1659	1489	1606	1646	1291	1047	804	682	(44)	
(45)		RadStd	53	71	94	136	167	143	200	143	110	104	67	42	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page